



Sandy Creek Central School District

"Comet Pride is Community-Wide!"

May 7, 2021

Kyle L. Faulkner

*Superintendent of
Schools*

Shelley H. Fitzpatrick

*Business
Administrator*

Board of Education:

John Shelmidine

President

Brian MacVean

Vice-President

Mark Haynes

Joseph Hathway

Heidi Metott

Andrea Harris

Michele Warner

Timothy Filiatrault

*Elementary School
Principal*

Kevin Seymour

High School Principal

Amy Howard-

McCormack

*Dir. of Curriculum &
Inst.*

Dear Parents/Guardians and Community Members:

Every five years the New York State Department of Education requires all school districts to test for lead in their drinking water. We completed our testing on April 21, 2021, and received the test results back on April 27, 2021. The New York State legislation requires all water sources to be under 15 parts per billion (ppb). We tested a total of 153 outlets and nine (9) outlets came back above the 15 ppb threshold. All elevated outlets have been pulled from service and have signage placed that state "Do Not Drink." The results are as follows:

Elementary School - We tested 57 outlets and 7 came back elevated. (Room 1014 - Classroom, Room 1010 - Elementary Art Room sink c on west side, Room 1107 - Elementary Art Room sinks A & B on east side, Men's Room sink by Elementary basement, Room 1116 - Elementary Library Office sink, Room 1108 - Elementary Principal's Office sink). We have replaced 2 faucets and replaced the other aerators and are retesting May 7, 2021.

Middle School - We tested 23 outlets and all are below the 15 ppb threshold.

High School - We tested 55 outlets and 2 came back elevated. (Kitchen Steamer, and Girls Bathroom sink A by High School Office). We have replaced one faucet, one inlet line and one wye.

Gymnasium Complex - We tested 18 outlets and all are below the 15 ppb threshold.

Please feel free to refer to our website at www.sandycreekcsd.org, as we will post all results of the lead testing at Sandy Creek Central School District. Do not hesitate to contact me if you have any questions or concerns.

Sincerely,

Kyle L. Faulkner
Superintendent of Schools

KLF/vls