



# Sandy Creek Central School District

**"Comet Pride is Community-Wide!"**

May 7, 2021

Dear Parents/Guardians and Community Members:

Every five years the New York State Department of Education requires all school districts to test for lead in their drinking water. We completed our testing on April 21, 2021, and received the test results back on April 27, 2021. The New York State legislation requires all water sources to be under 15 parts per billion (ppb). We tested a total of 153 outlets and nine (9) outlets came back above the 15 ppb threshold. All elevated outlets have been pulled from service and have signage placed that state "Do Not Drink." The results are as follows:

Elementary School - We tested 57 outlets and 7 came back elevated. (Room 1014 - Classroom, Room 1010 - Elementary Art Room sink c on west side, Room 1107 - Elementary Art Room sinks A & B on east side, Men's Room sink by Elementary basement, Room 1116 - Elementary Library Office sink, Room 1108 - Elementary Principal's Office sink). We have replaced 2 faucets and replaced the other aerators and are retesting May 7, 2021.

Middle School - We tested 23 outlets and all are below the 15 ppb threshold.

High School - We tested 55 outlets and 2 came back elevated. (Kitchen Steamer, and Girls Bathroom sink A by High School Office). We have replaced one faucet, one inlet line and one wye.

Gymnasium Complex - We tested 18 outlets and all are below the 15 ppb threshold.

Please feel free to refer to our website at [www.sandycreekcscd.org](http://www.sandycreekcscd.org), as we will post all results of the lead testing at Sandy Creek Central School District. Do not hesitate to contact me if you have any questions or concerns.

Sincerely,



Kyle L. Faulkner  
Superintendent of Schools

KLF/vls

Kyle L. Faulkner  
Superintendent of Schools  
Shelley H. Fitzpatrick  
Business Administrator

**Board of  
Education:**

John Shelmidine  
President  
Brian MacVean  
Vice-President  
Mark Haynes  
Joseph Hathway  
Heidi Metott  
Andrea Harris  
Michele Warner

Timothy Filiatrault  
Elementary School Principal  
Kevin Seymour  
Middle/High School Principal  
Amy Howard-McCormack  
Dir. of Curriculum & Inst.

# Water Testing Summary

## Sandy Creek Central School District

### 2021

We have tested a total of 211 outlets and a total of (5) have been retested on 10/15/2021 because they were above the 15ppb threshold. One new bottle fill station was also tested at this time.

The Elementary school – we tested 58 outlets and currently we are waiting on (1) retest and one recently installed bottle fill station.

The Middle school – We tested 60 outlets and are waiting on (3) retests.

The High school – We tested 56 outlets and are waiting on (1) retest.

The Gymnasium – We tested 38 outlets and all were good.

# Water Testing Summary

## Sandy Creek Central School District

### November 2, 2021

As of November 2, 2021 I received the test results that we were waiting on and all came back below the 15ppb threshold. All of our drinking sources have met or are better than the minimum standards for LEAD testing.



## Lead Samples 2021 SCCS Buildings and Grounds

Bldg	Letter	Sample Id #	Sample Loc/Rm	Flushed	Flush Time	Staff	Date Sampled	Sampler	Time Sample	<15PPB	>15PPB	Note	Retest Date
Elem	A	001	Rm 1202 Sink	4/20/2021	7:54pm	AR	4/21/2021	AR	7:21am	1.9			
Elem	A	002	Rm 1203 Sink	4/20/2021	7:55pm	AR	4/21/2021	AR	7:22am	7			
Elem	A	003	Rm 1204 Sink	4/20/2021	7:57pm	AR	4/21/2021	AR	7:23am	1.7			
Elem	A	004	Rm 1205 Sink	4/20/2021	7:56pm	AR	4/21/2021	AR	7:24am	2.1			
Elem	A	005	Rm 1206 Sink	4/20/2021	7:57pm	AR	4/21/2021	AR	7:25am	5.2			
Elem	A	006	Rm 1207 Sink	4/20/2021	7:58pm	AR	4/21/2021	AR	7:23am	2.1			
Elem	A	007	Rm 1208 Sink	4/20/2021	7:59pm	AR	4/21/2021	AR	7:24am	<1.0			
Elem	A	008	Rm 1302 Sink	4/20/2021	8:00pm	AR	4/21/2021	AR	7:26am	1.8			
Elem	A	009	Rm 1303 Sink	4/20/2021	8:02pm	AR	4/21/2021	AR	7:26am	1.3			
Elem	A	010	Rm 1304 Sink	4/20/2021	8:03pm	AR	4/21/2021	AR	7:27am	2.1			
Elem	A	011	Rm 1305 Sink	4/20/2021	8:04pm	AR	4/21/2021	AR	7:27am	1.8			
Elem	A	012-2	Rm 1014 Sink	5/6/2021	7:05pm	AR	5/7/2021	AR	6:06am	1.9			
Elem	A	013	Rm 1013 Sink	4/20/2021	8:07pm	AR	4/21/2021	AR	7:13am	<1.0			
Elem	A	014	Rm 1310 Sink	4/20/2021	8:09pm	AR	4/21/2021	AR	7:30am	3			
Elem	A	015	South West Hall Sink	4/20/2021	8:05pm	AR	4/21/2021	AR	7:28am	<1.0			
Elem	A	016	North West Hall Sink	4/20/2021	8:08pm	AR	4/21/2021	AR	7:28am	1			
Elem	A	017	Rm 1011 Sink	4/20/2021	8:14pm	AR	4/21/2021	AR	7:31am	4.6			
Elem	A	018	Rm 1012 Sink	4/20/2021	8:12pm	AR	4/21/2021	AR	7:32am	9.2			
Elem	A	019	Rm 1009 Sink	4/20/2021	8:15pm	AR	4/21/2021	AR	7:32am	3.7			
Elem	A	020	Rm 1010 A Sink	4/20/2021	8:16pm	AR	4/21/2021	AR	7:33am	4.2			
Elem	A	021	Rm 1010 B Sink	4/20/2021	8:17pm	AR	4/21/2021	AR	7:33am	13.1			
Elem	A	022-1	Rm 1010 C Sink	5/6/2021	7:07pm	AR	5/7/2021	AR	6:11am	11.4			
Elem	A	023-1	Rm 1107 A Sink	5/6/2021	7:08pm	AR	5/7/2021	AR	6:12am	5.9			
Elem	A	024-1	Rm 1107 B Sink	5/6/2021	7:10pm	AR	4/21/2021	AR	6:12am	8.4			
Elem	A	025-1	Men's Rm Sink	5/6/2021	7:11pm	AR	5/7/2021	AR	6:08am	1.1			
Elem	A	026	Ladie's Rm Sink	4/20/2021	8:20pm	AR	4/21/2021	AR	7:36am	3.5			
Elem	A	027	3rd gr Boys Sink A	4/20/2021	8:09pm	AR	4/21/2021	AR	7:41am	<1.0			
Elem	A	028	3rd gr Boys Sink B	4/20/2021	8:09pm	AR	4/21/2021	AR	7:41am	<1.0			
Elem	A	029	3rd gr Girls A Sink	4/20/2021	8:10pm	AR	4/21/2021	AR	7:40am	1.1			
Elem	A	030	3rd gr Girls B Sink	4/20/2021	8:10pm	AR	4/21/2021	AR	7:40am	<1.0			



## Lead Samples 2021 SCCS Buildings and Grounds

Bldg	Letter	Sample Id #	Sample Loc/Rm	Flushed	Flush Time	Staff	Date Sampled	Sampler	Time Sample	<15PPB	>15PPB	Note	Retest Date
Elem	A	031	4th gr Bottle Fill #1	4/20/2021	8:11pm	AR	4/21/2021	AR	7:42am	<1.0			
Elem	A	032	5th gr Bottle Fill #2	4/20/2021	8:22pm	AR	4/21/2021	AR	7:17am	<1.0			
Elem	A	033	5th gr Boys Bathrm Sink A	4/20/2021	8:21pm	AR	4/21/2021	AR	7:43am	2.5			
Elem	A	034	5th gr Boys Bathrm Sink B	4/20/2021	8:21pm	AR	4/21/2021	AR	7:43am	5.6			
Elem	A	035	5th gr Boys Bathrm Sink C	4/20/2021	8:21pm	AR	4/21/2021	AR	7:43am	3.3			
Elem	A	036	5th gr girls Bathrm Sink A	4/20/2021	8:23pm	AR	4/21/2021	AR	7:16am	2			
Elem	A	037	5th gr girls bathrm Sink B	4/20/2021	8:23pm	AR	4/21/2021	AR	7:16am	2.9			
Elem	A	038	5th gr girls bathrm Sink C	4/20/2021	8:23pm	AR	4/21/2021	AR	7:16am	2.2			
Elem	A	039	Teach Common's Men Sink	4/20/2021	8:24pm	AR	4/21/2021	AR	7:15am	6.3			
Elem	A	040	Teach Common Ladies Sink	4/20/2021	8:24pm	AR	4/21/2021	AR	7:14am	<1.0			
Elem	A	041	Rm 1440 Exam Rm North	4/20/2021	8:45pm	AR	4/21/2021	AR	7:10am	6.4			
Elem	A	042	Rm 1440 Exam Rm South	4/20/2021	8:46pm	AR	4/21/2021	AR	7:10am	5.9			
Elem	A	043	Rm 1440 Supply Rm sink	4/20/2021	8:47pm	AR	4/21/2021	AR	7:11am	<1.0			
Elem	A	044	Dental Office A	4/20/2021	8:48pm	AR	4/21/2021	AR	7:09am	2			
Elem	A	045	Bottle #18	4/20/2021	9:02pm	AR	4/21/2021	AR	7:50am	<1.0			
Elem	A	046	SBHC Bathroom Sink	4/20/2021	8:49pm	AR	4/21/2021	AR	7:08am	<1.0			
Elem	A	047	Nurses Bathroom	4/20/2021	8:50pm	AR	4/21/2021	AR	7:06am	<1.0			
Elem	A	048	Laundry Rm bathrm sink	4/20/2021	8:51pm	AR	4/21/2021	AR	7:08am	<1.0			
Elem	A	049-1	Rm 1116 Sink	5/6/2021	7:15pm	AR	5/7/2021	AR	6:17am	3.7			
Elem	A	050/403	Rm 1108 Sink	10/14/2021	7:25pm	AR	10/15/2021	AR	6:47am	1.3			
Elem	A	404	Bottle Fill Station	10/14/2021	7:25pm	AR	10/15/2021	AR	6:52am	<1.0			
Elem	A	051	Rm 1105 Sink	4/20/2021	7:53pm	AR	4/21/2021	AR	7:20am	<1.0			
Elem	A	052	Rm 1425 Sink	4/20/2021	8:26pm	AR	4/21/2021	AR	7:13am	1.7			
Elem	A	053	Rm 1428 Sink	4/20/2021	8:27pm	AR	4/21/2021	AR	7:46am	3.8			
Elem	A	054	Rm 1429 Sink	4/20/2021	8:29pm	AR	4/21/2021	AR	7:47am	10.3			
Elem	A	055	Rm 1440 Sink Lab	4/20/2021	8:50pm	AR	4/21/2021	AR	7:10am	1.8			
Elem	A	056	Rm 1502 Sink Nurse	4/20/2021	8:52pm	AR	4/21/2021	AR	7:05am	<1.0			
Elem	A	057	Rm 1460 Sink	4/20/2021	9:01pm	AR	4/21/2021	AR	7:51am	2.2			



## Lead Samples 2021 SCCS Buildings and Grounds

Bldg	Letter	Sample Id #	Sample Loc/Rm	Flushed	Flush Time	Staff	Date Sampled	Sampler	Time Sampled	<15PPB	>15PPB	Note	Retest Date
H.S	B	100	Kitch Portable Sink cooler	4/20/2021	6:57pm	AR	4/21/2021	AR	5:10am	1.5			
H.S	B	101	Kitch East Wall Sray	4/20/2021	6:53pm	AR	4/21/2021	AR	5:12am	10.8			
H.S	B	102	Kitch Sink East Wall A	4/20/2021	6:54pm	AR	4/21/2021	AR	5:13am	1.8			
H.S	B	103	Kitch Sink East Wall B	4/20/2021	6:55pm	AR	4/21/2021	AR	5:14am	3.2			
H.S	B	104	Kitch Pedal Sink	4/20/2021	6:56pm	AR	4/21/2021	AR	5:14am	3.8			
H.S	B	105	Kitch Dish Sprayer	4/20/2021	6:58pm	AR	4/21/2021	AR	5:16am	3.1			
H.S	B	106	Kitch Kettle	4/20/2021	6:59pm	AR	4/21/2021	AR	5:17am	2.6			
H.S	B	107	Kitch Sink on West Wall	4/20/2021	7:00pm	AR	4/21/2021	AR	5:18am	6.3			
H.S	B	108	Kitch Pedal Sink South Wall	4/20/2021	7:00pm	AR	4/21/2021	AR	5:19am	5.9			
H.S	B	109	Kitch Center Island West Sprayer	4/20/2021	7:01pm	AR	4/21/2021	AR	5:20am	9.3			
H.S	B	110	Kitch Center Faucet	4/20/2021	7:01pm	AR	4/21/2021	AR	5:21am	1.1			
H.S	B	111	Kitch Center Island East Sprayer	4/20/2021	7:02pm	AR	4/21/2021	AR	5:22am	2.9			
H.S	B	112	Kitch Ice	4/20/2021		AR	4/21/2021	AR	5:23am	<1.0			
H.S	B	113	Kitch Tray Return Sprayer	4/20/2021	6:55pm	AR	4/21/2021	AR	5:24am	4.3			
H.S	B	114	Kitch Tray Return Faucet	4/20/2021	6:56pm	AR	4/21/2021	AR	5:25am	2.6			
H.S	B		Kitch Serving Island Sink EL										
H.S	B	116	Kitc SW Wall replace sink EL	4/20/2021	7:05pm	AR	4/21/2021	AR	5:26am	5.1			
H.S,	B	405/117	Kitch Steamer	10/14/2021	7:15PM	AR	10/15/2021	AR	6:15am	<1.0			
H.S	B	118	Kitch Serving Pedel Sink	4/20/2021	7:05pm	AR	4/21/2021	AR	5:29am	1.4			
H.S	B	119	Drink Fount #3	4/20/2021	7:10pm	AR	4/21/2021	AR	5:37am	<1.0			
H.S	B	120	H.S.Off Sink	4/20/2021	7:12pm	AR	4/21/2021	AR	5:39am	1.7			
H.S	B	121	D.F. #4	4/20/2021	7:14pm	AR	4/21/2021	AR	5:42am	<1.0			
H.S	B	122	Home EC Sink 1	4/20/2021	7:22pm	AR	4/21/2021	AR	5:55am	1.1			
H.S	B	123	Home EC Sink 2	4/20/2021	7:22pm	AR	4/21/2021	AR	5:55am	1.3			
H.S	B	124	Home EC Sink 3	4/20/2021	7:23pm	AR	4/21/2021	AR	5:56am	1.1			
H.S	B	125	Home EC Sink 4	4/20/2021	7:24pm	AR	4/21/2021	AR	5:57am	1.9			
H.S	B	126	Home EC Sink 5	4/20/2021	7:24pm	AR	4/21/2021	AR	5:58am	3.8			
H.S	B	128	Custodiam Sink	4/20/2021	7:42pm	AR	4/21/2021	AR	7:55am	<1.0			

## Lead Samples 2021 SCCS Buildings and Grounds

Bldg	Letter	Sample Id #	Sample Loc/Rm	Flushed	Flush Time	Staff	Date Sampled	Sampler	Time Sampled	<15PPB	>15PPB	Note	Retest Date
HS/MS	B	129											
HS/MS	B	130	Bottled H2O	4/20/2021	6:51pm	AR	4/21/2021	AR	8:26am	<1.0			
HS/MS	B	131	DO Supt Sink	4/20/2021	6:52pm	AR	4/21/2021	AR	5:34am	<1.0			
HS/MS	B	132	DO bathroom Sink	4/20/2021	6:50pm	AR	4/21/2021	AR	5:32am	1.5			
HS/MS	B	133	DO Sink	4/20/2021	6:54pm	AR	4/21/2021	AR	5:31am	2			
HS/MS	B	134-1	Girls bath sinkA by HS Off	5/6/2021	7:20pm	AR	5/7/2021	AR	6:20am	4.3			
HS/MS	B	135	Girls sink B	4/20/2021	7:08pm	AR	4/21/2021	AR	5:46am	1.5			
HS/MS	B	136	Girls Sink C	4/20/2021	7:08pm	AR	4/21/2021	AR	5:47am	1.3			
HS/MS	B	137	Rm 1908 Sink	4/20/2021	7:13pm	AR	4/21/2021	AR	5:40am	1.2			
HS/MS	B	138	HS Office Sink M.S.	4/20/2021	7:12pm	AR	4/21/2021	AR	5:40am	<1.0			
HS/MS	B	139	Rm 1940 Sink	4/20/2021	7:13pm	AR	4/21/2021	AR	5:43am	2.7			
HS/MS	B	140	Boy's Bathroom Sink A	4/20/2021	7:17pm	AR	4/21/2021	AR	5:45am	1.2			
HS/MS	B	141	Boys Bathroom Sink B	4/20/2021	7:18pm	AR	4/21/2021	AR	5:45am	8.5			
HS/MS	B	142	Rm 1711 Sink 1	4/20/2021	7:21pm	AR	4/21/2021	AR	5:50am	<1.0			
HS/MS	B	143	Rm 1707 Lav Sink 2	4/20/2021	7:20pm	AR	4/21/2021	AR	5:51am	<1.0			
HS/MS	B	144	Rm 1707 A Sink	4/20/2021	7:22pm	AR	4/21/2021	AR	5:52am	<1.0			
HS/MS	B	145	Rm 1707 B Sink	4/20/2021	7:22pm	AR	4/21/2021	AR	5:52am	<1.0			
HS/MS	B	146	Rm 1707 C Sink	4/20/2021	7:23pm	AR	4/21/2021	AR	5:53am	2.8			
HS/MS	B	147	Rm 1707 D Sink	4/20/2021	7:23pm	AR	4/21/2021	AR	5:54am	<1.0			
HS/MS	B	148	Rm 1617 Sink A	4/20/2021	9:16pm	AR	4/21/2021	AR	6:36am	1.2			
HS/MS	B	149	Rm 1617 Sink B	4/20/2021	9:17pm	AR	4/21/2021	AR	6:37am	<1.0			
HS/MS	B	150	Girls Bath Sink A HS Lib	4/20/2021	7:25pm	AR	4/21/2021	AR	6:00am	2.8			



## Lead Samples 2021 SCCS Buildings and Grounds

[illegible]

## Lead Samples 2021 SCCS Buildings and Grounds

Bldg	Letter	Sample Id #	Sample Loc/Rm	Flushed	Flush Time	Staff	Date Sampled	Sampler	Time Sampled	<15PPB	>15PPB	Note	Retest Date
HS/MS	B	200	M/S Girls Bath sink A 6th	4/20/2021	7:40pm	AR	4/21/2021	AR	6:26am	3.3			
HS/MS	B	201	M/S Girls Bath sink B 6th	4/20/2021	7:40pm	AR	4/21/2021	AR	6:26am	1.8			
HS/MS	B	202	M/S Boys Sink A 6th	4/20/2021	7:40pm	AR	4/21/2021	AR	6:24am	<1.0			
HS/MS	B	203	M/S Boys Sink B 6th	4/20/2021	7:40pm	AR	4/21/2021	AR	6:25am	<1.0			
HS/MS	B	204	Foun Bottle #10	4/20/2021	7:40pm	AR	4/21/2021	AR	6:23am	<1.0			
Hs/MS	B	400/223	Rm 2701 Sink A	10/14/2021	7:20pm	AR	10/15/2021	AR	7.15am	<1.0			
HS/MS	B	224	Rm 2701 Sink B	5/6/2021	7:20pm	AR	5/7/2021	AR	6:27am	6			
HS/MS	B	225	Rm 2701 Sink C	5/6/2021	7:22pm	AR	5/7/2021	AR	6:28am	4.5			
HS/MS	B	226	Rm 2701 Sink D	5/6/2021	7:22pm	AR	5/7/2021	AR	6:29am	3.2			
HS/MS	B	227	Rm 2701 Sink E	5/6/2021	7:23pm	AR	5/7/2021	AR	6:31am	3.6			
HS/MS	B	205	Rm 2701 Office Sink	4/20/2021	7:36pm	AR	4/21/2021	AR	6:22am	1.5			
HS/MS	B	228	Rm 2701 Sink F	5/6/2021	7:23pm	AR	5/7/2021	AR	6:32am	4.1			
HS/MS	B	229	Rm 2705 Sink A	5/6/2021	7:27pm	AR	5/7/2021	AR	6:33am	3			
HS/MS	B	230	Rm 2705 Sink B	5/6/2021	7:27pm	AR	5/7/2021	AR	6:35am	1.8			
HS/MS	B	231	Rm 2705 Sink C	5/6/2021	7:28pm	AR	5/7/2021	AR	6:36am	1.4			
HS/MS	B	232	Rm 2705 Sink D	5/6/2021	7:29pm	AR	5/7/2021	AR	6:38am	3.8			
HS/MS	B	233	Rm 2705 Sink E	5/6/2021	7:30pm	AR	5/7/2021	AR	6:39am	1.8			
HS/MS	B	234	Rm 2705 Sink F	5/6/2021	7:30pm	AR	5/7/2021	AR	6:40am	8.4			
HS/MS	B	206	Rm 2706 Sink A	4/20/2021	7:33pm	AR	4/21/2021	AR	6:19am	2.5			
HS/MS	B	207	Rm 2706 Sink B	4/20/2021	7:34pm	AR	4/21/2021	AR	6:20am	3.7			
HS/MS	B	208	Rm 2706 Sink C	4/20/2021	7:35pm	AR	4/21/2021	AR	6:21am	3.5			



## Lead Samples 2021 SCCS Buildings and Grounds

Bldg	Letter	Sample Id #	Sample Loc/Rm	Flushed	Flush Time	Staff	Date Sampled	Sampler	Time Sampled	Results	>15PPB	Note	Retest Date
HS/MS	B	209	Rm 2720 Lavi sink	4/20/2021	7:32pm	AR	4/21/2021	AR	6:16am	4.8			
HS/MS	B	210	Rm 2716 sink	4/20/2021	7:33pm	AR	4/20/2021	AR	6:17am	1.5			
HS/MS	B	211	Gls Bath Sink by rm 2725A	4/20/2021	7:31pm	AR	4/21/2021	AR	6:15am	1.8			
HS/MS	B	212	Gls Bath Sink by rm 2725B	4/20/2021	7:31pm	AR	4/21/2021	AR	6:15am	1.7			
HS/MS	B	213	Fountain Bottle Fill #9	4/20/2021	7:30pm	AR	4/21/2021	AR	6:14am	<1.0			
HS/MS	B	214	Fountain Bottle Fill #8	4/20/2021	7:31pm	AR	4/21/2021	AR	6:16am	2.4			
HS/MS	B	215	Bottle fill #7	4/20/2021	7:31pm	AR	4/21/2021	AR	6:12am	1.3			
HS/MS	B	216	Rm 2907 Sink A	4/20/2021	7:29pm	AR	4/21/2021	AR	6:08am	4.2			
HS/MS	B	217	Rm 2907 Sink B	4/20/2021	7:29pm	AR	4/21/2021	AR	6:09am	4.8			
HS/MS	B	218	Rm 2517 Sink	4/20/2021	7:43pm	AR	4/21/2021	AR	6:30am	2.5			
HS/MS	B	402/235	Rm 2514 Sink A	10/14/2021	7:35pm	AR	10/15/2021	AR	6:42am	1.9			
HS/MS	B	236	Rm 2514 Sink B	5/6/2021		AR	5/7/2021	AR	6:47am	2.1			
HS/MS	B	237	Rm 2514 Sink C	5/6/2021		AR	5/7/2021	AR	6:48am	8.4			
HS/MS	B	238	Rm 2514 Sink D	5/6/2021		AR	5/7/2021	AR	6:49am	8.7			
HS/MS	B	239	Rm 2514 Sink E	5/6/2021		AR	5/7/2021	AR	6:50am	8.5			
HS/MS	B	240	Rm 2511 Sink A	5/6/2021		AR	5/7/2021	AR	6:51am	9.8			
HS/MS	B	241	Rm 2511 Sink B	5/6/2021		AR	5/7/2021	AR	6:52am	1			
HS/MS	B	242	Rm 2511 Sink C	5/6/2021		AR	5/7/2021	AR	6:53am	4.2			
HS/MS	B	243	Rm 2511 Sink D	5/6/2021		AR	5/7/2021	AR	6:55am	4.3			
HS/MS	B	244	Rm 2511 Sink E	5/6/2021		AR	5/7/2021	AR	6:56am	4.6			
HS/MS	B	245	Rm 2511 Sink F	5/6/2021		AR	5/7/2021	AR	6:57am	4.4			



## Lead Samples 2021 SCCS Buildings and Grounds

Bldg	Letter	Sample	Sample Loc/Rm	Flushed	Flush	Staff	Date Sampled	Sampler	Time Sampled	<15PPB	>15PPB	Note	Retest Date
HS/MS	B	219	Rm 2511 Office sink	4/20/2021	7:42pm	AR	4/21/2021	AR	6:29am	14.8			
HS/MS	B	401/246	Rm 2510 Sink A	10/14/2021	7:45pm	AR	10/15/2021	AR	6:50	4.7			
HS/MS	B	247	Rm 2510 Sink B	5/6/2021		AR	5/7/2021	AR	6:59am	4.2			
HS/MS	B	248	Rm 2510 Sink C	5/6/2021		AR	5/7/2021	AR	7:00am	4.1			
HS/MS	B	249	Rm 2510 Sink D	5/6/2021		AR	5/7/2021	AR	7:01am	1.3			
HS/MS	B	250	Rm 2510 Sink E	5/6/2021		AR	5/7/2021	AR	7:02am	3.7			
HS/MS	B	251	Rm 2510 Sink F	5/6/2021		AR	5/7/2021	AR	7:03am	4			
HS/MS	B	252	Rm 2506 Sink A	5/6/2021		AR	5/7/2021	AR	7:03am	8.1			
HS/MS	B	253	Rm 2506 Sink B	5/6/2021		AR	5/7/2021	AR	7:03am	4.2			
HS/MS	B	254	Rm 2506 Sink C	5/6/2021		AR	5/7/2021	AR	7:04am	<1.0			
HS/MS	B	255	Rm 2506 Sink D	5/6/2021		AR	5/7/2021	AR	7:04am	4.2			
HS/MS	B	256	Rm 2506 Sink E	5/6/2021		AR	5/7/2021	AR	7:06am	4.9			
HS/MS	B	220	2506 Off Sink	4/20/2021	7:41pm	AR	4/21/2021	AR	6:27am	1.9			
HS/MS	B	257	Rm 2506 Sink F	5/6/2021		AR	5/7/2021	AR	7:07am	1.9			
HS/MS	B	221	Boys A 2802	4/20/2021	7:42pm	AR	4/21/2021	AR	6:07am	3.6			
HS/MS	B	222	Boys B 2802	4/20/2021	7:42pm	AR	4/21/2021	AR	6:07am	3.2			
HS/MS	B	258	Rm 2705 Sink G	5/6/2021	8:11pm	AR	5/7/2021	AR	6:42am	1.7			
HS/MS	B	259	Rm 2510 Sink G	5/6/2021	7:52p	AR	5/7/2021	AR	7:52am	2.9			

## Lead Samples 2021 SCCS Buildings and Grounds

Bldg	Letter	Sample Id #	Sample Loc/Rm	Flushed	Flush Time	Staff	Date Sampled	Sampler	Time Sampled	Results	>15PPB	Note	Retest Date
GYM	C	300	Concession foun Bottle Fill #11	4/20/2021	9:18pm	AR	4/21/2021	AR	6:40am	<1.0			
GYM	C	301	Concession foun Bottle Fill #12	4/20/2021	9:19pm	AR	4/21/2021	AR	6:41am	<1.0			
GYM	C	302	Concession foun Bottle Fill #13	4/20/2021	9:20pm	AR	4/21/2021	AR	6:42am	<1.0			
GYM	C	303	NW Ball-field Hose Bib	4/20/2021		AR	4/21/2021	AR	6:44am	5.7			
GYM	C	318	Boys Team locker rm sink A	5/6/2021	8:20pm	AR	5/7/2021	AR	5:50am	5.8			
GYM	C	319	Boys Team locker rm sink B	5/6/2021	8:20pm	AR	5/7/2021	AR	5:49am	1.6			
GYM	C	320	Boys phys ed locker rm sink A	5/6/2021	8:23pm	AR	5/7/2021	AR	5:47am	4.6			
GYM	C	321	Boys phys ed locker rm sink B	5/6/2021	8:24pm	AR	5/7/2021	AR	5:48am	2.7			
GYM	C	322	Girls Team locker rm sink A	5/6/2021	8:25pm	AR	5/7/2021	AR	5:51am	1.8			
GYM	C	323	Girls Team locker rm sink B	5/6/2021	8:25pm	AR	5/7/2021	AR	5:52am	5.2			
GYM	C	324	Girls phys ed locker rm sink A	5/6/2021	8:30pm	AR	5/7/2021	AR	5:53am	2			
GYM	C	325	Girls phys ed locker rm sink B	5/6/2021	8:30pm	AR	5/7/2021	AR	5:54am	5.9			
GYM	C	304	Wrestling rm foun bottle Fill #14	4/20/2021	9:24pm	AR	4/21/2021	AR	6:58am	<1.0			
GYM	C	326	Boys Rm A	5/6/2021	8:35pm	AR	5/7/2021	AR	5:59am	4.8			
GYM	C	327	Boys Rm B	5/6/2021	8:35pm	AR	5/7/2021	AR	5:59am	2.5			
GYM	C	328	Boys Rm C	5/6/2021	8:35pm	AR	5/7/2021	AR	6:00am	3.7			
GYM	C	329	Boys Rm D	5/6/2021	8:35pm	AR	5/7/2021	AR	6:00am	3.7			



## Lead Samples 2021 SCCS Buildings and Grounds

Bldg	Letter	Sample	Sample Loc/Rm	Flushed	Time	Staff	Sampled	Sampler	Sampled	<15PPB	>15PPB	Note	Date
GYM	C	330	Boys Rm E	5/6/2021		AR	5/7/2021	AR	6:00am	1.7			
GYM	C	331	Girls Rm A	5/6/2021		AR	5/7/2021	AR	5:55am	1.5			
GYM	C	332	Girls Rm B	5/6/2021		AR	5/7/2021	AR	5:55am	2.3			
GYM	C	333	Girls Rm C	5/6/2021		AR	5/7/2021	AR	5:56am	3.4			
GYM	C	334	Girls Rm D	5/6/2021		AR	5/7/2021	AR	5:56am	2.1			
GYM	C	335	Girls Rm E	5/6/2021		AR	5/7/2021	AR	5:57am	2			
GYM	C	305	Elevator Bottle Fill #15	4/20/2021	9:28pm	AR	4/21/2021	AR	6:48am	<1.0			
GYM	C	306	Weight Room Bottle Fill # 16	4/20/2021	9:30pm	AR	4/21/2021	AR	6:50am	<1.0			
GYM	C	307	Bottle Fill #17	4/20/2021	9:32pm	AR	4/21/2021	AR	6:49am	<1.0			
GYM	C	308	Rm 3047 A	4/20/2021	9:28pm	AR	4/21/2021	AR	6:54am	1.1			
GYM	C	309	Rm 3047 B	4/20/2021	9:29pm	AR	4/21/2021	AR	6:55am	<1.0			
GYM	C	310	Rm 3052 Sink	4/20/2021	9:33pm	AR	4/21/2021	AR	6:56am	2.7			
GYM	C	311	Rm 3056 Sink	4/20/2021	9:35pm	AR	4/21/2021	AR	6:57am	<1.0			
GYM	C	312	Rm 3007 Sink	4/20/2021	9:37pm	AR	4/21/2021	AR	6:46am	<1.0			
GYM	C	313	Rm 3023 Ice	4/20/2021		AR	4/21/2021	AR	7:03am	<1.0			
GYM	C	314	Rm 3023 Sink A	4/20/2021	9:21pm	AR	4/21/2021	AR	7:01am	2.7			
GYM	C	315	Rm 3023 Sink B	4/20/2021	9:22pm	AR	4/21/2021	AR	7:02am	<1.0			
GYM	C	316	Concession Stand	4/20/2021	9:22pm	AR	4/21/2021	AR	6:45am	2.6			
GYM	C	317	3027 Office	4/20/2021	9:27pm	AR	4/21/2021	AR	7:00am	<1.0			
GYM	C	336	Away Team Room A	5/6/2021		AR	5/7/2021	AR	5:45am	1.4			
GYM	C	337	Away Team Room B	5/6/2021		AR	5/7/2021	AR	5:46am	6.6			



April 27, 2021

Andy Ridgeway  
Sandy Creek Central School District  
124 Salisbury  
Sandy Creek, NY 13145

RE: Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

Dear Andy Ridgeway:

Enclosed are the analytical results for sample(s) received by the laboratory on April 22, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:  
• Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Nicolette M. Lovari  
nicolette.lovari@pacelabs.com  
(631)694-3040  
Project Manager

Enclosures

cc: Lori Krebs, Sandy Creek Central School District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## CERTIFICATIONS

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

---

### **Pace Analytical Services Long Island**

Virginia Certification # 460302  
Delaware Certification # NY10478  
Delaware Certification # NY10478  
575 Broad Hollow Rd, Melville, NY 11747  
New York Certification #: 10478 Primary Accrediting Body  
New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350  
Connecticut Certification #: PH-0435  
Maryland Certification #: 208  
Rhode Island Certification #: LAO00340  
Massachusetts Certification #: M-NY026  
New Hampshire Certification #: 2987

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

Sample: 001		Lab ID: 70170347001		Collected: 04/21/21 07:21		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.9	ug/L	1.0	1		04/26/21 16:02	7439-92-1		

Sample: 002		Lab ID: 70170347002		Collected: 04/21/21 07:22		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	7.0	ug/L	1.0	1		04/26/21 16:06	7439-92-1		

Sample: 003		Lab ID: 70170347003		Collected: 04/21/21 07:23		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.7	ug/L	1.0	1		04/26/21 16:07	7439-92-1		

Sample: 004		Lab ID: 70170347004		Collected: 04/21/21 07:24		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.1	ug/L	1.0	1		04/26/21 16:09	7439-92-1		

Sample: 005	Lab ID: 70170347005	Collected: 04/21/21 07:25	Received: 04/22/21 09:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.2	ug/L	1.0	1		04/26/21 16:10	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 3 of 61



## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

Sample: 006		Lab ID: 70170347006		Collected: 04/21/21 07:23		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.1	ug/L	1.0	1		04/26/21 16:13	7439-92-1		
Sample: 007		Lab ID: 70170347007		Collected: 04/21/21 07:24		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 16:14	7439-92-1		
Sample: 008		Lab ID: 70170347008		Collected: 04/21/21 07:26		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		04/26/21 16:15	7439-92-1		
Sample: 009		Lab ID: 70170347009		Collected: 04/21/21 07:26		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.3	ug/L	1.0	1		04/26/21 16:16	7439-92-1		
Sample: 010		Lab ID: 70170347010		Collected: 04/21/21 07:27		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.1	ug/L	1.0	1		04/26/21 16:18	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 4 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

<b>Sample: 011</b>		<b>Lab ID: 70170347011</b>		Collected: 04/21/21 07:27		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		04/26/21 16:19	7439-92-1		
<b>Sample: 012</b>		<b>Lab ID: 70170347012</b>		Collected: 04/21/21 07:29		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	33.3	ug/L	1.0	1		04/26/21 16:22	7439-92-1		
<b>Sample: 013</b>		<b>Lab ID: 70170347013</b>		Collected: 04/21/21 07:29		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 16:23	7439-92-1		
<b>Sample: 014</b>		<b>Lab ID: 70170347014</b>		Collected: 04/21/21 07:30		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.0	ug/L	1.0	1		04/26/21 16:26	7439-92-1		
<b>Sample: 015</b>		<b>Lab ID: 70170347015</b>		Collected: 04/21/21 07:28		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 16:27	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 016</b>		<b>Lab ID: 70170347016</b>	Collected: 04/21/21 07:28	Received: 04/22/21 09:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		04/26/21 16:29	7439-92-1	
<b>Sample: 017</b>		<b>Lab ID: 70170347017</b>	Collected: 04/21/21 07:31	Received: 04/22/21 09:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.6	ug/L	1.0	1		04/26/21 16:30	7439-92-1	
<b>Sample: 018</b>		<b>Lab ID: 70170347018</b>	Collected: 04/21/21 07:32	Received: 04/22/21 09:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.2	ug/L	1.0	1		04/26/21 16:31	7439-92-1	
<b>Sample: 019</b>		<b>Lab ID: 70170347019</b>	Collected: 04/21/21 07:32	Received: 04/22/21 09:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.7	ug/L	1.0	1		04/26/21 16:32	7439-92-1	
<b>Sample: 020</b>		<b>Lab ID: 70170347020</b>	Collected: 04/21/21 07:33	Received: 04/22/21 09:40	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.2	ug/L	1.0	1		04/26/21 16:33	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 6 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 021</b>		<b>Lab ID: 70170347021</b>		Collected: 04/21/21 07:33		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	13.1	ug/L	1.0	1		04/26/21 16:36	7439-92-1		
<b>Sample: 022</b>		<b>Lab ID: 70170347022</b>		Collected: 04/21/21 07:34		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	17.4	ug/L	1.0	1		04/26/21 16:42	7439-92-1		
<b>Sample: 023</b>		<b>Lab ID: 70170347023</b>		Collected: 04/21/21 07:35		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	15.7	ug/L	1.0	1		04/26/21 16:43	7439-92-1		
<b>Sample: 024</b>		<b>Lab ID: 70170347024</b>		Collected: 04/21/21 07:35		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	18.7	ug/L	1.0	1		04/26/21 16:44	7439-92-1		
<b>Sample: 025</b>		<b>Lab ID: 70170347025</b>		Collected: 04/21/21 07:36		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	15.9	ug/L	1.0	1		04/26/21 16:45	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 7 of 61



## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 026</b>	<b>Lab ID: 70170347026</b>	Collected: 04/21/21 07:36		Received: 04/22/21 09:40		Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.5	ug/L	1.0	1		04/26/21 16:46	7439-92-1	

<b>Sample: 027</b>	<b>Lab ID: 70170347027</b>	Collected: 04/21/21 07:41		Received: 04/22/21 09:40		Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 16:47	7439-92-1	

<b>Sample: 028</b>	<b>Lab ID: 70170347028</b>	Collected: 04/21/21 07:41		Received: 04/22/21 09:40		Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 16:48	7439-92-1	

<b>Sample: 029</b>	<b>Lab ID: 70170347029</b>	Collected: 04/21/21 07:40		Received: 04/22/21 09:40		Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		04/26/21 16:50	7439-92-1	

<b>Sample: 030</b>	<b>Lab ID: 70170347030</b>	Collected: 04/21/21 07:40		Received: 04/22/21 09:40		Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 16:53	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 8 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 031</b>		<b>Lab ID: 70170347031</b>		Collected: 04/21/21 07:42		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 16:54	7439-92-1		
<b>Sample: 032</b>		<b>Lab ID: 70170347032</b>		Collected: 04/21/21 07:17		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 16:57	7439-92-1		
<b>Sample: 033</b>		<b>Lab ID: 70170347033</b>		Collected: 04/21/21 07:43		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.5	ug/L	1.0	1		04/26/21 16:58	7439-92-1		
<b>Sample: 034</b>		<b>Lab ID: 70170347034</b>		Collected: 04/21/21 07:43		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.6	ug/L	1.0	1		04/26/21 16:59	7439-92-1		
<b>Sample: 035</b>		<b>Lab ID: 70170347035</b>		Collected: 04/21/21 07:43		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.3	ug/L	1.0	1		04/26/21 17:00	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 9 of 61



## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

Sample: 036	Lab ID: 70170347036	Collected: 04/21/21 07:16	Received: 04/22/21 09:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		04/26/21 17:01	7439-92-1	

Sample: 037	Lab ID: 70170347037	Collected: 04/21/21 07:16	Received: 04/22/21 09:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.9	ug/L	1.0	1		04/26/21 17:03	7439-92-1	

Sample: 038		Lab ID: 70170347038		Collected: 04/21/21 07:16		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.2	ug/L	1.0	1		04/26/21 17:06	7439-92-1		

Sample: 039		Lab ID: 70170347039		Collected: 04/21/21 07:15		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.3	ug/L	1.0	1		04/26/21 17:07	7439-92-1		

Sample: 040		Lab ID: 70170347040		Collected: 04/21/21 07:14		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 17:08	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 10 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 041</b>		<b>Lab ID: 70170347041</b>		Collected: 04/21/21 07:10		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.4	ug/L	1.0	1		04/26/21 17:11	7439-92-1		
<b>Sample: 042</b>		<b>Lab ID: 70170347042</b>		Collected: 04/21/21 07:10		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.9	ug/L	1.0	1		04/26/21 17:14	7439-92-1		
<b>Sample: 043</b>		<b>Lab ID: 70170347043</b>		Collected: 04/21/21 07:11		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 17:15	7439-92-1		
<b>Sample: 044</b>		<b>Lab ID: 70170347044</b>		Collected: 04/21/21 07:09		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		04/26/21 17:18	7439-92-1		
<b>Sample: 045</b>		<b>Lab ID: 70170347045</b>		Collected: 04/21/21 07:50		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 17:20	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 11 of 61



## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 046</b>		<b>Lab ID: 70170347046</b>		Collected: 04/21/21 07:08		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 17:21	7439-92-1		
<b>Sample: 047</b>		<b>Lab ID: 70170347047</b>		Collected: 04/21/21 07:06		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 17:22	7439-92-1		
<b>Sample: 048</b>		<b>Lab ID: 70170347048</b>		Collected: 04/21/21 07:08		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 17:23	7439-92-1		
<b>Sample: 049</b>		<b>Lab ID: 70170347049</b>		Collected: 04/21/21 07:38		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	21.8	ug/L	1.0	1		04/26/21 17:24	7439-92-1		
<b>Sample: 050</b>		<b>Lab ID: 70170347050</b>		Collected: 04/21/21 07:18		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	49.7	ug/L	1.0	1		04/26/21 17:25	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 12 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 051</b>		<b>Lab ID: 70170347051</b>	Collected: 04/21/21 07:20		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		04/26/21 17:26	7439-92-1	
<b>Sample: 052</b>		<b>Lab ID: 70170347052</b>	Collected: 04/21/21 07:13		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.7	ug/L	1.0	1		04/26/21 17:32	7439-92-1	
<b>Sample: 053</b>		<b>Lab ID: 70170347053</b>	Collected: 04/21/21 07:46		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.8	ug/L	1.0	1		04/26/21 17:33	7439-92-1	
<b>Sample: 054</b>		<b>Lab ID: 70170347054</b>	Collected: 04/21/21 07:47		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	10.3	ug/L	1.0	1		04/26/21 17:34	7439-92-1	
<b>Sample: 055</b>		<b>Lab ID: 70170347055</b>	Collected: 04/21/21 07:10		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		04/26/21 17:35	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 13 of 61



## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

Sample: 056	Lab ID: 70170347056	Collected: 04/21/21 07:05	Received: 04/22/21 09:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 17:36	7439-92-1	

Sample: 057	Lab ID: 70170347057	Collected: 04/21/21 07:51	Received: 04/22/21 09:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.2	ug/L	1.0	1		04/26/21 17:37	7439-92-1	

Sample: 100		Lab ID: 70170347058		Collected: 04/21/21 05:10		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		04/26/21 17:38	7439-92-1		

Sample: 101	Lab ID: 70170347059	Collected: 04/21/21 05:12	Received: 04/22/21 09:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	10.8	ug/L	1.0	1		04/26/21 17:39	7439-92-1	

Sample: 102	Lab ID: 70170347060	Collected: 04/21/21 05:13	Received: 04/22/21 09:40	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		04/26/21 17:40	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 14 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 103</b>		<b>Lab ID: 70170347061</b>		Collected: 04/21/21 05:14		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.2	ug/L	1.0	1		04/26/21 17:45	7439-92-1	M1	

<b>Sample: 104</b>		<b>Lab ID: 70170347062</b>		Collected: 04/21/21 05:14		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.8	ug/L	1.0	1		04/26/21 17:49	7439-92-1		

<b>Sample: 105</b>		<b>Lab ID: 70170347063</b>		Collected: 04/21/21 05:16		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.1	ug/L	1.0	1		04/26/21 17:50	7439-92-1		

<b>Sample: 106</b>		<b>Lab ID: 70170347064</b>		Collected: 04/21/21 05:17		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.6	ug/L	1.0	1		04/26/21 17:51	7439-92-1		

<b>Sample: 107</b>		<b>Lab ID: 70170347065</b>		Collected: 04/21/21 05:18		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.3	ug/L	1.0	1		04/26/21 17:52	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 15 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 108</b>		<b>Lab ID: 70170347066</b>		Collected: 04/21/21 05:19		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.9	ug/L	1.0	1		04/26/21 17:53	7439-92-1		
<b>Sample: 109</b>		<b>Lab ID: 70170347067</b>		Collected: 04/21/21 05:20		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	9.3	ug/L	1.0	1		04/26/21 17:54	7439-92-1		
<b>Sample: 110</b>		<b>Lab ID: 70170347068</b>		Collected: 04/21/21 05:21		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		04/26/21 17:57	7439-92-1		
<b>Sample: 111</b>		<b>Lab ID: 70170347069</b>		Collected: 04/21/21 05:22		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.9	ug/L	1.0	1		04/26/21 17:58	7439-92-1		
<b>Sample: 112</b>		<b>Lab ID: 70170347070</b>		Collected: 04/21/21 05:23		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 17:59	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 16 of 61



## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 113</b>		<b>Lab ID: 70170347071</b>		Collected: 04/21/21 05:24		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.3	ug/L	1.0	1		04/26/21 18:00	7439-92-1		
<b>Sample: 114</b>		<b>Lab ID: 70170347072</b>		Collected: 04/21/21 05:25		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.6	ug/L	1.0	1		04/26/21 18:04	7439-92-1		
<b>Sample: 116</b>		<b>Lab ID: 70170347073</b>		Collected: 04/21/21 05:26		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.1	ug/L	1.0	1		04/26/21 18:05	7439-92-1		
<b>Sample: 117</b>		<b>Lab ID: 70170347074</b>		Collected: 04/21/21 05:26		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	39.8	ug/L	1.0	1		04/26/21 18:06	7439-92-1		
<b>Sample: 118</b>		<b>Lab ID: 70170347075</b>		Collected: 04/21/21 05:29		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		04/26/21 18:07	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 17 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 119</b>	<b>Lab ID: 70170347076</b>	Collected: 04/21/21 05:37		Received: 04/22/21 09:40		Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 18:10	7439-92-1	
<b>Sample: 120</b>	<b>Lab ID: 70170347077</b>	Collected: 04/21/21 05:39		Received: 04/22/21 09:40		Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.7	ug/L	1.0	1		04/26/21 18:11	7439-92-1	
<b>Sample: 121</b>	<b>Lab ID: 70170347078</b>	Collected: 04/21/21 05:42		Received: 04/22/21 09:40		Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 18:12	7439-92-1	
<b>Sample: 122</b>	<b>Lab ID: 70170347079</b>	Collected: 04/21/21 05:55		Received: 04/22/21 09:40		Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		04/26/21 18:13	7439-92-1	
<b>Sample: 123</b>	<b>Lab ID: 70170347080</b>	Collected: 04/21/21 05:55		Received: 04/22/21 09:40		Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.3	ug/L	1.0	1		04/26/21 18:14	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 18 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

Sample: 124		Lab ID: 70170347081		Collected: 04/21/21 05:56		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		04/26/21 18:17	7439-92-1		

Sample: 125		Lab ID: 70170347082		Collected: 04/21/21 05:57		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.9	ug/L	1.0	1		04/26/21 18:23	7439-92-1		

Sample: 126		Lab ID: 70170347083		Collected: 04/21/21 05:58		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.8	ug/L	1.0	1		04/26/21 18:24	7439-92-1		

Sample: 128		Lab ID: 70170347084		Collected: 04/21/21 07:55		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 18:25	7439-92-1		

Sample: 130		Lab ID: 70170347085		Collected: 04/21/21 08:26		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 18:26	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 19 of 61



## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 131</b>		<b>Lab ID: 70170347086</b>	Collected: 04/21/21 05:34		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		04/26/21 18:27	7439-92-1	

<b>Sample: 132</b>		<b>Lab ID: 70170347087</b>	Collected: 04/21/21 05:32		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		04/26/21 18:28	7439-92-1	

<b>Sample: 133</b>		<b>Lab ID: 70170347088</b>	Collected: 04/21/21 05:31		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		04/26/21 18:29	7439-92-1	

<b>Sample: 134</b>		<b>Lab ID: 70170347089</b>	Collected: 04/21/21 05:46		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	17.2	ug/L	1.0	1		04/26/21 18:30	7439-92-1	

<b>Sample: 135</b>		<b>Lab ID: 70170347090</b>	Collected: 04/21/21 05:46		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		04/26/21 18:31	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 136</b>		<b>Lab ID: 70170347091</b>		Collected: 04/21/21 05:47		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.3	ug/L	1.0	1		04/26/21 18:32	7439-92-1		

<b>Sample: 137</b>		<b>Lab ID: 70170347092</b>		Collected: 04/21/21 05:40		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		04/26/21 18:38	7439-92-1		

<b>Sample: 138</b>		<b>Lab ID: 70170347093</b>		Collected: 04/21/21 05:40		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 18:39	7439-92-1		

<b>Sample: 139</b>		<b>Lab ID: 70170347094</b>		Collected: 04/21/21 05:43		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.7	ug/L	1.0	1		04/26/21 18:40	7439-92-1		

<b>Sample: 140</b>		<b>Lab ID: 70170347095</b>		Collected: 04/21/21 05:45		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		04/26/21 18:41	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 21 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 141</b>		<b>Lab ID: 70170347096</b>		Collected: 04/21/21 05:45		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.5	ug/L	1.0	1		04/26/21 18:42	7439-92-1		
<b>Sample: 142</b>		<b>Lab ID: 70170347097</b>		Collected: 04/21/21 05:50		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 18:43	7439-92-1		
<b>Sample: 143</b>		<b>Lab ID: 70170347098</b>		Collected: 04/21/21 05:51		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 18:44	7439-92-1		
<b>Sample: 144</b>		<b>Lab ID: 70170347099</b>		Collected: 04/21/21 05:52		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 18:45	7439-92-1		
<b>Sample: 145</b>		<b>Lab ID: 70170347100</b>		Collected: 04/21/21 05:52		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 18:48	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 22 of 61



## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 146</b>		<b>Lab ID: 70170347101</b>	Collected: 04/21/21 05:53		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.8	ug/L	1.0	1		04/26/21 18:52	7439-92-1	
<b>Sample: 147</b>		<b>Lab ID: 70170347102</b>	Collected: 04/21/21 05:54		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		04/26/21 18:55	7439-92-1	
<b>Sample: 148</b>		<b>Lab ID: 70170347103</b>	Collected: 04/21/21 06:30		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		04/26/21 18:56	7439-92-1	
<b>Sample: 149</b>		<b>Lab ID: 70170347104</b>	Collected: 04/21/21 06:32		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		04/26/21 18:57	7439-92-1	
<b>Sample: 150</b>		<b>Lab ID: 70170347105</b>	Collected: 04/21/21 06:00		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.8	ug/L	1.0	1		04/26/21 18:58	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 23 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 151</b>		<b>Lab ID: 70170347106</b>	Collected: 04/21/21 06:00		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		04/26/21 19:01	7439-92-1	
<b>Sample: 152</b>		<b>Lab ID: 70170347107</b>	Collected: 04/21/21 06:04		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.9	ug/L	1.0	1		04/26/21 19:02	7439-92-1	
<b>Sample: 153</b>		<b>Lab ID: 70170347108</b>	Collected: 04/21/21 06:05		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.6	ug/L	1.0	1		04/26/21 19:03	7439-92-1	
<b>Sample: 154</b>		<b>Lab ID: 70170347109</b>	Collected: 04/21/21 06:01		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.2	ug/L	1.0	1		04/26/21 19:05	7439-92-1	
<b>Sample: 155</b>		<b>Lab ID: 70170347110</b>	Collected: 04/21/21 07:56		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		04/26/21 19:06	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 24 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 156</b>		<b>Lab ID: 70170347111</b>	Collected: 04/21/21 06:34		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.1	ug/L	1.0	1		04/26/21 19:07	7439-92-1	

<b>Sample: 157</b>		<b>Lab ID: 70170347112</b>	Collected: 04/21/21 06:35		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		04/26/21 19:10	7439-92-1	

<b>Sample: 200</b>		<b>Lab ID: 70170347113</b>	Collected: 04/21/21 06:26		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.3	ug/L	1.0	1		04/26/21 19:11	7439-92-1	

<b>Sample: 201</b>		<b>Lab ID: 70170347114</b>	Collected: 04/21/21 06:26		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		04/26/21 19:14	7439-92-1	

<b>Sample: 202</b>		<b>Lab ID: 70170347115</b>	Collected: 04/21/21 06:24		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		04/26/21 19:15	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 25 of 61



## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 203</b>		<b>Lab ID: 70170347116</b>	Collected: 04/21/21 06:25		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		04/26/21 19:16	7439-92-1	
<b>Sample: 204</b>		<b>Lab ID: 70170347117</b>	Collected: 04/21/21 06:23		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		04/26/21 19:17	7439-92-1	
<b>Sample: 205</b>		<b>Lab ID: 70170347118</b>	Collected: 04/21/21 06:22		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.5	ug/L	1.0	1		04/26/21 19:19	7439-92-1	
<b>Sample: 206</b>		<b>Lab ID: 70170347119</b>	Collected: 04/21/21 06:19		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.5	ug/L	1.0	1		04/26/21 19:20	7439-92-1	
<b>Sample: 207</b>		<b>Lab ID: 70170347120</b>	Collected: 04/21/21 06:20		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.7	ug/L	1.0	1		04/26/21 19:21	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 26 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

Sample: 208		Lab ID: 70170347121		Collected: 04/21/21 06:21		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.5	ug/L	1.0	1		04/26/21 19:24	7439-92-1		
Sample: 209		Lab ID: 70170347122		Collected: 04/21/21 06:16		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.8	ug/L	1.0	1		04/26/21 19:29	7439-92-1		
Sample: 210		Lab ID: 70170347123		Collected: 04/21/21 06:17		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		04/26/21 19:30	7439-92-1		
Sample: 211		Lab ID: 70170347124		Collected: 04/21/21 06:15		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		04/26/21 19:31	7439-92-1		
Sample: 212		Lab ID: 70170347125		Collected: 04/21/21 06:15		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.7	ug/L	1.0	1		04/26/21 19:32	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 27 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 218</b>		<b>Lab ID: 70170347131</b>		Collected: 04/21/21 06:30		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.5	ug/L	1.0	1		04/26/21 19:41	7439-92-1		

<b>Sample: 219</b>		<b>Lab ID: 70170347132</b>		Collected: 04/21/21 06:29		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	14.8	ug/L	1.0	1		04/26/21 19:44	7439-92-1		

<b>Sample: 220</b>		<b>Lab ID: 70170347133</b>		Collected: 04/21/21 06:27		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.9	ug/L	1.0	1		04/26/21 19:46	7439-92-1		

<b>Sample: 221</b>		<b>Lab ID: 70170347134</b>		Collected: 04/21/21 06:07		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.6	ug/L	1.0	1		04/26/21 19:47	7439-92-1		

<b>Sample: 222</b>		<b>Lab ID: 70170347135</b>		Collected: 04/21/21 06:07		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.2	ug/L	1.0	1		04/26/21 19:48	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

Sample: 300		Lab ID: 70170347136		Collected: 04/21/21 06:40		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 19:49	7439-92-1		
Sample: 301		Lab ID: 70170347137		Collected: 04/21/21 06:41		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 19:50	7439-92-1		
Sample: 302		Lab ID: 70170347138		Collected: 04/21/21 06:42		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 19:53	7439-92-1		
Sample: 303		Lab ID: 70170347139		Collected: 04/21/21 06:44		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.7	ug/L	1.0	1		04/26/21 19:54	7439-92-1		
Sample: 304		Lab ID: 70170347140		Collected: 04/21/21 06:58		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 19:55	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 30 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 213</b>		<b>Lab ID: 70170347126</b>		Collected: 04/21/21 06:14		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 19:34	7439-92-1		

<b>Sample: 214</b>		<b>Lab ID: 70170347127</b>		Collected: 04/21/21 06:13		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.4	ug/L	1.0	1		04/26/21 19:35	7439-92-1		

<b>Sample: 215</b>		<b>Lab ID: 70170347128</b>		Collected: 04/21/21 06:12		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.3	ug/L	1.0	1		04/26/21 19:36	7439-92-1		

<b>Sample: 216</b>		<b>Lab ID: 70170347129</b>		Collected: 04/21/21 06:08		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.2	ug/L	1.0	1		04/26/21 19:37	7439-92-1		

<b>Sample: 217</b>		<b>Lab ID: 70170347130</b>		Collected: 04/21/21 06:09		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.8	ug/L	1.0	1		04/26/21 19:40	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 28 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

Sample: 305		Lab ID: 70170347141		Collected: 04/21/21 06:48		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 19:58	7439-92-1		
Sample: 306		Lab ID: 70170347142		Collected: 04/21/21 06:50		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 20:02	7439-92-1		
Sample: 307		Lab ID: 70170347143		Collected: 04/21/21 06:49		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 20:03	7439-92-1		
Sample: 308		Lab ID: 70170347144		Collected: 04/21/21 06:54		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		04/26/21 20:06	7439-92-1		
Sample: 309		Lab ID: 70170347145		Collected: 04/21/21 06:55		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 20:07	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 31 of 61



## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

<b>Sample: 310</b>		<b>Lab ID: 70170347146</b>	Collected: 04/21/21 06:56		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.7	ug/L	1.0	1		04/26/21 20:08	7439-92-1	
<b>Sample: 311</b>		<b>Lab ID: 70170347147</b>	Collected: 04/21/21 06:57		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		04/26/21 20:09	7439-92-1	
<b>Sample: 312</b>		<b>Lab ID: 70170347148</b>	Collected: 04/21/21 06:46		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		04/26/21 20:10	7439-92-1	
<b>Sample: 313</b>		<b>Lab ID: 70170347149</b>	Collected: 04/21/21 07:03		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		04/26/21 20:11	7439-92-1	
<b>Sample: 314</b>		<b>Lab ID: 70170347150</b>	Collected: 04/21/21 07:01		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.7	ug/L	1.0	1		04/26/21 20:12	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 32 of 61

## ANALYTICAL RESULTS

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

Sample: 315		Lab ID: 70170347151		Collected: 04/21/21 07:02		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 20:13	7439-92-1		

Sample: 316		Lab ID: 70170347152		Collected: 04/21/21 06:45		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.6	ug/L	1.0	1		04/26/21 20:19	7439-92-1		

Sample: 317		Lab ID: 70170347153		Collected: 04/21/21 07:00		Received: 04/22/21 09:40		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		04/26/21 20:20	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALITY CONTROL DATA

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

QC Batch:	205540	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70170347001, 70170347002, 70170347003, 70170347004, 70170347005, 70170347006, 70170347007, 70170347008, 70170347009, 70170347010, 70170347011, 70170347012, 70170347013, 70170347014, 70170347015, 70170347016, 70170347017, 70170347018, 70170347019, 70170347020

METHOD BLANK: 1017053 Matrix: Water

Associated Lab Samples: 70170347001, 70170347002, 70170347003, 70170347004, 70170347005, 70170347006, 70170347007, 70170347008, 70170347009, 70170347010, 70170347011, 70170347012, 70170347013, 70170347014, 70170347015, 70170347016, 70170347017, 70170347018, 70170347019, 70170347020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	04/26/21 16:00	

LABORATORY CONTROL SAMPLE: 1017054

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.8	100	85-115	

MATRIX SPIKE SAMPLE: 1017057

Parameter	Units	70170347001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.9	50	62.1	121	70-130	

MATRIX SPIKE SAMPLE: 1017059

Parameter	Units	70170347011 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.8	50	60.6	118	70-130	

SAMPLE DUPLICATE: 1017056

Parameter	Units	70170347001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.9	1.8	2	

SAMPLE DUPLICATE: 1017058

Parameter	Units	70170347011 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.8	1.8	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

QC Batch:	205541	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70170347021, 70170347022, 70170347023, 70170347024, 70170347025, 70170347026, 70170347027, 70170347028, 70170347029, 70170347030, 70170347031, 70170347032, 70170347033, 70170347034, 70170347035, 70170347036, 70170347037, 70170347038, 70170347039, 70170347040		

METHOD BLANK:	1017063	Matrix:	Water
Associated Lab Samples:	70170347021, 70170347022, 70170347023, 70170347024, 70170347025, 70170347026, 70170347027, 70170347028, 70170347029, 70170347030, 70170347031, 70170347032, 70170347033, 70170347034, 70170347035, 70170347036, 70170347037, 70170347038, 70170347039, 70170347040		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	04/26/21 16:34	

LABORATORY CONTROL SAMPLE: 1017064

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.0	100	85-115	

MATRIX SPIKE SAMPLE: 1017066

Parameter	Units	70170347021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	13.1	50	74.0	122	70-130	

MATRIX SPIKE SAMPLE: 1017068

Parameter	Units	70170347031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	57.3	115	70-130	

SAMPLE DUPLICATE: 1017065

Parameter	Units	70170347021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	13.1	13.0	1	

SAMPLE DUPLICATE: 1017067

Parameter	Units	70170347031 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALITY CONTROL DATA

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

QC Batch: 205542 Analysis Method: EPA 200.8  
QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water  
Laboratory: Pace Analytical Services - Melville  
Associated Lab Samples: 70170347041, 70170347042, 70170347043, 70170347044, 70170347045, 70170347046, 70170347047, 70170347048, 70170347049, 70170347050, 70170347051, 70170347052, 70170347053, 70170347054, 70170347055, 70170347056, 70170347057, 70170347058, 70170347059, 70170347060

METHOD BLANK: 1017069 Matrix: Water  
Associated Lab Samples: 70170347041, 70170347042, 70170347043, 70170347044, 70170347045, 70170347046, 70170347047, 70170347048, 70170347049, 70170347050, 70170347051, 70170347052, 70170347053, 70170347054, 70170347055, 70170347056, 70170347057, 70170347058, 70170347059, 70170347060

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	04/26/21 17:09	

LABORATORY CONTROL SAMPLE: 1017070

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.0	100	85-115	

MATRIX SPIKE SAMPLE: 1017072

Parameter	Units	70170347041 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	6.4	50	68.6	124	70-130	

MATRIX SPIKE SAMPLE: 1017074

Parameter	Units	70170347051 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	58.3	115	70-130	

SAMPLE DUPLICATE: 1017071

Parameter	Units	70170347041 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	6.4	6.3	1	

SAMPLE DUPLICATE: 1017073

Parameter	Units	70170347051 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 36 of 61

## QUALITY CONTROL DATA

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

QC Batch:	205543	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70170347061, 70170347062, 70170347063, 70170347064, 70170347065, 70170347066, 70170347067, 70170347068, 70170347069, 70170347070, 70170347071, 70170347072, 70170347073, 70170347074, 70170347075, 70170347076, 70170347077, 70170347078, 70170347079, 70170347080		

METHOD BLANK:	1017075	Matrix:	Water
Associated Lab Samples:	70170347061, 70170347062, 70170347063, 70170347064, 70170347065, 70170347066, 70170347067, 70170347068, 70170347069, 70170347070, 70170347071, 70170347072, 70170347073, 70170347074, 70170347075, 70170347076, 70170347077, 70170347078, 70170347079, 70170347080		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	04/26/21 17:41	

LABORATORY CONTROL SAMPLE: 1017076						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.1	100	85-115	

MATRIX SPIKE SAMPLE:		1017078					
Parameter	Units	70170347061 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.2	50	68.6	131	70-130	M1

MATRIX SPIKE SAMPLE:		1017080					
Parameter	Units	70170347071 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.3	50	63.4	118	70-130	

SAMPLE DUPLICATE: 1017077					
Parameter	Units	70170347061 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.2	3.2	1	

SAMPLE DUPLICATE: 1017079					
		70170347071	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	4.3	4.3	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 37 of 61



## QUALITY CONTROL DATA

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

QC Batch:	205544	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70170347081, 70170347082, 70170347083, 70170347084, 70170347085, 70170347086, 70170347087, 70170347088, 70170347089, 70170347090, 70170347091, 70170347092, 70170347093, 70170347094, 70170347095, 70170347096, 70170347097, 70170347098, 70170347099, 70170347100		

METHOD BLANK:	1017081	Matrix:	Water
Associated Lab Samples:	70170347081, 70170347082, 70170347083, 70170347084, 70170347085, 70170347086, 70170347087, 70170347088, 70170347089, 70170347090, 70170347091, 70170347092, 70170347093, 70170347094, 70170347095, 70170347096, 70170347097, 70170347098, 70170347099, 70170347100		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	04/26/21 18:15	

LABORATORY CONTROL SAMPLE: 1017082						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.6	99	85-115	

MATRIX SPIKE SAMPLE:		1017084					
		70170347081	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	1.1	50	60.9	120	70-130	

MATRIX SPIKE SAMPLE:		1017086					
Parameter	Units	70170347091 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.3	50	63.7	125	70-130	

SAMPLE DUPLICATE: 1017083

Parameter	Units	70170347081 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.1	1.1	3	

SAMPLE DUPLICATE: 1017085					
Parameter	Units	70170347091 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.3	1.4	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALITY CONTROL DATA

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

QC Batch:	205545	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70170347101, 70170347102, 70170347103, 70170347104, 70170347105, 70170347106, 70170347107, 70170347108, 70170347109, 70170347110, 70170347111, 70170347112, 70170347113, 70170347114, 70170347115, 70170347116, 70170347117, 70170347118, 70170347119, 70170347120

METHOD BLANK:	1017087	Matrix:	Water
---------------	---------	---------	-------

Associated Lab Samples: 70170347101, 70170347102, 70170347103, 70170347104, 70170347105, 70170347106, 70170347107, 70170347108, 70170347109, 70170347110, 70170347111, 70170347112, 70170347113, 70170347114, 70170347115, 70170347116, 70170347117, 70170347118, 70170347119, 70170347120

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	04/26/21 18:49	

LABORATORY CONTROL SAMPLE: 1017088

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.7	99	85-115	

MATRIX SPIKE SAMPLE: 1017090

Parameter	Units	70170347101 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.8	50	47.1	89	70-130	

MATRIX SPIKE SAMPLE: 1017092

Parameter	Units	70170347111 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	7.1	50	65.5	117	70-130	

SAMPLE DUPLICATE: 1017089

Parameter	Units	70170347101 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.8	2.7	1	

SAMPLE DUPLICATE: 1017091

Parameter	Units	70170347111 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	7.1	7.1	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 39 of 61

## QUALITY CONTROL DATA

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

QC Batch:	205547	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70170347121, 70170347122, 70170347123, 70170347124, 70170347125, 70170347126, 70170347127, 70170347128, 70170347129, 70170347130, 70170347131, 70170347132, 70170347133, 70170347134, 70170347135, 70170347136, 70170347137, 70170347138, 70170347139, 70170347140		

METHOD BLANK:	1017093	Matrix:	Water
Associated Lab Samples:	70170347121, 70170347122, 70170347123, 70170347124, 70170347125, 70170347126, 70170347127, 70170347128, 70170347129, 70170347130, 70170347131, 70170347132, 70170347133, 70170347134, 70170347135, 70170347136, 70170347137, 70170347138, 70170347139, 70170347140		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	04/26/21 19:22	

LABORATORY CONTROL SAMPLE: 1017094						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.5	99	85-115	

MATRIX SPIKE SAMPLE:		1017096					
Parameter	Units	70170347121 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.5	50	61.5	116	70-130	

MATRIX SPIKE SAMPLE:		1017098					
		70170347131	Spike	MS	MS	% Rec	
Parameter	Units	Result	Conc.	Result	% Rec	Limits	Qualifiers
Lead	ug/L	2.5	50	60.4	116	70-130	

SAMPLE DUPLICATE: 1017095					
		70170347121	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	3.5	3.5	1	

SAMPLE DUPLICATE: 1017097					
		70170347131	Dup		
Parameter	Units	Result	Result	RPD	Qualifiers
Lead	ug/L	2.5	2.5	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 40 of 61



## QUALITY CONTROL DATA

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

QC Batch:	205549	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70170347141, 70170347142, 70170347143, 70170347144, 70170347145, 70170347146, 70170347147, 70170347148, 70170347149, 70170347150, 70170347151, 70170347152, 70170347153

METHOD BLANK: 1017099 Matrix: Water  
Associated Lab Samples: 70170347141, 70170347142, 70170347143, 70170347144, 70170347145, 70170347146, 70170347147, 70170347148, 70170347149, 70170347150, 70170347151, 70170347152, 70170347153

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	04/26/21 19:56	

LABORATORY CONTROL SAMPLE: 1017100

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.6	99	85-115	

MATRIX SPIKE SAMPLE: 1017102

Parameter	Units	70170347141 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	59.9	120	70-130	

MATRIX SPIKE SAMPLE: 1017104

Parameter	Units	70170347151 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	64.1	126	70-130	

SAMPLE DUPLICATE: 1017101

Parameter	Units	70170347141 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1017103

Parameter	Units	70170347151 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 41 of 61

## QUALIFIERS

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.  
ND - Not Detected at or above adjusted reporting limit.  
TNTC - Too Numerous To Count  
J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.  
MDL - Adjusted Method Detection Limit.  
PQL - Practical Quantitation Limit.  
RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.  
S - Surrogate  
1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.  
Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.  
LCS(D) - Laboratory Control Sample (Duplicate)  
MS(D) - Matrix Spike (Duplicate)  
DUP - Sample Duplicate  
RPD - Relative Percent Difference  
NC - Not Calculable.  
SG - Silica Gel - Clean-Up  
U - Indicates the compound was analyzed for, but not detected.  
N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.  
Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.  
TNI - The NELAC Institute.

### WORKORDER QUALIFIERS

WO: 70170347  
[1] Samples received but not on COC. ID's and times taken from bottles for 220, 221, 222

### ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70170347001	001	EPA 200.8	205540		
70170347002	002	EPA 200.8	205540		
70170347003	003	EPA 200.8	205540		
70170347004	004	EPA 200.8	205540		
70170347005	005	EPA 200.8	205540		
70170347006	006	EPA 200.8	205540		
70170347007	007	EPA 200.8	205540		
70170347008	008	EPA 200.8	205540		
70170347009	009	EPA 200.8	205540		
70170347010	010	EPA 200.8	205540		
70170347011	011	EPA 200.8	205540		
70170347012	012	EPA 200.8	205540		
70170347013	013	EPA 200.8	205540		
70170347014	014	EPA 200.8	205540		
70170347015	015	EPA 200.8	205540		
70170347016	016	EPA 200.8	205540		
70170347017	017	EPA 200.8	205540		
70170347018	018	EPA 200.8	205540		
70170347019	019	EPA 200.8	205540		
70170347020	020	EPA 200.8	205540		
70170347021	021	EPA 200.8	205541		
70170347022	022	EPA 200.8	205541		
70170347023	023	EPA 200.8	205541		
70170347024	024	EPA 200.8	205541		
70170347025	025	EPA 200.8	205541		
70170347026	026	EPA 200.8	205541		
70170347027	027	EPA 200.8	205541		
70170347028	028	EPA 200.8	205541		
70170347029	029	EPA 200.8	205541		
70170347030	030	EPA 200.8	205541		
70170347031	031	EPA 200.8	205541		
70170347032	032	EPA 200.8	205541		
70170347033	033	EPA 200.8	205541		
70170347034	034	EPA 200.8	205541		
70170347035	035	EPA 200.8	205541		
70170347036	036	EPA 200.8	205541		
70170347037	037	EPA 200.8	205541		
70170347038	038	EPA 200.8	205541		
70170347039	039	EPA 200.8	205541		
70170347040	040	EPA 200.8	205541		
70170347041	041	EPA 200.8	205542		
70170347042	042	EPA 200.8	205542		
70170347043	043	EPA 200.8	205542		
70170347044	044	EPA 200.8	205542		
70170347045	045	EPA 200.8	205542		
70170347046	046	EPA 200.8	205542		
70170347047	047	EPA 200.8	205542		
70170347048	048	EPA 200.8	205542		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70170347049	049	EPA 200.8	205542		
70170347050	050	EPA 200.8	205542		
70170347051	051	EPA 200.8	205542		
70170347052	052	EPA 200.8	205542		
70170347053	053	EPA 200.8	205542		
70170347054	054	EPA 200.8	205542		
70170347055	055	EPA 200.8	205542		
70170347056	056	EPA 200.8	205542		
70170347057	057	EPA 200.8	205542		
70170347058	100	EPA 200.8	205542		
70170347059	101	EPA 200.8	205542		
70170347060	102	EPA 200.8	205542		
70170347061	103	EPA 200.8	205543		
70170347062	104	EPA 200.8	205543		
70170347063	105	EPA 200.8	205543		
70170347064	106	EPA 200.8	205543		
70170347065	107	EPA 200.8	205543		
70170347066	108	EPA 200.8	205543		
70170347067	109	EPA 200.8	205543		
70170347068	110	EPA 200.8	205543		
70170347069	111	EPA 200.8	205543		
70170347070	112	EPA 200.8	205543		
70170347071	113	EPA 200.8	205543		
70170347072	114	EPA 200.8	205543		
70170347073	116	EPA 200.8	205543		
70170347074	117	EPA 200.8	205543		
70170347075	118	EPA 200.8	205543		
70170347076	119	EPA 200.8	205543		
70170347077	120	EPA 200.8	205543		
70170347078	121	EPA 200.8	205543		
70170347079	122	EPA 200.8	205543		
70170347080	123	EPA 200.8	205543		
70170347081	124	EPA 200.8	205544		
70170347082	125	EPA 200.8	205544		
70170347083	126	EPA 200.8	205544		
70170347084	128	EPA 200.8	205544		
70170347085	130	EPA 200.8	205544		
70170347086	131	EPA 200.8	205544		
70170347087	132	EPA 200.8	205544		
70170347088	133	EPA 200.8	205544		
70170347089	134	EPA 200.8	205544		
70170347090	135	EPA 200.8	205544		
70170347091	136	EPA 200.8	205544		
70170347092	137	EPA 200.8	205544		
70170347093	138	EPA 200.8	205544		
70170347094	139	EPA 200.8	205544		
70170347095	140	EPA 200.8	205544		
70170347096	141	EPA 200.8	205544		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: LEADS IN SCHOOL 4/21  
Pace Project No.: 70170347

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70170347097	142	EPA 200.8	205544		
70170347098	143	EPA 200.8	205544		
70170347099	144	EPA 200.8	205544		
70170347100	145	EPA 200.8	205544		
70170347101	146	EPA 200.8	205545		
70170347102	147	EPA 200.8	205545		
70170347103	148	EPA 200.8	205545		
70170347104	149	EPA 200.8	205545		
70170347105	150	EPA 200.8	205545		
70170347106	151	EPA 200.8	205545		
70170347107	152	EPA 200.8	205545		
70170347108	153	EPA 200.8	205545		
70170347109	154	EPA 200.8	205545		
70170347110	155	EPA 200.8	205545		
70170347111	156	EPA 200.8	205545		
70170347112	157	EPA 200.8	205545		
70170347113	200	EPA 200.8	205545		
70170347114	201	EPA 200.8	205545		
70170347115	202	EPA 200.8	205545		
70170347116	203	EPA 200.8	205545		
70170347117	204	EPA 200.8	205545		
70170347118	205	EPA 200.8	205545		
70170347119	206	EPA 200.8	205545		
70170347120	207	EPA 200.8	205545		
70170347121	208	EPA 200.8	205547		
70170347122	209	EPA 200.8	205547		
70170347123	210	EPA 200.8	205547		
70170347124	211	EPA 200.8	205547		
70170347125	212	EPA 200.8	205547		
70170347126	213	EPA 200.8	205547		
70170347127	214	EPA 200.8	205547		
70170347128	215	EPA 200.8	205547		
70170347129	216	EPA 200.8	205547		
70170347130	217	EPA 200.8	205547		
70170347131	218	EPA 200.8	205547		
70170347132	219	EPA 200.8	205547		
70170347133	220	EPA 200.8	205547		
70170347134	221	EPA 200.8	205547		
70170347135	222	EPA 200.8	205547		
70170347136	300	EPA 200.8	205547		
70170347137	301	EPA 200.8	205547		
70170347138	302	EPA 200.8	205547		
70170347139	303	EPA 200.8	205547		
70170347140	304	EPA 200.8	205547		
70170347141	305	EPA 200.8	205549		
70170347142	306	EPA 200.8	205549		
70170347143	307	EPA 200.8	205549		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: LEADS IN SCHOOL 4/21

Pace Project No.: 70170347

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70170347144	308	EPA 200.8	205549		
70170347145	309	EPA 200.8	205549		
70170347146	310	EPA 200.8	205549		
70170347147	311	EPA 200.8	205549		
70170347148	312	EPA 200.8	205549		
70170347149	313	EPA 200.8	205549		
70170347150	314	EPA 200.8	205549		
70170347151	315	EPA 200.8	205549		
70170347152	316	EPA 200.8	205549		
70170347153	317	EPA 200.8	205549		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 04/27/2021 03:57 PM

Page 46 of 61









## CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page : 1 Of 1

[illegible]





## CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page : 1 Of 1

Section A Required Client Information:						Section B Required Project Information:							Section C Invoice Information:											
Company: Sandy Creek Central School District						Report To: Andy Ridgeway							Attention:											
Address: 124 Salisbury						Copy To:							Company Name:											
Sandy Creek, NY 13145													Address:											
Email: andrew@scs.cnyric.org						Purchase Order #:							Pace Quote:											
Phone: (315) 387-3445 Fax:						Project Name: Lead In Schools							Pace Project Manager: nicolette.lovari@pacelabs.com,											
Requested Due Date:						Project #:							Pace Profile #: 5745											
<b>Regulatory Agency</b>																			<b>State / Location</b>					
																			<b>NY</b>					
ITEM #	SAMPLE ID <small>One Character per box. (A-Z, 0-9 / , - ) Sample IDs must be unique</small>	MATRIX	CODE	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G-GRAB O-COMP)	COLLECTED				TEMP AT COLLECTION	# OF CONTAINERS	Preservatives								Y/N	Analyses Test Y/N	Lead	Residual Chlorine [Y/N]	
		Drinking Water DW	W1		Water WW	P	Product SL	OIL OL	Wipe WP		Air AR	Other OT	Tissue TS	START DATE TIME	END DATE TIME	Unpreserved	H2SO4	HNO3	HCl					NaOH
1	049		G		G	4/21			7:38	1		I												
2	050		G		G	4/21			7:18	1		I												
3	051		G		G	4/21			7:20	1		I												
4	052		G		G	4/21			7:13	1		I												
5	053		G		G	4/21			7:46	1		I												
6	054		G		G	4/21			7:47	1		I												
7	055		G		G	4/21			7:10	1		I												
8	056		G		G	4/21			7:05	1		I												
9	057		G		G	4/21			7:51	1		I												
10																								
11																								
12																								
ADDITIONAL COMMENTS		RELINQUISHED BY / AFFILIATION				DATE	TIME	ACCEPTED BY / AFFILIATION				DATE	TIME	SAMPLE CONDITIONS										
		Andrew H. Ridgeway				4/21/2021	12:10	[Signature] Pace Lab				4/21/21	9:40											

Page 51 of 61



Page 52 of 61



















**Required Client Information:**

Company:	Sandy Creek Central School District	
Address:	124 Salisbury	
	Sandy Creek, NY 13145	
Email:	andgiew@sccs.cnyric.org	
Phone:	(315) 387-3445	Fax:
Requested Due Date:		

## Section B

**Required Project Information:**

Report To:	Andy Ridgeway
Copy To:	
Purchase Order #:	
Project Name:	Lead in Schools
Project #:	

## Section C

**Invoice Information:**

Attention:	
Company Name:	
Address:	
Pace Quoté:	
Pace Project Manager:	nicolette.iovari@pacelabs.com
Pace Profile #:	5745

Regulatory Agency

State / Location

NY

Page 58 of 61











## Sample Condition Upon Receipt

WUH-70170347

Client Name:

SCCSD

Project

PM: NHL

Due Date: 04/29/21

CLIENT: SCCSD

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other

Tracking #: 7735 1083 7329

Custody Seal on Cooler/Box Present: ☒ Yes ☐ No Seals intact: ☒ Yes ☐ NoPacking Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☒ None ☐ Other

Thermometer Used: TH091

Correction Factor: +0.0

Cooler Temperature(°C): 21.1 Cooler Temperature Corrected(°C): 21.1

Temp should be above freezing to 6.0°C

USDA Regulated Soil ( ☒ N/A, water sample)

Date and Initials of person examining contents: KW 4/22/21

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ Yes ☐ NoDid samples originate from a foreign source including Hawaii and Puerto Rico? ☐ Yes ☒ No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

		COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for)	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	11.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	12. Sample 220/221/222 not on COC logged off bottle.
-Includes date/time/ID, Matrix: SL (W) OIL		13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	Sample #
pH paper Lot # HCO41002		
All containers needing preservation are found to be in compliance with method recommendation?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
(HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)		
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).		
Per Method, VOA pH is checked after analysis		
Samples checked for dechlorination:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14.
KI starch test strips Lot #		
Residual chlorine strips Lot #		Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	15.
Lead Acetate Strips Lot #		
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):		

Client Notification/ Resolution:

Field Data Required?

Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:



May 24, 2021

Andy Ridgeway  
Sandy Creek Central School District  
124 Salisbury  
Sandy Creek, NY 13145

RE: Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Dear Andy Ridgeway:

Enclosed are the analytical results for sample(s) received by the laboratory on May 11, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:  
• Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

*Nicolette Lovari*

Nicolette M. Lovari  
nicolette.lovari@pacelabs.com  
(631)694-3040  
Project Manager

Enclosures

cc: Lori Krebs, Sandy Creek Central School District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC  
575 Broad Hollow Road  
Melville, NY 11747  
(631)694-3040

## CERTIFICATIONS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

---

### Pace Analytical Services Long Island

Virginia Certification # 460302  
Delaware Certification # NY10478  
Delaware Certification # NY10478  
575 Broad Hollow Rd, Melville, NY 11747  
New York Certification #: 10478 Primary Accrediting Body  
New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350  
Connecticut Certification #: PH-0435  
Maryland Certification #: 208  
Rhode Island Certification #: LAO00340  
Massachusetts Certification #: M-NY026  
New Hampshire Certification #: 2987

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Sample: 117-1	Lab ID: 70172562001	Collected: 05/07/21 05:43	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	37.4	ug/L	1.0	1		05/24/21 10:30	7439-92-1	
Sample: 318	Lab ID: 70172562002	Collected: 05/07/21 05:50	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.8	ug/L	1.0	1		05/24/21 10:31	7439-92-1	
Sample: 319	Lab ID: 70172562003	Collected: 05/07/21 05:49	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.6	ug/L	1.0	1		05/24/21 10:34	7439-92-1	
Sample: 320	Lab ID: 70172562004	Collected: 05/07/21 05:47	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.6	ug/L	1.0	1		05/24/21 10:35	7439-92-1	
Sample: 321	Lab ID: 70172562005	Collected: 05/07/21 05:48	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.7	ug/L	1.0	1		05/24/21 10:36	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 05/24/2021 04:59 PM

Page 3 of 31



## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Sample: 322	Lab ID: 70172562006	Collected: 05/07/21 05:51	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		05/24/21 10:39	7439-92-1	
Sample: 323	Lab ID: 70172562007	Collected: 05/07/21 05:52	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.2	ug/L	1.0	1		05/24/21 10:42	7439-92-1	
Sample: 324	Lab ID: 70172562008	Collected: 05/07/21 05:53	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		05/24/21 10:43	7439-92-1	
Sample: 325	Lab ID: 70172562009	Collected: 05/07/21 05:54	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.9	ug/L	1.0	1		05/24/21 10:45	7439-92-1	
Sample: 326	Lab ID: 70172562010	Collected: 05/07/21 05:59	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.8	ug/L	1.0	1		05/24/21 10:46	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Sample: 327	Lab ID: 70172562011	Collected: 05/07/21 05:59	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.5	ug/L	1.0	1		05/24/21 10:47	7439-92-1	

Sample: 328	Lab ID: 70172562012	Collected: 05/07/21 06:00	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.7	ug/L	1.0	1		05/24/21 10:48	7439-92-1	

Sample: 329	Lab ID: 70172562013	Collected: 05/07/21 06:00	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.7	ug/L	1.0	1		05/24/21 10:49	7439-92-1	

Sample: 330	Lab ID: 70172562014	Collected: 05/07/21 06:01	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.7	ug/L	1.0	1		05/24/21 10:50	7439-92-1	

Sample: 331	Lab ID: 70172562015	Collected: 05/07/21 05:55	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.5	ug/L	1.0	1		05/24/21 10:51	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Sample: 332	Lab ID: 70172562016	Collected: 05/07/21 05:55	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.3	ug/L	1.0	1		05/24/21 10:52	7439-92-1	

Sample: 333	Lab ID: 70172562017	Collected: 05/07/21 05:56	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.4	ug/L	1.0	1		05/24/21 10:57	7439-92-1	

Sample: 334		Lab ID: 70172562018		Collected: 05/07/21 05:56		Received: 05/11/21 11:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.1	ug/L	1.0	1		05/24/21 10:58	7439-92-1		

Sample: 335	Lab ID: 70172562019	Collected: 05/07/21 05:57	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.0	ug/L	1.0	1		05/24/21 10:59	7439-92-1	

Sample: 336	Lab ID: 70172562020	Collected: 05/07/21 05:45	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		05/24/21 11:00	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Sample: 337		Lab ID: 70172562021	Collected: 05/07/21 05:46	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.6	ug/L	1.0	1		05/24/21 11:01	7439-92-1		
Sample: 12-2		Lab ID: 70172562022	Collected: 05/07/21 06:06	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.9	ug/L	1.0	1		05/24/21 11:02	7439-92-1		
Sample: 022-1		Lab ID: 70172562023	Collected: 05/07/21 06:11	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	11.4	ug/L	1.0	1		05/24/21 11:03	7439-92-1		
Sample: 023-1		Lab ID: 70172562024	Collected: 05/07/21 06:11	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.9	ug/L	1.0	1		05/24/21 11:04	7439-92-1		
Sample: 024-1		Lab ID: 70172562025	Collected: 05/07/21 06:12	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.4	ug/L	1.0	1		05/24/21 11:05	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 05/24/2021 04:59 PM

Page 7 of 31

## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Sample: 025-1		Lab ID: 70172562026	Collected: 05/07/21 06:08	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		05/24/21 11:09	7439-92-1		
Sample: 049-1		Lab ID: 70172562027	Collected: 05/07/21 06:17	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.7	ug/L	1.0	1		05/24/21 11:12	7439-92-1		
Sample: 050-2		Lab ID: 70172562028	Collected: 05/07/21 06:16	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	17.2	ug/L	1.0	1		05/24/21 11:13	7439-92-1		
Sample: 134-1		Lab ID: 70172562029	Collected: 05/07/21 06:20	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.3	ug/L	1.0	1		05/24/21 11:14	7439-92-1		
Sample: 223		Lab ID: 70172562030	Collected: 05/07/21 06:25	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	35.2	ug/L	1.0	1		05/24/21 11:15	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 05/24/2021 04:59 PM

Page 8 of 31

## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7

Pace Project No.: 70172562

Sample: 224	Lab ID: 70172562031	Collected: 05/07/21 06:27	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	6.0	ug/L	1.0	1		05/24/21 11:16	7439-92-1	
Sample: 225	Lab ID: 70172562032	Collected: 05/07/21 06:28	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.5	ug/L	1.0	1		05/24/21 11:17	7439-92-1	
Sample: 226	Lab ID: 70172562033	Collected: 05/07/21 06:29	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.2	ug/L	1.0	1		05/24/21 11:20	7439-92-1	
Sample: 227	Lab ID: 70172562034	Collected: 05/07/21 06:31	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.6	ug/L	1.0	1		05/24/21 11:21	7439-92-1	
Sample: 228	Lab ID: 70172562035	Collected: 05/07/21 06:32	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.1	ug/L	1.0	1		05/24/21 11:22	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 05/24/2021 04:59 PM

Page 9 of 31



## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Sample: 229	Lab ID: 70172562036	Collected: 05/07/21 06:33	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.0	ug/L	1.0	1		05/24/21 11:23	7439-92-1	

Sample: 230	Lab ID: 70172562037	Collected: 05/07/21 06:35	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		05/24/21 11:26	7439-92-1	

Sample: 231	Lab ID: 70172562038	Collected: 05/07/21 06:36	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		05/24/21 11:27	7439-92-1	

Sample: 232	Lab ID: 70172562039	Collected: 05/07/21 06:38	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.8	ug/L	1.0	1		05/24/21 11:28	7439-92-1	

Sample: 233	Lab ID: 70172562040	Collected: 05/07/21 06:39	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.8	ug/L	1.0	1		05/24/21 11:29	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Sample: 234	Lab ID: 70172562041	Collected: 05/07/21 06:40	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.4	ug/L	1.0	1		05/24/21 11:31	7439-92-1	

Sample: 235	Lab ID: 70172562042	Collected: 05/07/21 06:46	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	32.8	ug/L	1.0	1		05/24/21 11:32	7439-92-1	

Sample: 236	Lab ID: 70172562043	Collected: 05/07/21 06:47	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.1	ug/L	1.0	1		05/24/21 11:33	7439-92-1	

Sample: 237	Lab ID: 70172562044	Collected: 05/07/21 06:48	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.4	ug/L	1.0	1		05/24/21 11:34	7439-92-1	

Sample: 238	Lab ID: 70172562045	Collected: 05/07/21 06:49	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.7	ug/L	1.0	1		05/24/21 11:35	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

<b>Sample: 239</b>		<b>Lab ID: 70172562046</b>	Collected: 05/07/21 06:50		Received: 05/11/21 11:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	8.5	ug/L	1.0	1		05/24/21 11:38	7439-92-1	
<b>Sample: 240</b>		<b>Lab ID: 70172562047</b>	Collected: 05/07/21 06:51		Received: 05/11/21 11:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.8	ug/L	1.0	1		05/24/21 11:43	7439-92-1	
<b>Sample: 241</b>		<b>Lab ID: 70172562048</b>	Collected: 05/07/21 06:52		Received: 05/11/21 11:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.0	ug/L	1.0	1		05/24/21 11:44	7439-92-1	
<b>Sample: 242</b>		<b>Lab ID: 70172562049</b>	Collected: 05/07/21 06:53		Received: 05/11/21 11:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.2	ug/L	1.0	1		05/24/21 11:45	7439-92-1	
<b>Sample: 243</b>		<b>Lab ID: 70172562050</b>	Collected: 05/07/21 06:55		Received: 05/11/21 11:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.3	ug/L	1.0	1		05/24/21 11:46	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Sample: 244	Lab ID: 70172562051	Collected: 05/07/21 06:56	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.6	ug/L	1.0	1		05/24/21 11:47	7439-92-1	

Sample: 245	Lab ID: 70172562052	Collected: 05/07/21 06:57	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.4	ug/L	1.0	1		05/24/21 11:48	7439-92-1	

Sample: 246	Lab ID: 70172562053	Collected: 05/07/21 06:58	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	68.7	ug/L	1.0	1		05/24/21 11:49	7439-92-1	

Sample: 247	Lab ID: 70172562054	Collected: 05/07/21 06:59	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.2	ug/L	1.0	1		05/24/21 11:50	7439-92-1	

Sample: 248	Lab ID: 70172562055	Collected: 05/07/21 07:00	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.1	ug/L	1.0	1		05/24/21 11:51	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Sample: 249		Lab ID: 70172562056		Collected: 05/07/21 07:00		Received: 05/11/21 11:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.3	ug/L	1.0	1		05/24/21 11:52	7439-92-1		
Sample: 250		Lab ID: 70172562057		Collected: 05/07/21 07:01		Received: 05/11/21 11:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.7	ug/L	1.0	1		05/24/21 11:57	7439-92-1		
Sample: 251		Lab ID: 70172562058		Collected: 05/07/21 07:02		Received: 05/11/21 11:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.0	ug/L	1.0	1		05/24/21 11:58	7439-92-1		
Sample: 252		Lab ID: 70172562059		Collected: 05/07/21 07:03		Received: 05/11/21 11:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	8.1	ug/L	1.0	1		05/24/21 11:59	7439-92-1		
Sample: 253		Lab ID: 70172562060		Collected: 05/07/21 07:03		Received: 05/11/21 11:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.2	ug/L	1.0	1		05/24/21 12:00	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Sample: 254	Lab ID: 70172562061	Collected: 05/07/21 07:04	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		05/24/21 12:01	7439-92-1	

Sample: 255	Lab ID: 70172562062	Collected: 05/07/21 07:04	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.2	ug/L	1.0	1		05/24/21 12:02	7439-92-1	

Sample: 256	Lab ID: 70172562063	Collected: 05/07/21 07:06	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.9	ug/L	1.0	1		05/24/21 12:03	7439-92-1	

Sample: 257	Lab ID: 70172562064	Collected: 05/07/21 07:07	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.9	ug/L	1.0	1		05/24/21 12:04	7439-92-1	

Sample: 258	Lab ID: 70172562065	Collected: 05/07/21 06:42	Received: 05/11/21 11:30	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.7	ug/L	1.0	1		05/24/21 12:06	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Sample: 259		Lab ID: 70172562066	Collected: 05/07/21 07:03	Received: 05/11/21 11:30	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.9	ug/L	1.0	1		05/24/21 12:09	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALITY CONTROL DATA

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

QC Batch:	210082	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70172562001, 70172562002, 70172562003, 70172562004, 70172562005

METHOD BLANK: 1049112 Matrix: Water  
Associated Lab Samples: 70172562001, 70172562002, 70172562003, 70172562004, 70172562005

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/24/21 10:06	

LABORATORY CONTROL SAMPLE: 1049113

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.5	101	85-115	

MATRIX SPIKE SAMPLE: 1049115

Parameter	Units	70172427017 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.1	50	57.4	113	70-130	

MATRIX SPIKE SAMPLE: 1049117

Parameter	Units	70172427027 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.1	50	58.1	110	70-130	

SAMPLE DUPLICATE: 1049114

Parameter	Units	70172427017 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.1	1.1	0	

SAMPLE DUPLICATE: 1049116

Parameter	Units	70172427027 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.1	3.1	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

## REPORT OF LABORATORY ANALYSIS

Date: 05/24/2021 04:59 PM

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Page 17 of 31

### QUALITY CONTROL DATA

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

QC Batch:	210083	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70172562006, 70172562007, 70172562008, 70172562009, 70172562010, 70172562011, 70172562012, 70172562013, 70172562014, 70172562015, 70172562016, 70172562017, 70172562018, 70172562019, 70172562020, 70172562021, 70172562022, 70172562023, 70172562024, 70172562025

METHOD BLANK: 1049118 Matrix: Water

Associated Lab Samples: 70172562006, 70172562007, 70172562008, 70172562009, 70172562010, 70172562011, 70172562012, 70172562013, 70172562014, 70172562015, 70172562016, 70172562017, 70172562018, 70172562019, 70172562020, 70172562021, 70172562022, 70172562023, 70172562024, 70172562025

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/24/21 10:37	

LABORATORY CONTROL SAMPLE: 1049119

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.1	102	85-115	

MATRIX SPIKE SAMPLE: 1049121

Parameter	Units	70172562006 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.8	50	64.7	126	70-130	

MATRIX SPIKE SAMPLE: 1049123

Parameter	Units	70172562016 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.3	50	64.3	124	70-130	

SAMPLE DUPLICATE: 1049120

Parameter	Units	70172562006 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.8	1.8	1	

SAMPLE DUPLICATE: 1049122

Parameter	Units	70172562016 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.3	2.4	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## QUALITY CONTROL DATA

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

QC Batch:	210084	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70172562026, 70172562027, 70172562028, 70172562029, 70172562030, 70172562031, 70172562032, 70172562033, 70172562034, 70172562035, 70172562036, 70172562037, 70172562038, 70172562039, 70172562040, 70172562041, 70172562042, 70172562043, 70172562044, 70172562045		

METHOD BLANK:	1049124	Matrix:	Water
Associated Lab Samples:	70172562026, 70172562027, 70172562028, 70172562029, 70172562030, 70172562031, 70172562032, 70172562033, 70172562034, 70172562035, 70172562036, 70172562037, 70172562038, 70172562039, 70172562040, 70172562041, 70172562042, 70172562043, 70172562044, 70172562045		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/24/21 11:06	

LABORATORY CONTROL SAMPLE: 1049125

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.1	104	85-115	

MATRIX SPIKE SAMPLE: 1049127

Parameter	Units	70172562026 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.1	50	63.6	125	70-130	

MATRIX SPIKE SAMPLE: 1049129

Parameter	Units	70172562036 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.0	50	60.0	114	70-130	

SAMPLE DUPLICATE: 1049126

Parameter	Units	70172562026 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.1	1.1	7	

SAMPLE DUPLICATE: 1049128

Parameter	Units	70172562036 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	3.0	2.9	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALITY CONTROL DATA

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

QC Batch:	210085	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70172562046, 70172562047, 70172562048, 70172562049, 70172562050, 70172562051, 70172562052, 70172562053, 70172562054, 70172562055, 70172562056, 70172562057, 70172562058, 70172562059, 70172562060, 70172562061, 70172562062, 70172562063, 70172562064, 70172562065		

METHOD BLANK:	1049130	Matrix:	Water
Associated Lab Samples:	70172562046, 70172562047, 70172562048, 70172562049, 70172562050, 70172562051, 70172562052, 70172562053, 70172562054, 70172562055, 70172562056, 70172562057, 70172562058, 70172562059, 70172562060, 70172562061, 70172562062, 70172562063, 70172562064, 70172562065		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/24/21 11:36	

LABORATORY CONTROL SAMPLE: 1049131

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.1	102	85-115	

MATRIX SPIKE SAMPLE: 1049133

Parameter	Units	70172562046 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	8.5	50	65.9	115	70-130	

MATRIX SPIKE SAMPLE: 1049135

Parameter	Units	70172562056 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.3	50	59.2	116	70-130	

SAMPLE DUPLICATE: 1049132

Parameter	Units	70172562046 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	8.5	8.4	2	

SAMPLE DUPLICATE: 1049134

Parameter	Units	70172562056 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.3	1.3	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALITY CONTROL DATA

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

QC Batch:	210086	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70172562066

METHOD BLANK: 1049136 Matrix: Water

Associated Lab Samples: 70172562066

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	05/24/21 12:07	

LABORATORY CONTROL SAMPLE: 1049137

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.6	101	85-115	

MATRIX SPIKE SAMPLE: 1049139

Parameter	Units	70172562066 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.9	50	63.9	122	70-130	

SAMPLE DUPLICATE: 1049138

Parameter	Units	70172562066 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.9	2.9	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## QUALIFIERS

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

## DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAP Institute.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70172562001	117-1	EPA 200.8	210082		
70172562002	318	EPA 200.8	210082		
70172562003	319	EPA 200.8	210082		
70172562004	320	EPA 200.8	210082		
70172562005	321	EPA 200.8	210082		
70172562006	322	EPA 200.8	210083		
70172562007	323	EPA 200.8	210083		
70172562008	324	EPA 200.8	210083		
70172562009	325	EPA 200.8	210083		
70172562010	326	EPA 200.8	210083		
70172562011	327	EPA 200.8	210083		
70172562012	328	EPA 200.8	210083		
70172562013	329	EPA 200.8	210083		
70172562014	330	EPA 200.8	210083		
70172562015	331	EPA 200.8	210083		
70172562016	332	EPA 200.8	210083		
70172562017	333	EPA 200.8	210083		
70172562018	334	EPA 200.8	210083		
70172562019	335	EPA 200.8	210083		
70172562020	336	EPA 200.8	210083		
70172562021	337	EPA 200.8	210083		
70172562022	12-2	EPA 200.8	210083		
70172562023	022-1	EPA 200.8	210083		
70172562024	023-1	EPA 200.8	210083		
70172562025	024-1	EPA 200.8	210083		
70172562026	025-1	EPA 200.8	210084		
70172562027	049-1	EPA 200.8	210084		
70172562028	050-2	EPA 200.8	210084		
70172562029	134-1	EPA 200.8	210084		
70172562030	223	EPA 200.8	210084		
70172562031	224	EPA 200.8	210084		
70172562032	225	EPA 200.8	210084		
70172562033	226	EPA 200.8	210084		
70172562034	227	EPA 200.8	210084		
70172562035	228	EPA 200.8	210084		
70172562036	229	EPA 200.8	210084		
70172562037	230	EPA 200.8	210084		
70172562038	231	EPA 200.8	210084		
70172562039	232	EPA 200.8	210084		
70172562040	233	EPA 200.8	210084		
70172562041	234	EPA 200.8	210084		
70172562042	235	EPA 200.8	210084		
70172562043	236	EPA 200.8	210084		
70172562044	237	EPA 200.8	210084		
70172562045	238	EPA 200.8	210084		
70172562046	239	EPA 200.8	210085		
70172562047	240	EPA 200.8	210085		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: LEAD IN SCHOOLS 5/7  
Pace Project No.: 70172562

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70172562048	241	EPA 200.8	210085		
70172562049	242	EPA 200.8	210085		
70172562050	243	EPA 200.8	210085		
70172562051	244	EPA 200.8	210085		
70172562052	245	EPA 200.8	210085		
70172562053	246	EPA 200.8	210085		
70172562054	247	EPA 200.8	210085		
70172562055	248	EPA 200.8	210085		
70172562056	249	EPA 200.8	210085		
70172562057	250	EPA 200.8	210085		
70172562058	251	EPA 200.8	210085		
70172562059	252	EPA 200.8	210085		
70172562060	253	EPA 200.8	210085		
70172562061	254	EPA 200.8	210085		
70172562062	255	EPA 200.8	210085		
70172562063	256	EPA 200.8	210085		
70172562064	257	EPA 200.8	210085		
70172562065	258	EPA 200.8	210085		
70172562066	259	EPA 200.8	210086		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





70172552

70172562

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

5

**Required Client Information:**

Company: Sandy Creek Central School District

Address	124 Salisbury
---------	---------------

Sandy Creek, NY 13145

Email: [bridgewillsees@myric.com](mailto:bridgewillsees@myric.com)

Phone (315) 387-3445

Requested Due Date:

**ject Information:**

Report To: Andy Ridgeway

Copy To	
---------	--

Purchase Order #
------------------

Project Name:	Lead in Schools
---------------	-----------------

Project M:

## Section C

**Invoice information:**

**Attention:**

Company Name
--------------

Address:
----------

Pace Quote:

**Pace Project Manager:**

Pace Profile #: 5745

Page : 1 Of 1

Page 25 of 31

## CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page : 1 Of 1

[illegible]







Page : 1 Of 1

Page 28 of 31

## CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

## Section A

## Section B

### Section C

**Required Client Information:**

**Required Project Information:**

**Invoice information:**

Page : 1 Of 1

Company: Sandy Creek Central School District		Report To: Andy Ridgeway		Attention:		Page: 1 Of 1	
Address: 124 Salisbury		Copy To:		Company Name:			
Sandy Creek, NY 13145				Address:			
Email: aridgwe@scsccs.nyrc.org		Purchase Order #		Pace Quote:		Regulatory Agency	
Phone: (315) 387-3445		Fax:		Pace Project Manager: nicollette.lovari@pacelabs.com		State / Location	
Requested Due Date		Project #		Pace Profile #: 5745		NY	

[illegible]



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b> Required Client Information:		<b>Section B</b> Required Project Information:		<b>Section C</b> Invoice Information:		Page: 1 Of 1	
Company: Sandy Creek Central School District		Report To: Andy Ridgeway		Attention:			
Address: 124 Salisbury		Copy To:		Company Name:			
Sandy Creek, NY 13145				Address:			
Email: aridgeway@scsds.ny.us		Purchase Order #:		Pace Quote:		Regulatory Agency:	
Phone: (315) 387-3445		Project Name: Lead in Schools		Pace Project Manager: nicoleto@paceanalytical.com		State / Location:	
Requested Due Date:		Project #:		Pace Profile #: 5745		NY	

ITEM #	SAMPLE ID One Character per box, (A-Z, 0-9, -, .) Sample IDs must be unique	MATRIX CODE (see valid codes to left)	COLLECTED START DATE TIME END DATE TIME	PRESERVATIVES UNPRESERVED H2SO4 HNO3 HCl NaOH Na2S2O3 Methanol Other	Y/N	Requested Analysis Filtered (Y/N)												Residual Chlorine (Y/N)
1	254	DW	5/7 7:04	1	1													
2	255		5/7 7:04	1	1													
3	256		5/7 7:06	1	1													
4	257		5/7 7:07	1	1													
5	258		5/7 6:42	1	1													
6	259		5/7 7:03	1	1													
7																		
8																		
9																		
10																		
11																		
12																		

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	Andrew H. Ridgeway	5/7/2021	11:42		5-7	11:42	
		5-12	10:12		5/11/21	10:20	
		5-11-21	11:30		5/11/21	11:30	

SAMPLER NAME AND SIGNATURE		TEMP in C	Received on Ice (Y/N)	Custody Sealed (Y/N)	Cooler (Y/N)	Samples stored (Y/N)
PRINT Name of SAMPLER: Andrew H. Ridgeway						
SIGNATURE of SAMPLER: Andrew H. Ridgeway						
		DATE Signed: 5/7/2021				





Sample Collection Worksheet

Client Name:

Sand Creek

Project

WO#: 70172562

PM: NML

Due Date: 05/18/21

CLIENT: SCCSD

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace ☐ Other

Tracking #:

Custody Seal on Cooler/Box Present: ☐ Yes ☒ No Seals intact: ☐ Yes ☒ NoPacking Material: ☐ Bubble Wrap ☐ Bubble Bags ☐ Ziploc ☒ None ☐ Other

Thermometer Used: TH091

Correction Factor: +0.0

Cooler Temperature(°C): 21.3

Cooler Temperature Corrected(°C): 21.3

Temp should be above freezing to 6.0°C

USDA Regulated Soil ☒ N/A, water sample

Date and Initials of person examining contents: KW 5/12/21

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC,

Did samples originate from a foreign source

NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ Yes ☒ Noincluding Hawaii and Puerto Rico)? ☐ Yes ☒ No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

				COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		6.
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		7.
Sufficient Volume: (Triple volume provided for)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	11. Note if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		12.
-Includes date/time/ID, Matrix: SL (W) OIL				
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # HCL48594				Sample #
All containers needing preservation are found to be in compliance with method recommendation?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
(HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)				
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water).				Initial when completed: Lot # of added preservative: Date/Time preservative added:
Per Method, VOA pH is checked after analysis				
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	14.
KI starch test strips Lot #				
Residual chlorine strips Lot #				Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	15.
Lead Acetate Strips Lot #				
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	16.
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Pace Trip Blank Lot # (if applicable):				

Client Notification/ Resolution:

Field Data Required?

Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

\* PM (Project Manager) review is documented electronically in LIMS

ENV-FRM-MELV-0024 OC

Page 31 of 31

November 01, 2021

Andy Ridgeway  
Sandy Creek Central School District  
124 Salisbury  
Sandy Creek, NY 13145

RE: Project: LEAD IN SCHOOLS 10/15  
Pace Project No.: 70191369

Dear Andy Ridgeway:

Enclosed are the analytical results for sample(s) received by the laboratory on October 16, 2021. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Jennifer Aracri for  
Savannah S. Benatar  
savannah.benatar@pacelabs.com  
(631)694-3040  
Project Manager

Enclosures

cc: Lori Krebs, Sandy Creek Central School District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## CERTIFICATIONS

Project: LEAD IN SCHOOLS 10/15  
Pace Project No.: 70191369

---

### **Pace Analytical Services Long Island**

575 Broad Hollow Rd, Melville, NY 11747  
Connecticut Certification #: PH-0435  
Delaware Certification # NY 10478  
Maryland Certification #: 208  
Massachusetts Certification #: M-NY026  
New Hampshire Certification #: 2987

New Jersey Certification #: NY158  
New York Certification #: 10478 Primary Accrediting Body  
Pennsylvania Certification #: 68-00350  
Rhode Island Certification #: LAO00340  
Virginia Certification # 460302

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 10/15

Pace Project No.: 70191369

<b>Sample: 400</b>		<b>Lab ID: 70191369001</b>	Collected: 10/15/21 06:31		Received: 10/16/21 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/01/21 11:41	7439-92-1	M1
<b>Sample: 401</b>		<b>Lab ID: 70191369002</b>	Collected: 10/15/21 06:39		Received: 10/16/21 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.7	ug/L	1.0	1		11/01/21 11:45	7439-92-1	M1
<b>Sample: 402</b>		<b>Lab ID: 70191369003</b>	Collected: 10/15/21 06:42		Received: 10/16/21 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		11/01/21 11:52	7439-92-1	
<b>Sample: 403</b>		<b>Lab ID: 70191369004</b>	Collected: 10/15/21 06:47		Received: 10/16/21 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1		11/01/21 11:53	7439-92-1	
<b>Sample: 404</b>		<b>Lab ID: 70191369005</b>	Collected: 10/15/21 06:52		Received: 10/16/21 10:30		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		11/01/21 11:54	7439-92-1	

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 11/01/2021 06:10 PM

Page 3 of 9

## ANALYTICAL RESULTS

Project: LEAD IN SCHOOLS 10/15

Pace Project No.: 70191369

Sample: 405		Lab ID: 70191369006		Collected: 10/15/21 06:55		Received: 10/16/21 10:30		Matrix: Drinking Water	
Parameters		Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		11/01/21 11:55	7439-92-1		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 11/01/2021 06:10 PM

Page 4 of 9

### QUALITY CONTROL DATA

Project: LEAD IN SCHOOLS 10/15  
Pace Project No.: 70191369

QC Batch:	231283	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70191369001, 70191369002, 70191369003, 70191369004, 70191369005, 70191369006

METHOD BLANK: 1166323 Matrix: Water  
Associated Lab Samples: 70191369001, 70191369002, 70191369003, 70191369004, 70191369005, 70191369006

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/01/21 11:37	

LABORATORY CONTROL SAMPLE: 1166324

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.1	100	85-115	

MATRIX SPIKE SAMPLE: 1166326

Parameter	Units	70191369001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	67.8	134	70-130	M1

MATRIX SPIKE SAMPLE: 1166329

Parameter	Units	70191369002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.7	50	71.4	133	70-130	M1

SAMPLE DUPLICATE: 1166325

Parameter	Units	70191369001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1166328

Parameter	Units	70191369002 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	4.7	4.8	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## QUALIFIERS

Project: LEAD IN SCHOOLS 10/15  
Pace Project No.: 70191369

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

### ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

## QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: LEAD IN SCHOOLS 10/15

Pace Project No.: 70191369

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70191369001	400	EPA 200.8	231283		
70191369002	401	EPA 200.8	231283		
70191369003	402	EPA 200.8	231283		
70191369004	403	EPA 200.8	231283		
70191369005	404	EPA 200.8	231283		
70191369006	405	EPA 200.8	231283		

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.

Date: 11/01/2021 06:10 PM

Page 7 of 9







## Sample Condition Upon Receipt

Client Name:

Sandy Creek

Proj

WO#: 70191369

PM: NHL

Due Date: 11/01/21

CLIENT: SCCSD

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other

Tracking #: 2849 0253 2560

Custody Seal on Cooler/Box Present: ☒ Yes ☐ No Seals intact: ☒ Yes ☐ No ☐ N/APacking Material: ☐ Bubble Wrap ☐ Bubble Bags ☒ Ziploc ☐ None ☐ OtherThermometer Used: ~~TH091~~ TH176 Correction Factor: +0.1

Cooler Temperature(°C): 2.2 Cooler Temperature Corrected(°C): 2.2

Temp should be above freezing to 6.0°C

USDA Regulated Soil ( ☐ N/A, water sample)

Date and Initials of person examining contents: MN 10/16/21

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC,

NM, NY, OK, OR, SC, TN, TX, or VA (check map)? ☐ Yes ☐ No

Did samples originate from a foreign source

including Hawaii and Puerto Rico)? ☐ Yes ☒ No

If Yes to either question, fill out a Regulated Soil Checklist (F-LI-C-010) and include with SCUR/COC paperwork.

				COMMENTS:		
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		1.		
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		2.		
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		3.		
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	4.		
Samples Arrived within Hold Time:	<input checked="" type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		5.		
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		6.		
Rush Turn Around Time Requested:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No		7.		
Sufficient Volume: (Triple volume provided for I)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		8.		
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		9.		
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No				
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		10.		
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	11.	Note if sediment is visible in the dissolved container.	
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No		12.		
-Includes date/time/ID, Matrix: SL WP OIL						
All containers needing preservation have been checked?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	13.	<input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl	
pH paper Lot # HC155968					Sample #	
All containers needing preservation are found to be in compliance with method recommendation?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A			
(HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)						
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRD/8015 (water).						
Per Method, VOA pH is checked after analysis						
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	14.		
KI starch test strips Lot #						
Residual chlorine strips Lot #					Positive for Res. Chlorine? Y N	
SM 4500 CN samples checked for sulfide?	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	15.		
Lead Acetate Strips Lot #					Positive for Sulfide? Y N	
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	16.		
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	17.		
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A			
Pace Trip Blank Lot # (if applicable):						

Client Notification/ Resolution:

Field Data Required?

Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

\* PM [Project Manager] review is documented electronically in LIMS.

ENV-FRM-MELV-0024 01

Page 9 of 9

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results
400	10/15/2021 06:31	11/1/2021 11:41	70191369001	Lead	<1.0
401	10/15/2021 06:39	11/1/2021 11:45	70191369002	Lead	4.7
402	10/15/2021 06:42	11/1/2021 11:52	70191369003	Lead	1.9
403	10/15/2021 06:47	11/1/2021 11:53	70191369004	Lead	1.3
404	10/15/2021 06:52	11/1/2021 11:54	70191369005	Lead	<1.0
405	10/15/2021 06:55	11/1/2021 11:55	70191369006	Lead	<1.0
<b>NYSDOH Action Level for Lead of 15 ppb</b>					

NYSDOH Action Level	Units
15	ug/L
15	ug/L
15	ug/L
15	ug/L
15	ug/L
15	ug/L