



# Sandy Creek Central School District

*"Comet Pride is Community-Wide!"*

May 20, 2024

Dear Parents/Guardians and Community Members:

Every three years the New York State Department of Education requires all school districts to test for lead in their drinking water. We completed our testing on April 17, 2024, and received the test results back on May 14, 2024. The New York State legislation requires all water sources to be under 5 parts per billion (ppb), which is a change this year from 15 ppb. We tested a total of 255 outlets and thirty-one (31) outlets came back above the 5 ppb threshold. It is important to note that none of the outlets currently over the 5 ppb threshold are drinking fountains that are used by students and staff. All elevated outlets have been pulled from service and have signage placed that state "Do Not Drink." The results are as follows:

Elementary School – We tested 82 outlets and currently have posted Do Not use for drinking/Non potable at (7) locations.

Middle School – We tested 66 outlets and (20) of them have been posted as Not for drinking/Non potable.

High School – We tested 59 outlets and (3) of them have been posted as Not for drinking/Non potable.

Gymnasium Complex – We tested 48 outlets and only (1) has been posted as Not for Drinking/Non potable.

Please feel free to refer to our website at [www.sandycreekcsd.org](http://www.sandycreekcsd.org), as we will post all results of the lead testing at Sandy Creek Central School District. Do not hesitate to contact me if you have any questions or concerns.

Sincerely,

Kevin Seymour  
Superintendent

KS/em

Kevin Seymour  
Superintendent of Schools

Cora Harvey  
Business Administrator

---

**Board of Education:**

John Shelmidine  
President

Joseph Hathway  
Vice-President

Kevin Halsey  
Andrea Harris  
John Macklen  
Heidi Metott  
Michele Warner

---

Timothy Filiatrault  
Principal  
Elementary School

Steven Newcombe  
Principal  
Middle/High School

Amy Howard-McCormack  
Director of Curriculum,  
Instruction & Data

James Hunt  
Assistant Principal  
Athletic Director

**Lead Samples 2024 SCCS Buildings and Grounds**

Bldg	Letter	Sample ID#	Sample Loc/Rm	Flushed	Flush Time	Staff	Date Sampled	Sampler	Time Sample	<5PPB	>5PPB	Note	Retest Date
Elem	A	001	Rm 1202 Sink	4/16/2024	5:35 PM	KS	4/17/2024	AR/JV	6:04 AM	0.0017			
Elem	A	002	Rm 1202 DF	4/16/2024	5:35 PM	KS	4/17/2024	AR/JV	6:05 AM	0.0011			
Elem	A	003	Rm 1203 Sink	4/16/2024	5:36 PM	KS	4/17/2024	AR/JV	6:06 AM	ND			
Elem	A	004	Rm 1203 DF	4/16/2024	5:37 PM	KS	4/17/2024	AR/JV	6:07 AM	ND			
Elem	A	005	Rm 1204 Sink	4/16/2024	5:38 PM	KS	4/17/2024	AR/JV	6:08 AM		0.0262		
Elem	A	006	Rm 1204 Bath Sink	4/16/2024	5:39 PM	KS	4/17/2024	AR/JV	6:09 AM	ND			
Elem	A	007	Rm 1205 Sink	4/16/2024	5:40 PM	KS	4/17/2024	AR/JV	6:10 AM	0.0012			
Elem	A	008	Rm 1205 DF	4/16/2024	5:42 PM	KS	4/17/2024	AR/JV	6:10 AM	ND			
Elem	A	009	Rm 1206 Sink	4/16/2024	5:43 PM	KS	4/17/2024	AR/JV	6:11 AM	ND			
Elem	A	010	Rm 1206 DF	4/16/2024	5:50 PM	KS	4/17/2024	AR/JV	6:11 AM	ND			
Elem	A	011	Rm 1207 Sink	4/16/2024	5:52 PM	KS	4/17/2024	AR/JV	6:12 AM	0.0014			
Elem	A	012	Rm 1207 DF	4/16/2024	5:53 PM	KS	4/17/2024	AR/JV	6:12 AM	ND			
Elem	A	013	Rm 1208 Sink	4/16/2024	5:56 PM	KS	4/17/2024	AR/JV	6:13 AM	0.0010			
Elem	A	014	Rm 1208 DF	4/16/2024	5:57 PM	KS	4/17/2024	AR/JV	6:14 AM	ND			
Elem	A	015	Rm 1302 Sink	4/16/2024	6:02 PM	KS	4/17/2024	AR/JV	6:15 AM	ND			
Elem	A	016	Rm 1302 DF	4/16/2024	6:03 PM	KS	4/17/2024	AR/JV	6:15 AM	ND			
Elem	A	017	Rm 1303 Sink	4/16/2024	6:04 PM	KS	4/17/2024	AR/JV	6:16 AM	ND			
Elem	A	018	Rm 1303 DF	4/16/2024	6:05 PM	KS	4/17/2024	AR/JV	6:16 AM	ND			
Elem	A	019	Rm 1304 Sink	4/16/2024	6:06 PM	KS	4/17/2024	AR/JV	6:17 AM	ND			
Elem	A	020	Rm 1304 DF	4/16/2024	6:07 PM	KS	4/17/2024	AR/JV	6:18 AM	ND			
Elem	A	021	Rm 1305 Sink	4/16/2024	6:09 PM	KS	4/17/2024	AR/JV	6:19 AM	ND			
Elem	A	022	Rm 1305 DF	4/16/2024	6:10 PM	KS	4/17/2024	AR/JV	6:19 AM	ND			
Elem	A	023	South West Hall Sink	4/16/2024	6:12 PM	KS	4/17/2024	AR/JV	6:20 AM	ND			
Elem	A	024	Rm 1014 Sink	4/16/2024	6:14 PM	KS	4/17/2024	AR/JV	6:21 AM	0.0018			
Elem	A	025	Rm 1014 DF	4/16/2024	6:20 PM	KS	4/17/2024	AR/JV	6:21 AM	ND			
Elem	A	026	Playground 1 #20	4/16/2024	6:20 PM	KS	4/17/2024	AR/JV	6:22 AM	ND			
Elem	A	027	Playground 2 #21	4/16/2024	6:22 PM	KS	4/17/2024	AR/JV	6:22 AM	ND			
Elem	A	028	Rm 1013 Sink	4/16/2024	6:25 PM	KS	4/17/2024	AR/JV	6:23 AM	0.0015			
Elem	A	029	Rm 1013 DF	4/16/2024	6:25 PM	KS	4/17/2024	AR/JV	6:23 AM	ND			
Elem	A	030	North West Hall Sink	4/16/2024	6:28 PM	KS	4/17/2024	AR/JV	6:24 AM	ND			
Elem	A	031	Rm 1310 Sink	4/16/2024	6:32 PM	KS	4/17/2024	AR/JV	6:25 AM	0.0019			
Elem	A	032	Rm 1310 DF	4/16/2024	6:35 PM	KS	4/17/2024	AR/JV	6:25 AM	ND			
Elem	A	033	Rm 1011 Sink	4/16/2024	6:37 PM	KS	4/17/2024	AR/JV	6:27 AM	0.0028			
Elem	A	034	Rm 1011 DF	4/16/2024	6:40 PM	KS	4/17/2024	AR/JV	6:27 AM	0.0013			
Elem	A	035	Rm 1012 Sink	4/16/2024	6:45 PM	KS	4/17/2024	AR/JV	6:26 AM	0.0046			

Elem	A	036	Rm 1012 DF	4/16/2024	6:47 PM	KS	4/17/2024	AR/JV	6:26 AM	0.0050			
Elem	A	037	Rm 1009 Sink	4/16/2024	6:48 PM	KS	4/17/2024	AR/JV	6:28 AM	0.0013			
Elem	A	038	Rm 1009 DF	4/16/2024	6:49 PM	KS	4/17/2024	AR/JV	6:28 AM	0.0028			
Elem	A	039	Rm 1010 Sink A	4/16/2024	6:50 PM	KS	4/17/2024	AR/JV	6:29 AM	0.0032			
Elem	A	040	Rm 1010 Sink B	4/16/2024	6:51 PM	KS	4/17/2024	AR/JV	6:29 AM	0.0027			
Elem	A	041	Rm 1010 Sink C	4/16/2024	6:52 PM	KS	4/17/2024	AR/JV	6:30 AM	0.0028			
Elem	A	042	Rm 1107 Sink A	4/16/2024	6:53 PM	KS	4/17/2024	AR/JV	6:31 AM		0.0085		
Elem	A	043	Rm 1107 Sink B	4/16/2024	6:55 PM	KS	4/17/2024	AR/JV	6:31 AM	0.0047			
Elem	A	044	Men's Rm Sink	4/16/2024	6:59 PM	KS	4/17/2024	AR/JV	6:32 AM		0.010		
Elem	A	045	Ladies Rm Sink	4/16/2024	7:01 PM	KS	4/17/2024	AR/JV	6:33 AM		0.0078		
Elem	A	046	Rm 1116 Sink	4/16/2024	7:03 PM	KS	4/17/2024	AR/JV	6:34 AM	0.0022			
Elem	A	047	Rm 1108 Sink	4/16/2024	7:05 PM	KS	4/17/2024	AR/JV	6:01 AM	0.0013			
Elem	A	048	Bottle Fill # 19	4/16/2024	7:07 PM	KS	4/17/2024	AR/JV	6:01 AM	0.0011			
Elem	A	049	Rm 1105 Sink	4/16/2024	7:10 PM	KS	4/17/2024	AR/JV	6:03 AM		0.0096		
Elem	A	050	3rd Gr. Boys Sink A	4/16/2024	7:12 PM	KS	4/17/2024	AR/JV	6:35 AM	ND			
Elem	A	051	3rd Gr. Boys Sink B	4/16/2024	7:13 PM	KS	4/17/2024	AR/JV	6:35 AM	ND			
Elem	A	052	3rd Gr. Girls Sink A	4/16/2024	7:14 PM	KS	4/17/2024	AR/JV	6:36 AM	ND			
Elem	A	053	3rd Gr. Girls Sink B	4/16/2024	7:15 PM	KS	4/17/2024	AR/JV	6:36 AM	0.001			
Elem	A	054	4th Gr. DF #1 A	4/16/2024	7:20 PM	KS	4/17/2024	AR/JV	6:37 AM	ND			
Elem	A	055	4th Gr. BF #1	4/16/2024	7:21 PM	KS	4/17/2024	AR/JV	6:37 AM	ND			
Elem	A	056	4th Gr. DF #1 B	4/16/2024	7:22 PM	KS	4/17/2024	AR/JV	6:38 AM	ND			
Elem	A	057	5th Gr. Boys Bathroom Sink A	4/16/2024	7:25 PM	KS	4/17/2024	AR/JV	6:39 AM	0.0024			
Elem	A	058	5th Gr. Boys Bathroom Sink B	4/16/2024	7:25 PM	KS	4/17/2024	AR/JV	6:39 AM	0.0050			
Elem	A	059	5th Gr. Boys Bathroom Sink C	4/16/2024	7:27 PM	KS	4/17/2024	AR/JV	6:39 AM	0.0031			
Elem	A	060	5th Gr. DF #2 A	4/16/2024	7:30 PM	KS	4/17/2024	AR/JV	6:40 AM	ND			
Elem	A	061	5th Gr. DF #2 B	4/16/2024	7:31 PM	KS	4/17/2024	AR/JV	6:40 AM	ND			
Elem	A	062	5th Gr. BF #2	4/16/2024	7:32 PM	KS	4/17/2024	AR/JV	6:41 AM	ND			
Elem	A	063	5th Gr. Girls Bathroom Sink A	4/16/2024	7:35 PM	KS	4/17/2024	AR/JV	6:42 AM	0.0011			
Elem	A	064	5th Gr. Girls Bathroom Sink B	4/16/2024	7:35 PM	KS	4/17/2024	AR/JV	6:42 AM	0.0018			
Elem	A	065	5th Gr. Girls Bathroom Sink C	4/16/2024	7:36 PM	KS	4/17/2024	AR/JV	6:43 AM	0.0017			
Elem	A	066	Teach Common's Gen. Neutral Sink	4/16/2024	7:40 PM	KS	4/17/2024	AR/JV	6:43 AM		0.0129		
Elem	A	067	Teach Common's Ladies Sink	4/16/2024	7:41 PM	KS	4/17/2024	AR/JV	6:44 AM	ND			
Elem	A	068	Rm 1425 Sink	4/16/2024	7:42 PM	KS	4/17/2024	AR/JV	6:44 AM	0.0024			
Elem	A	069	Rm 1428 Sink	4/16/2024	7:45 PM	KS	4/17/2024	AR/JV	6:45 AM	0.0037			
Elem	A	070	Rm 1429 Sink	4/16/2024	7:48 PM	KS	4/17/2024	AR/JV	6:46 AM		0.0355		
Elem	A	071	Rm 1440 Exam Rm North	4/16/2024	7:50 PM	KS	4/17/2024	AR/JV	6:47 AM	0.0028			
Elem	A	072	Rm 1440 Exam Rm South	4/16/2024	7:52 PM	KS	4/17/2024	AR/JV	6:47 AM	0.0039			
Elem	A	073	Rm 1440 Supply Rm Sink	4/16/2024	7:53 PM	KS	4/17/2024	AR/JV	6:48 AM	ND			

[illegible]



**Lead Samples 2024 SCCS Buildings and Grounds**

Bldg	Letter	Sample ID#	Sample Loc/Rm	Flushed	Flush Time	Staff	Date Sampled	Sampler	Time Sample	<5PPB	>5PPB	Note	Retest Date
HS/MS	B	100	DO Supt Sink	4/16/2024	8:05 PM	KS	4/17/2024	AR/JV	4:30 AM	ND			
HS/MS	B	101	DO Bathroom Sink	4/16/2024	8:10 PM	KS	4/17/2024	AR/JV	4:31 AM	0.0011			
HS/MS	B	102	DO Sink	4/16/2024	8:11 PM	KS	4/17/2024	AR/JV	4:32 AM	0.0029			
HS/MS	B	103	Kitch Portable Sink Cooler	4/16/2024	8:12 PM	KS	4/17/2024	AR/JV	4:15 AM	0.0017			
HS/MS	B	104	Kitch East Wall Spray	4/16/2024	8:13 PM	KS	4/17/2024	AR/JV	4:16 AM	0.0033			
HS/MS	B	105	Kitch Sink East Wall A	4/16/2024	8:14 PM	KS	4/17/2024	AR/JV	4:17 AM	0.0011			
HS/MS	B	106	Kitch Sink East Wall B	4/16/2024	8:15 PM	KS	4/17/2024	AR/JV	4:18 AM	ND			
HS/MS	B	107	Kitch Pedal Sink	4/16/2024	8:15 PM	KS	4/17/2024	AR/JV	4:18 AM	ND			
HS/MS	B	108	Kitch Dish Sprayer	4/16/2024	8:16 PM	KS	4/17/2024	AR/JV	4:19 AM	0.0017			
HS/MS	B	109	Kitch Kettle	4/16/2024	8:16 PM	KS	4/17/2024	AR/JV	4:20 AM	0.0035			
HS/MS	B	110	Kitch Sink on West Wall	4/16/2024	8:17 PM	KS	4/17/2024	AR/JV	4:21 AM	ND			
HS/MS	B	111	Kitch Pedal Sink South Wall	4/16/2024	8:17 PM	KS	4/17/2024	AR/JV	4:22 AM	0.0012			
HS/MS	B	112	Kitch Center Island West Sprayer	4/16/2024	8:18 PM	KS	4/17/2024	AR/JV	4:22 AM	0.0047			
HS/MS	B	113	Kitch Center Faucet	4/16/2024	8:18 PM	KS	4/17/2024	AR/JV	4:23 AM	ND			
HS/MS	B	114	Kitch Center Island East Sprayer	4/16/2024	8:20 PM	KS	4/17/2024	AR/JV	4:24 AM		0.0054		
HS/MS	B	115	Kitch Ice	4/16/2024	8:21 PM	KS	4/17/2024	AR/JV	4:25 AM	ND			
HS/MS	B	116	Kitch Tray Return Sprayer	4/16/2024	8:21 PM	KS	4/17/2024	AR/JV	4:26 AM	0.0047			
HS/MS	B	117	Kitch Tray Return Facuet	4/16/2024	8:22 PM	KS	4/17/2024	AR/JV	4:27 AM	0.0041			
HS/MS	B	118	Kitch Serving Island Sink EL	4/16/2024	8:23 PM	KS	4/17/2024	AR/JV	4:28 AM	0.0045			
HS/MS	B	119	Kitch SW Wall Replace Sink EL										
HS/MS	B	120	Kitch Serving Pedal Sink	4/16/2024	8:25 PM	KS	4/17/2024	AR/JV	4:29 AM	0.0011			
HS/MS	B	121	Girls Bath Sink A (by HS Off.)	4/16/2024	8:10 PM	KS	4/17/2024	AR/JV	4:34 AM	0.0011			
HS/MS	B	122	Girls Sink B	4/16/2024	8:12 PM	KS	4/17/2024	AR/JV	4:34 AM	0.0016			
HS/MS	B	123	Girls Sink C	4/16/2024	8:13 PM	KS	4/17/2024	AR/JV	4:35 AM	ND			
HS/MS	B	124	Drink Fount #3	4/16/2024	8:14 PM	KS	4/17/2024	AR/JV	4:36 AM	ND			
HS/MS	B	125	Drink Fount #3 Bottle Fill	4/16/2024	8:15 PM	KS	4/17/2024	AR/JV	4:36 AM	ND			
HS/MS	B	126	H.S. Office Sink Bathroom	4/16/2024	8:16 PM	KS	4/17/2024	AR/JV	4:37 AM	ND			
HS/MS	B	127	Rm 1908 Sink (Steve N. Office)	4/16/2024	8:17 PM	KS	4/17/2024	AR/JV	4:38 AM	0.0016			
HS/MS	B	128	Rm 1940 Sink	4/16/2024	8:20 PM	KS	4/17/2024	AR/JV	4:39 AM	0.0016			
HS/MS	B	129	DF #4	4/16/2024	8:22 PM	KS	4/17/2024	AR/JV	4:40 AM	ND			
HS/MS	B	130	DF #4 Bottle Fill	4/16/2024	8:23 PM	KS	4/17/2024	AR/JV	4:41 AM	ND			
HS/MS	B	131	Boy's Bathroom Sink A	4/16/2024	8:24 PM	KS	4/17/2024	AR/JV	4:42 AM	ND			
HS/MS	B	132	Boy's Bathroom Sink B	4/16/2024	8:26 PM	KS	4/17/2024	AR/JV	4:42 AM		0.0090		

[illegible]

**Lead Samples 2024 SCCS Buildings and Grounds**

Bldg	Letter	Sample ID#	Sample Loc/Rm	Flushed	Flush Time	Staff	Date Sampled	Sampler	Time Sample	<5PPB	>5PPB	Note	Retest Date
HS/MS	B	200	MS Girls Bath Sink A 6th	4/17/2024	7:20 PM	KS	4/18/2024	AR/JV	6:07 AM	ND			
HS/MS	B	201	MS Girls Bath Sink B 6th	4/17/2024	7:20 PM	KS	4/18/2024	AR/JV	6:08 AM	ND			
HS/MS	B	202	MS Boys Sink A 6th	4/17/2024	7:21 PM	KS	4/18/2024	AR/JV	6:09 AM	ND			
HS/MS	B	203	MS Boys Sink B 6th	4/17/2024	7:21 PM	KS	4/18/2024	AR/JV	6:10 AM	ND			
HS/MS	B	204	DF #10	4/16/2024	9:15 PM	KS	4/17/2024	AR/JV	7:26 AM	ND			
HS/MS	B	205	Bottle Fill #10	4/16/2024	9:16 PM	KS	4/17/2024	AR/JV	7:26 AM	ND			
HS/MS	B	206	Rm 2701 Sink A	4/17/2024	8:00 PM	KS	4/18/2024	AR/JV	6:11 AM		0.0094		
HS/MS	B	207	Rm 2701 Sink B	4/17/2024	8:00 PM	KS	4/18/2024	AR/JV	6:12 AM	0.0042			
HS/MS	B	208	Rm 2701 Sink C	4/17/2024	8:00 PM	KS	4/18/2024	AR/JV	6:12 AM	0.0043			
HS/MS	B	209	Rm 2701 Sink D	4/17/2024	8:01 PM	KS	4/18/2024	AR/JV	6:13 AM	0.0028			
HS/MS	B	210	Rm 2701 Sink E	4/17/2024	8:02 PM	KS	4/18/2024	AR/JV	6:13 AM	0.0048			
HS/MS	B	211	Rm 2701 Sink F	4/17/2024	8:02 PM	KS	4/18/2024	AR/JV	6:14 AM	0.0043			
HS/MS	B	212	Rm 2701 Sink G										
HS/MS	B	213	Rm 2701 Office Sink	4/17/2024	7:47 PM	KS	4/18/2024	AR/JV	6:15 AM	0.0015			
HS/MS	B	214	Rm 2705 Sink A	4/17/2024	7:47 PM	KS	4/18/2024	AR/JV	6:16 AM	0.0029			
HS/MS	B	215	Rm 2705 Sink B	4/17/2024	7:47 PM	KS	4/18/2024	AR/JV	6:16 AM		0.0051		
HS/MS	B	216	Rm 2705 Sink C	4/17/2024	7:47 PM	KS	4/18/2024	AR/JV	6:17 AM		0.0051		
HS/MS	B	217	Rm 2705 Sink D	4/17/2024	7:47 PM	KS	4/18/2024	AR/JV	6:17 AM	0.0049			
HS/MS	B	218	Rm 2705 Sink E	4/17/2024	7:48 PM	KS	4/18/2024	AR/JV	6:18 AM	0.0021			
HS/MS	B	219	Rm 2705 Sink F	4/17/2024	7:48 PM	KS	4/18/2024	AR/JV	6:18 AM	0.0044			
HS/MS	B	220	Rm 2705 Sink G	4/17/2024	7:48 PM	KS	4/18/2024	AR/JV	6:19 AM	0.0015			
HS/MS	B	221	Rm 2706 Sink A	4/17/2024	7:48 PM	KS	4/18/2024	AR/JV	6:20 AM		0.0289		
HS/MS	B	222	Rm 2706 Sink B	4/17/2024	7:49 PM	KS	4/18/2024	AR/JV	6:21 AM	0.0026			
HS/MS	B	223	Rm 2706 Sink C	4/17/2024	7:49 PM	KS	4/18/2024	AR/JV	6:21 AM	ND			
HS/MS	B	224	Rm 2720 Lav. Sink	4/17/2024	7:41 PM	KS	4/18/2024	AR/JV	6:25 AM	ND			
HS/MS	B	225	Rm 2716 Lav. Sink	4/17/2024	7:41 PM	KS	4/18/2024	AR/JV	6:24 AM	0.0020			
HS/MS	B	226	Girls Bath Sink by Rm 2725A	4/16/2024	9:20 PM	KS	4/17/2024	AR/JV	7:35 AM	0.0023			
HS/MS	B	227	Girls Bath Sink by Rm 2725B	4/16/2024	9:20 PM	KS	4/17/2024	AR/JV	7:35 AM	0.0024			
HS/MS	B	228	DF #9	4/16/2024	9:06 PM	KS	4/17/2024	AR/JV	7:27 AM	ND			
HS/MS	B	229	Bottle Fill #9	4/16/2024	9:07 PM	KS	4/17/2024	AR/JV	7:28 AM	0.0012			
HS/MS	B	230	DF #8	4/16/2024	9:08 PM	KS	4/17/2024	AR/JV	7:29 AM	ND			
HS/MS	B	231	Bottle Fill #8	4/16/2024	9:08 PM	KS	4/17/2024	AR/JV	7:29 AM	ND			
HS/MS	B	232	DF #7	4/16/2024	9:10 PM	KS	4/17/2024	AR/JV	7:30 AM	ND			

[illegible]



**Lead Samples 2024 SCCS Buildings and Grounds**

Bldg	Letter	Sample ID#	Sample Loc/Rm	Flushed	Flush Time	Staff	Date Sampled	Sampler	Time	<5PPB	>5PPB	Note	Retest
Gym	C	300	Boys Rm A	4/16/2024	7:30 PM	AR	4/17/2024	AR/JV	5:16 AM	0.0015			
Gym	C	301	Boys Rm B	4/16/2024	7:32 PM	AR	4/17/2024	AR/JV	5:16 AM	0.0014			
Gym	C	302	Boys Rm C	4/16/2024	7:35 PM	AR	4/17/2024	AR/JV	5:17 AM	0.0016			
Gym	C	303	Boys Rm D	4/16/2024	7:36 PM	AR	4/17/2024	AR/JV	5:18 AM	0.0013			
Gym	C	304	Boys Rm E	4/16/2024	7:37 PM	AR	4/17/2024	AR/JV	5:19 AM	ND			
Gym	C	305	Girls Rm A	4/16/2024	7:40 PM	AR	4/17/2024	AR/JV	5:20 AM	0.0012			
Gym	C	306	Girls Rm B	4/16/2024	7:41 PM	AR	4/17/2024	AR/JV	5:21 AM	ND			
Gym	C	307	Girls Rm C	4/16/2024	7:42 PM	AR	4/17/2024	AR/JV	5:21 AM	0.0014			
Gym	C	308	Girls Rm D	4/16/2024	7:45 PM	AR	4/17/2024	AR/JV	5:22 AM	ND			
Gym	C	309	Girls Rm E	4/16/2024	7:50 PM	AR	4/17/2024	AR/JV	5:23 AM	0.0011			
Gym	C	310	Concession DF #11 A	4/16/2024	7:51 PM	AR	4/17/2024	AR/JV	5:24 AM	ND			
Gym	C	311	Concession DF #11 B										
Gym	C	312	Concession DF #11 C (BF)	4/16/2024	7:53 PM	AR	4/17/2024	AR/JV	5:25 AM	ND			
Gym	C	313	Concession DF #12 A	4/16/2024	7:53 PM	AR	4/17/2024	AR/JV	5:26 AM	ND			
Gym	C	314	Concession DF #12 B	4/16/2024	7:54 PM	AR	4/17/2024	AR/JV	5:27 AM	ND			
Gym	C	315	Concession DF #12 C (BF)	4/16/2024	7:54 PM	AR	4/17/2024	AR/JV	5:28 AM	ND			
Gym	C	316	Concession DF #13 A	4/16/2024	7:55 PM	AR	4/17/2024	AR/JV	5:29 AM	ND			
Gym	C	317	Concession DF #13 B	4/16/2024	7:55 PM	AR	4/17/2024	AR/JV	5:29 AM	ND			
Gym	C	318	Concession DF #13 C (BF)	4/16/2024	7:56 PM	AR	4/17/2024	AR/JV	5:30 AM	ND			
Gym	C	319	NW Ball-Field Hose Bib	4/16/2024	7:25 PM	AR	4/17/2024	AR/JV	5:31 AM	0.0030			
Gym	C	320	Boys Team Locker Rm Sink A	4/16/2024	7:58 PM	AR	4/17/2024	AR/JV	5:32 AM	0.0050			
Gym	C	321	Boys Team Locker Rm Sink B	4/16/2024	7:58 PM	AR	4/17/2024	AR/JV	5:32 AM	0.0017			
Gym	C	322	Rm 3027 Office	4/16/2024	8:00 PM	AR	4/17/2024	AR/JV	5:33 AM	0.0025			
Gym	C	323	Boys Phys Ed Locker Rm Sink A	4/16/2024	8:01 PM	AR	4/17/2024	AR/JV	5:34 AM	ND			
Gym	C	324	Boys Phys Ed Locker Rm Sink B	4/16/2024	8:01 PM	AR	4/17/2024	AR/JV	5:35 AM	ND			
Gym	C	325	Wrestling Rm DF #14 A	4/16/2024	8:02 PM	AR	4/17/2024	AR/JV	5:36 AM	ND			
Gym	C	326	Wrestling Rm DF #14 B										
Gym	C	327	Wrestling Rm #14 C (BF)	4/16/2024	8:02 PM	AR	4/17/2024	AR/JV	5:36 AM	ND			
Gym	C	328	Away Team Room A	4/16/2024	8:30 PM	AR	4/17/2024	AR/JV	5:38 AM		0.0072		
Gym	C	329	Away Team Room B	4/16/2024	8:30 PM	AR	4/17/2024	AR/JV	5:38 AM	0.0028			
Gym	C	330	Rm 3023 (Training Rm.) Ice	4/16/2024	8:32 PM	AR	4/17/2024	AR/JV	5:40 AM	ND			
Gym	C	331	Rm 3023 (Training Rm.) Sink A	4/16/2024	8:34 PM	AR	4/17/2024	AR/JV	5:40 AM	0.0046			
Gym	C	332	Rm 3023 (Training Rm.) Sink B	4/16/2024	8:35 PM	AR	4/17/2024	AR/JV	5:40 AM	0.001			



[illegible]

# Water Testing Summary

## Sandy Creek Central School District

### May 15, 2024

District wide we tested a total of 255 outlets on April 17 & 18 , 2024. Of those tested (31) have come back above the new (5) ppb threshold. We will be doing some remediation to allow for retesting in a couple of weeks.

The Elementary school – we tested 82 outlets and currently have posted Do Not use for drinking / Non potable at (7) locations.

The Middle school – we tested 66 outlets and (20) of them have been posted as Not for drinking / Non potable.

The High school – we tested 59 outlets and (3) of them have been posted as Not for drinking / Non potable .

The Gymnasium Complex – we tested 48 outlets and only (1) has been posted as Not for drinking / Non potable.

Remediation with the non compliant ones will be to replace the aerators and then do a heavy flush for 2 weeks. Most of the high level ones were where the outlets aren't used frequently.



800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Project 02 Samples

Page 1 of 9

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV														
Client Address: <b>124 Salisbury Street</b>						DW= Drinking Water																	
Sandy Creek, NY 13145						GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil																	
Phone #: <b>315-412-5326</b>		Cell #:		G = Grab C = Composite Matrix - see codes above Chlorine Residual	Preservative Codes			<b>PLEASE NOTE:</b> Reports for businesses will be forwarded to your DOH.  <b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.															
E-Mail address: <u>aridge@scs.cnyric.org</u>					1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9= _____																		
Contact/Report to: <b>Andy Ridgeway</b>					<b>List Preservative Code Below</b> <table border="1" style="width:100%; border-collapse: collapse; text-align: center;"> <tr><td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td></tr> </table>			1	2	3	4	5	6	7	8	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:50%;">ANALYSIS / TEST REQUESTED</th> <th style="width:50%;">SAMPLE ID # (lab use only)</th> </tr> </table>						ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)
1	2	3	4					5	6	7	8												
ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)																						
Sampler: client																							
Date Collected	Time Collected	Sample Identification	G	C	Chlorine Residual	1	2	3	4	5	6	7	8	Subcontracted Y/N									
4/17/24	6:04	Elem. A 001	G	DW					1					Y	Lead	3627							
	6:05	002	G	DW					1					Y	Lead	3637							
	6:06	003	G	DW					1					Y	Lead								
	6:07	004	G	DW					1					Y	Lead								
	6:08	005	G	DW					1					Y	Lead								
	6:09	006	G	DW					1					Y	Lead								
	6:10	007	G	DW					1					Y	Lead								
	6:10	008	G	DW					1					Y	Lead								
	6:11	009	G	DW					1					Y	Lead								
	6:11	010	G	DW					1					Y	Lead								
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.													
Andrew Ridgeway		4/17/2024	9:12	Laurie Shultz		4/17/24	0912	16.4	Yes/No	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet YES NO													
Laurie Shultz		4/27/24	9:12	1100K BURNER		4/17/24	1100																

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

 Initial Review: RMB 4/17/24  
 Transcriptural Rev.: \_\_\_\_\_  
 Final Review: \_\_\_\_\_



## Chain of Custody

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil			Sample Information: <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV				
Client Address: <b>124 Salisbury Street</b>													
Sandy Creek, NY 13145													
Phone #: <b>315-412-5326</b>		Cell #:				Preservative Codes 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl 3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid 7= NH <sub>4</sub> CL 8= Unpres. 9=			PLEASE NOTE: Reports for businesses will be forwarded to your DOH.				
E-Mail address: <u>aridgew@sccs.cnyric.org</u>			G = Grab C = Composite	Matrix - see codes above	Chlorine Residual	List Preservative Code Below 1 2 3 4 5 6 7 8			Subcontracted Y/N				
Contact/Report to: <b>Andy Ridgeway</b>									Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/>				
Sampler: client									Date Needed: _____ a.m. / p.m.				
Date Collected	Time Collected	Sample Identification									ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)	
4/17/24	6:12	Elem A 011	G	DW				1			Y	Lead	3637
	6:12	012	G	DW				1			Y	Lead	
	6:13	013	G	DW				1			Y	Lead	
	6:14	014	G	DW				1			Y	Lead	
	6:15	015	G	DW				1			Y	Lead	
	6:15	016	G	DW				1			Y	Lead	
	6:16	017	G	DW				1			Y	Lead	
	6:16	018	G	DW				1			Y	Lead	
	6:17	019	G	DW				1			Y	Lead	
	6:18	020	G	DW				1			Y	Lead	
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.			
Andrew Ridgeway		4/17/2024	9:12	Laurie Shultz		4/17/24	09:12	16.4	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
Laurie Shultz		4/17/24	11:00	K. Borman		4/17/24	11:50		SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet				
									<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO				

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: KRM 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_



800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Page 3 of 9

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil			Sample Information: <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV		
Client Address: <b>124 Salisbury Street</b>											
Sandy Creek, NY 13145											
Phone #: <b>315-412-5326</b>		Cell #:				Preservative Codes 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl 3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid 7= NH <sub>4</sub> CL 8= Unpres. 9=			PLEASE NOTE: Reports for businesses will be forwarded to your DOH.		
E-Mail address: <u>aridge@scs.cnyric.org</u>									NOTES TO LABORATORY		
Contact/Report to: <b>Andy Ridgeway</b>									Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.		
Sampler: client											
Date Collected	Time Collected	Sample Identification	G = Grab C = Composite	Matrix - see codes above	Chlorine Residual	List Preservative Code Below			Subcontracted Y/N	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)
4/17/24	6:19	Elem. A 021	G	DW		1			Y	Lead	3637
	6:19	022	G	DW		1			Y	Lead	
	6:20	023	G	DW		1			Y	Lead	
	6:21	024	G	DW		1			Y	Lead	
	6:21	025	G	DW		1			Y	Lead	
	6:22	026	G	DW		1			Y	Lead	
	6:22	027	G	DW		1			Y	Lead	
	6:23	028	G	DW		1			Y	Lead	
	6:23	029	G	DW		1			Y	Lead	
	6:24	030	G	DW		1			Y	Lead	
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.	
Andrew Ridgeway		4/17/2024	9:12	Laurie Shultz		4/17/24	09:12	16.4	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Laurie Shultz		4/17/24	1100	K. Brynny		4/17/24	1100				
SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet										YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Initial Review: KMB 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_



## Chain of Custody

Page 4 of 9

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO#:			Matrix Codes DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil						Sample Information: <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: __Municipal__ <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV																						
Client Address: <b>124 Salisbury Street</b>																																		
<b>Sandy Creek, NY 13145</b>																																		
Phone #: <b>315-412-5326</b>		Cell #:		G = Grab C = Composite Matrix - see codes above Chlorine Residual	Preservative Codes 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.         9= _____								PLEASE NOTE: Reports for businesses will be forwarded to your DOH.																					
E-Mail address: <u>aridgew@scs.nyric.org</u>					<div style="float:right;">Y/N</div> <div style="clear:both;"></div> List Preservative Code Below <table border="1"><tr><td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td></tr><tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr></table>								1	2	3	4	5	6	7	8									NOTES TO LABORATORY Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.					
1	2	3	4										5	6	7	8																		
Contact/Report to: <b>Andy Ridgeway</b>				ANALYSIS / TEST REQUESTED						SAMPLE ID # (lab use only)																								
Sampler: client																																		
Date Collected	Time Collected	Sample Identification			G	DW																												
4/17/24	6:25	Elem. A 031			G	DW																												
	6:25	032			G	DW																												
	6:27	033			G	DW																												
	6:27	034			G	DW																												
	6:26	035			G	DW																												
	6:26	036			G	DW																												
	6:28	037			G	DW																												
	6:28	038			G	DW																												
	6:29	039			G	DW																												
	6:29	040			G	DW																												
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?		AUTHORIZED RECIPIENTS & CONTACT INFO.																							
Andrew Ridgeway		4/17/2024	9:12	Laurie Shelton		4/17/24	0912	16.4	(Yes) No		SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet <div style="text-align:center;">(YES) NO</div>																							
Laurie Shelton		4/17/24	1100	K Brown		4/17/24	1100																											

Doc. # 357

1/2/2024

Rev. # 118

**Amt. Due:** \_\_\_\_\_

**Amt. Paid:**

Cash	Check#	CC
------	--------	----

**Initial Review:**

Transcriptual Rev.:

**Final Review:**

## Chain of Custody

Page 5 of 9

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil						Sample Information: <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV								
Client Address: <b>124 Salisbury Street</b>																				
Sandy Creek, NY 13145																				
Phone #: <b>315-412-5326</b>			Cell #:			Preservative Codes 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.        9=  List Preservative Code Below 1 2 3 4 5 6 7 8						PLEASE NOTE: Reports for businesses will be forwarded to your DOH.								
E-Mail address: <u>aridgew@sccs.cnyric.org</u>			G = Grab C = Composite Matrix - see codes above Chlorine Residual									NOTES TO LABORATORY Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.								
Contact/Report to: <b>Andy Ridgeway</b>												ANALYSIS / TEST REQUESTED								
Sampler: client																			SAMPLE ID # (lab use only)	
Date Collected	Time Collected	Sample Identification	G	C																
4/17/24	6:30	ELEM.A 041	G	DW					1								Y	Lead	3637	
	6:31	042	G	DW					1								Y	Lead		
	6:31	043	G	DW					1								Y	Lead		
	6:32	044	G	DW					1								Y	Lead		
	6:33	045	G	DW					1								Y	Lead		
	6:34	046	G	DW					1								Y	Lead		
	6:01	047	G	DW					1								Y	Lead		
	6:01	048	G	DW					1								Y	Lead		
	6:03	049	G	DW					1								Y	Lead		
	6:35	050	G	DW					1								Y	Lead		
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.										
Andrew Ridgeway		4/17/2024	9:12	Laurie Shelton		4/17/24	0912	16.4	<input checked="" type="radio"/> Yes <input type="radio"/> No											
Laurie Shelton		4/17/24	1100	K. Bunney		4/17/24	1100													
SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet											YES NO									

Doc. # 357

1/2/2024

Rev. # 118

**Amt. Due:**

**Amt. Paid:**

Cash	Check#	CC
------	--------	----

Initial Review: *lems 4/17/24*

Transcriptual Rev.: \_\_\_\_\_

**Final Review:**



## Chain of Custody

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO#:			Matrix Codes			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV								
Client Address: <b>124 Salisbury Street</b>						DW= Drinking Water											
Sandy Creek, NY 13145						GW=Ground Water WW=Wastewater											
Phone #: <b>315-412-5326</b> Cell #:			G = Grab C = Composite Matrix - see codes above Chlorine Residual			Preservative Codes			PLEASE NOTE: Reports for businesses will be forwarded to your DOH. <b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.								
E-Mail address: <u>aridgew@scs.cnyric.org</u>						1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9= _____											
Contact/Report to: <b>Andy Ridgeway</b>						<b>List Preservative Code Below</b> 1 2 3 4 5 6 7 8											
Sampler: client																	
Date Collected	Time Collected	Sample Identification	G	C	Matrix	Chlorine Residual	1	2	3	4	5	6	7	8	Subcontracted Y/N	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)
4/17/24	6:35	Elem A	051	G	DW					1					Y	Lead	3637
	6:36		052	G	DW					1					Y	Lead	
	6:36		053	G	DW					1					Y	Lead	
	6:37		054	G	DW					1					Y	Lead	
	6:37		055	G	DW					1					Y	Lead	
	6:38		056	G	DW					1					Y	Lead	
	6:39		057	G	DW					1					Y	Lead	
	6:39		058	G	DW					1					Y	Lead	
	6:39		059	G	DW					1					Y	Lead	
	6:40		060	G	DW					1					Y	Lead	
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.							
Andrew Ridgeway		4/17/2024	9:12	Laurie Shultz		4/17/24	0912	16.4	(Yes) No	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet YES NO							
Laurie Shultz		4/17/24	1100	K. Bunnery		4/17/24	1100										

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: KMM 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_



## Chain of Custody

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			<b>Matrix Codes</b> DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: __Municipal__ <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV									
Client Address: <b>124 Salisbury Street</b>																		
<b>Sandy Creek, NY 13145</b>																		
Phone #: <b>315-412-5326</b>		Cell #:		G = Grab C = Composite Matrix - see codes above Chlorine Residual	<b>Preservative Codes</b> 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9=			PLEASE NOTE: Reports for businesses will be forwarded to your DOH. <b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.										
E-Mail address: <u>aridgew@sccs.cnyric.org</u>																		
Contact/Report to: <b>Andy Ridgeway</b>																		
Sampler: client																		
<b>Date Collected</b>	<b>Time Collected</b>	<b>Sample Identification</b>																
4/17/24	6:40	Elem A 061	G	DW					1							Y	Lead	3637
	6:41	062	G	DW					1							Y	Lead	/
	6:42	063	G	DW					1							Y	Lead	
	6:42	064	G	DW					1							Y	Lead	
	6:43	065	G	DW					1							Y	Lead	
	6:43	066	G	DW					1							Y	Lead	
	6:44	067	G	DW					1							Y	Lead	
	6:44	068	G	DW					1							Y	Lead	
	6:45	069	G	DW					1							Y	Lead	
	6:46	070	G	DW					1							Y	Lead	
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.								
Andrew Ridgeway		4/17/24	9:12	Laurie Shelton		4/17/24	09:12	16.4	(Yes) No	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet YES NO								
Laurie Shelton		4/17/24	1100	K. Brumby		4/17/24	1100											

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: Wm 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_



800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Page 8 of 9

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			<b>Matrix Codes</b> DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV							
Client Address: <b>124 Salisbury Street</b>																
<b>Sandy Creek, NY 13145</b>																
Phone #: <b>315-412-5326</b>		Cell #:		G = Grab C = Composite Matrix - see codes above Chlorine Residual			<b>Preservative Codes</b> 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9=			PLEASE NOTE: Reports for businesses will be forwarded to your DOH. <b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.						
E-Mail address: <u>aridge@scs.cnyric.org</u>																
Contact/Report to: <b>Andy Ridgeway</b>																
Sampler: client																
<b>Date Collected</b>	<b>Time Collected</b>	<b>Sample Identification</b>				<b>List Preservative Code Below</b>			Subcontracted Y/N	<b>ANALYSIS / TEST REQUESTED</b>		<b>SAMPLE ID # (lab use only)</b>				
						1	2	3		4	5	6	7	8		
4/17/24	6:47	Elem A 071	G	DW					1					Y	Lead	3637
	6:47	072	G	DW					1					Y	Lead	
	6:48	073	G	DW					1					Y	Lead	
	6:49	074	G	DW					1					Y	Lead	
	6:50	075	G	DW					1					Y	Lead	
	6:50	076	G	DW					1					Y	Lead	
	6:51	077	G	DW					1					Y	Lead	
	6:51	078	G	DW					1					Y	Lead	
	6:52	079	G	DW					1					Y	Lead	
	6:53	080	G	DW					1					Y	Lead	
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.						
Andrew Ridgeway		4/17/24	9:12	Laurie Stultz		4/17/24	0912	16.4	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO						
Laurie Stultz		4/17/24	1100	K. Brumby		4/17/24	1100									

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: CMR 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_



## Chain of Custody

Page 9 of 9

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes			Sample Information:			
Client Address: <b>124 Salisbury Street</b>						DW= Drinking Water			<input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV			
Sandy Creek, NY 13145						GW=Ground Water WW=Wastewater						
Phone #: <b>315-412-5326</b>		Cell #:		G = Grab C = Composite	Matrix - see codes above	Chlorine Residual	Preservative Codes			PLEASE NOTE: Reports for businesses will be forwarded to your DOH.		
E-Mail address: <u>aridgew@sccs.cnyric.org</u>							1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.        9= _____			<b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.		
Contact/Report to: <b>Andy Ridgeway</b>							Subcontracted Y / N Y    N					
Sampler: client										<b>List Preservative Code Below</b> 1   2   3   4   5   6   7   8		
Date Collected	Time Collected	Sample Identification										
4/17/24	6:53	Elem A 081	G	DW					1			Y
4/17/24	6:54	082	G	DW					1			Y
			G	DW								Y
			G	DW								Y
			G	DW								Y
			G	DW								Y
			G	DW								Y
			G	DW								Y
			G	DW								Y
			G	DW								Y
			G	DW								Y
			G	DW								Y
			G	DW								Y
			G	DW								Y
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.		
Andrew Ridgeway		4/17/2024	9:12	Laurie Sheltz		4/17/24	0912	16.4	<input checked="" type="radio"/> Yes / <input type="radio"/> No	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet <div style="text-align: center;"> <input checked="" type="radio"/> YES      <input type="radio"/> NO         </div>		
Laurie Sheltz		4/17/24	1100	K. Brown		4/17/24	1100					

Doc. # 357

1/2/2024

Rev. # 118

**Amt. Due:**

**Amt. Paid:** \_\_\_\_\_

Cash	Check#	CC
------	--------	----

Initial Review: KPM 4/17/04

Transcriptual Rev.: 10/17/2015

**Final Review:**

Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421128

**Project Number:** AL24-0474D-1

**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-01

**Date Collected:** 04/17/24 06:04

**Client ID:** 001

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0017		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 12:14	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421128

**Project Number:** AL24-0474D-1

**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-02

**Date Collected:** 04/17/24 06:05

**Client ID:** 002

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0011		mg/l	0.0010	-	1	04/26/24 00:54	04/29/24 12:28	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-1

**Lab Number:** L2421128  
**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-03  
**Client ID:** 003  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:06  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 12:42	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421128

**Project Number:** AL24-0474D-1

**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-04

**Date Collected:** 04/17/24 06:07

**Client ID:** 004

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 12:47	EPA 3005A	3,200.8	NTB





Serial\_No:04302410:20

Project Name: SANDY CREEK CS

Lab Number: L2421128

Project Number: AL24-0474D-1

Report Date: 04/30/24

**SAMPLE RESULTS**

Lab ID: L2421128-05

Date Collected: 04/17/24 06:08

Client ID: 005 Room 1204 sink

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0262		mg/l	0.0010	-	1	04/26/24 00:54	04/29/24 13:03	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421128

**Project Number:** AL24-0474D-1

**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-06

**Date Collected:** 04/17/24 06:09

**Client ID:** 006

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 13:07	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-1

**Lab Number:** L2421128  
**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-07  
**Client ID:** 007  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:10  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0012		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 13:12	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-1

**Lab Number:** L2421128  
**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-08  
**Client ID:** 008  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:10  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 13:17	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS  
Project Number: AL24-0474D-1

Lab Number: L2421128  
Report Date: 04/30/24

SAMPLE RESULTS

Lab ID: L2421128-09  
Client ID: 009  
Sample Location: ELEM. A

Date Collected: 04/17/24 06:11  
Date Received: 04/17/24  
Field Prep: Not Specified

Sample Depth:  
Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 13:21	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS  
Project Number: AL24-0474D-1

Lab Number: L2421128  
Report Date: 04/30/24

SAMPLE RESULTS

Lab ID: L2421128-10  
Client ID: 010  
Sample Location: ELEM. A

Date Collected: 04/17/24 06:11  
Date Received: 04/17/24  
Field Prep: Not Specified

Sample Depth:  
Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 13:26	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

Project Name: SANDY CREEK CS

Lab Number: L2421128

Project Number: AL24-0474D-1

Report Date: 04/30/24

**SAMPLE RESULTS**

Lab ID: L2421128-11

Date Collected: 04/17/24 06:12

Client ID: 011

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0014		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 13:31	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

Project Name: SANDY CREEK CS

Lab Number: L2421128

Project Number: AL24-0474D-1

Report Date: 04/30/24

**SAMPLE RESULTS**

Lab ID: L2421128-12

Date Collected: 04/17/24 06:12

Client ID: 012

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 13:35	EPA 3005A	3,200.8	NTB





Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-1

**Lab Number:** L2421128  
**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-13  
**Client ID:** 013  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:13  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0010		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 13:40	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

Project Name: SANDY CREEK CS

Lab Number: L2421128

Project Number: AL24-0474D-1

Report Date: 04/30/24

**SAMPLE RESULTS**

Lab ID: L2421128-14

Date Collected: 04/17/24 06:14

Client ID: 014

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 13:45	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

Project Name: SANDY CREEK CS

Lab Number: L2421128

Project Number: AL24-0474D-1

Report Date: 04/30/24

### SAMPLE RESULTS

Lab ID: L2421128-15

Date Collected: 04/17/24 06:15

Client ID: 015

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 13:59	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421128

**Project Number:** AL24-0474D-1

**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-16

**Date Collected:** 04/17/24 06:15

**Client ID:** 016

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 14:04	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421128

**Project Number:** AL24-0474D-1

**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-17

**Date Collected:** 04/17/24 06:16

**Client ID:** 017

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 14:09	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-1

**Lab Number:** L2421128  
**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-18  
**Client ID:** 018  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:16  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 14:13	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

Project Name: SANDY CREEK CS

Lab Number: L2421128

Project Number: AL24-0474D-1

Report Date: 04/30/24

### SAMPLE RESULTS

Lab ID: L2421128-19

Date Collected: 04/17/24 06:17

Client ID: 019

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 14:18	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-1

**Lab Number:** L2421128  
**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-20  
**Client ID:** 020  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:18  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	-	1	04/26/24 00:54	04/29/24 14:23	EPA 3005A	3,200.8	NTB





Serial\_No:04302410:20

Project Name: SANDY CREEK CS

Lab Number: L2421128

Project Number: AL24-0474D-1

Report Date: 04/30/24

**SAMPLE RESULTS**

Lab ID: L2421128-21

Date Collected: 04/17/24 06:19

Client ID: 021

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 19:05	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-1

**Lab Number:** L2421128  
**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-22  
**Client ID:** 022  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:19  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 19:29	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421128

**Project Number:** AL24-0474D-1

**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-23

**Date Collected:** 04/17/24 06:20

**Client ID:** 023

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 19:52	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421128

**Project Number:** AL24-0474D-1

**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-24

**Date Collected:** 04/17/24 06:21

**Client ID:** 024

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0018		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 19:57	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-1

**Lab Number:** L2421128  
**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-25  
**Client ID:** 025  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:21  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 20:02	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS  
Project Number: AL24-0474D-1

Lab Number: L2421128  
Report Date: 04/30/24

SAMPLE RESULTS

Lab ID: L2421128-26  
Client ID: 026  
Sample Location: ELEM. A

Date Collected: 04/17/24 06:22  
Date Received: 04/17/24  
Field Prep: Not Specified

Sample Depth:  
Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 20:06	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421128

**Project Number:** AL24-0474D-1

**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-27

**Date Collected:** 04/17/24 06:22

**Client ID:** 027

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 20:11	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421128

**Project Number:** AL24-0474D-1

**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-28

**Date Collected:** 04/17/24 06:23

**Client ID:** 028

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0015		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 20:16	EPA 3005A	3,200.8	NTB





Project Name: SANDY CREEK CS  
Project Number: AL24-0474D-1

Lab Number: L2421128  
Report Date: 04/30/24

SAMPLE RESULTS

Lab ID: L2421128-29  
Client ID: 029  
Sample Location: ELEM. A

Date Collected: 04/17/24 06:23  
Date Received: 04/17/24  
Field Prep: Not Specified

Sample Depth:  
Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 20:20	EPA 3005A	3,200.8	NTB



Serial\_No:04302410:20

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-1

**Lab Number:** L2421128  
**Report Date:** 04/30/24

**SAMPLE RESULTS**

**Lab ID:** L2421128-30  
**Client ID:** 030  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:24  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 20:25	EPA 3005A	3,200.8	NTB



Serial\_No:05012411:51

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421131

**Project Number:** AL24-0474D-2

**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-01

**Date Collected:** 04/17/24 06:25

**Client ID:** 031

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0019		mg/l	0.0010	--	1	04/28/24 17:10	04/30/24 19:09	EPA 3005A	3,200.8	EJF



Serial No:05012411:51

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-02  
**Client ID:** 032  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:25  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/28/24 17:10	04/30/24 19:23	EPA 3005A	3,200.8	EJF



Serial\_No:05012411:51

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-03  
**Client ID:** 033  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:27  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0028		mg/l	0.0010	—	1	04/28/24 17:10	04/30/24 19:56	EPA 3005A	3,200.8	EJF



Serial\_No:05012411:51

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

### SAMPLE RESULTS

**Lab ID:** L2421131-04  
**Client ID:** 034  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:27  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0013		mg/l	0.0010	—	1	04/28/24 17:10	04/30/24 20:01	EPA 3005A	3,200.8	EJF



Serial\_No:05012411:51

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-05  
**Client ID:** 035  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:26  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0046		mg/l	0.0010	—	1	04/28/24 17:10	04/30/24 20:05	EPA 3005A	3,200.8	EJF



Serial\_No:05012411:51

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421131

**Project Number:** AL24-0474D-2

**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-06

**Date Collected:** 04/17/24 06:26

**Client ID:** 036

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0050		mg/l	0.0010	—	1	04/28/24 17:10	04/30/24 20:10	EPA 3005A	3,200.8	EJF





Serial\_No:05012411:51

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421131

**Project Number:** AL24-0474D-2

**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-07

**Date Collected:** 04/17/24 06:28

**Client ID:** 037

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0013		mg/l	0.0010	--	1	04/28/24 17:10	04/30/24 20:15	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-08  
**Client ID:** 038  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:28  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0028		mg/l	0.0010	—	1	04/28/24 17:10	04/30/24 20:19	EPA 3005A	3,200.8	EJF



Serial\_No:05012411:51

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421131

**Project Number:** AL24-0474D-2

**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-09

**Date Collected:** 04/17/24 06:29

**Client ID:** 039

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0032		mg/l	0.0010	--	1	04/28/24 17:10	04/30/24 20:24	EPA 3005A	3,200.8	EJF



Project Name: SANDY CREEK CS

Lab Number: L2421131

Project Number: AL24-0474D-2

Report Date: 05/01/24

## SAMPLE RESULTS

Lab ID: L2421131-10

Date Collected: 04/17/24 06:29

Client ID: 040

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0027		mg/l	0.0010	—	1	04/28/24 17:10	04/30/24 20:29	EPA 3005A	3,200.8	EJF



Project Name: SANDY CREEK CS

Lab Number: L2421131

Project Number: AL24-0474D-2

Report Date: 05/01/24

## SAMPLE RESULTS

Lab ID: L2421131-11

Date Collected: 04/17/24 06:30

Client ID: 041

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0028		mg/l	0.0010	--	1	04/28/24 17:10	04/30/24 20:34	EPA 3005A	3,200.8	EJF



Serial\_No:05012411:51

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-12  
**Client ID:** 042  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:31  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0085		mg/l	0.0010	—	1	04/28/24 17:10	04/30/24 20:38	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-13  
**Client ID:** 043  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:31  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0047		mg/l	0.0010	—	1	04/28/24 17:10	04/30/24 20:53	EPA 3005A	3,200.8	EJF



Serial\_No:05012411:51

Project Name: SANDY CREEK CS

Lab Number: L2421131

Project Number: AL24-0474D-2

Report Date: 05/01/24

**SAMPLE RESULTS**

Lab ID: L2421131-14

Date Collected: 04/17/24 06:32

Client ID: 044

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.010		mg/l	0.0010	--	1	04/28/24 17:10	04/30/24 20:57	EPA 3005A	3,200.8	EJF





Serial\_No:05012411:51

**Project Name:** SANDY CREEK CS

**Project Number:** AL24-0474D-2

**Lab Number:** L2421131

**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-15

**Client ID:** 045

**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:33

**Date Received:** 04/17/24

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0078		mg/l	0.0010	--	1	04/28/24 17:10	04/30/24 21:02	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-16  
**Client ID:** 046  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:34  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0022		mg/l	0.0010	--	1	04/28/24 17:10	04/30/24 21:07	EPA 3005A	3,200.8	EJF



Serial\_No:05012411:51

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421131

**Project Number:** AL24-0474D-2

**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-17

**Date Collected:** 04/17/24 06:01

**Client ID:** 047

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals' - Mansfield Lab											
Lead, Total	0.0013		mg/l	0.0010	—	1	04/28/24 17:10	04/30/24 21:11	EPA 3005A	3,200.8	EJF



Serial\_No:05012411:51

Project Name: SANDY CREEK CS

Lab Number: L2421131

Project Number: AL24-0474D-2

Report Date: 05/01/24

**SAMPLE RESULTS**

Lab ID: L2421131-18

Date Collected: 04/17/24 06:01

Client ID: 048

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0011		mg/l	0.0010	--	1	04/28/24 17:10	04/30/24 21:16	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-19  
**Client ID:** 049  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:03  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0096		mg/l	0.0010	—	1	04/28/24 17:10	04/30/24 21:21	EPA 3005A	3,200.8	EJF



Serial\_No:05012411:51

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421131

**Project Number:** AL24-0474D-2

**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-20

**Date Collected:** 04/17/24 06:03

**Client ID:** 050

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/28/24 17:10	04/30/24 21:25	EPA 3005A	3,200.8	EJF



Serial\_No:05012411:51

Project Name: SANDY CREEK CS

Lab Number: L2421131

Project Number: AL24-0474D-2

Report Date: 05/01/24

**SAMPLE RESULTS**

Lab ID: L2421131-21

Date Collected: 04/17/24 06:35

Client ID: 051

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 20:30	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-22  
**Client ID:** 052  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:36  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 20:35	EPA 3005A	3,200.8	NTB





Project Name: SANDY CREEK CS

Lab Number: L2421131

Project Number: AL24-0474D-2

Report Date: 05/01/24

## SAMPLE RESULTS

Lab ID: L2421131-23

Date Collected: 04/17/24 06:36

Client ID: 053

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.001		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 20:49	EPA 3005A	3,200.8	NTB



Serial\_No:05012411:51

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-24  
**Client ID:** 054  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:37  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 20:53	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-25  
**Client ID:** 055  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:37  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 20:58	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-26  
**Client ID:** 056  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:38  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/26/24 00:54	04/29/24 21:03	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-27  
**Client ID:** 057  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:39  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0024		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 21:08	EPA 3005A	3,200.8	NTB



Serial\_No:05012411:51

Project Name: SANDY CREEK CS

Lab Number: L2421131

Project Number: AL24-0474D-2

Report Date: 05/01/24

**SAMPLE RESULTS**

Lab ID: L2421131-28

Date Collected: 04/17/24 06:39

Client ID: 058

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0050		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 21:12	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-2

**Lab Number:** L2421131  
**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-29  
**Client ID:** 059  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:39  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0031		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 21:17	EPA 3005A	3,200.8	NTB



Serial\_No:05012411:51

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421131

**Project Number:** AL24-0474D-2

**Report Date:** 05/01/24

**SAMPLE RESULTS**

**Lab ID:** L2421131-30

**Date Collected:** 04/17/24 06:40

**Client ID:** 060

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/26/24 00:54	04/29/24 21:22	EPA 3005A	3,200.8	NTB





**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-3

**Lab Number:** L2421137  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421137-01  
**Client ID:** 061  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:40  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:20	04/23/24 20:21	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-3

**Lab Number:** L2421137  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421137-02  
**Client ID:** 062  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:41  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 16:20	04/23/24 20:32	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421137

**Project Number:** AL24-0474D-3

**Report Date:** 04/24/24

# **SAMPLE RESULTS**

**Lab ID:** L2421137-03

**Date Collected:** 04/17/24 06:42

**Client ID:** 063

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0011		mg/l	0.0010	--	1	04/22/24 16:20	04/23/24 20:51	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421137

**Project Number:** AL24-0474D-3

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421137-04

**Date Collected:** 04/17/24 06:42

**Client ID:** 064

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
<b>Total Metals - Mansfield Lab</b>											
Lead, Total	0.0018		mg/l	0.0010	--	1	04/22/24 16:20	04/23/24 20:54	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-3

**Lab Number:** L2421137  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421137-05  
**Client ID:** 065  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:43  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0017		mg/l	0.0010	—	1	04/22/24 16:20	04/23/24 20:58	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

Project Name: SANDY CREEK CS

Lab Number: L2421137

Project Number: AL24-0474D-3

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421137-06

Date Collected: 04/17/24 06:43

Client ID: 066

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0129		mg/l	0.0010	--	1	04/22/24 16:20	04/23/24 21:02	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-3

**Lab Number:** L2421137  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421137-07  
**Client ID:** 067  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:44  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 16:20	04/23/24 21:06	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421137

**Project Number:** AL24-0474D-3

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421137-08

**Date Collected:** 04/17/24 06:44

**Client ID:** 068

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0024		mg/l	0.0010	--	1	04/22/24 16:20	04/23/24 21:09	EPA 3005A	3,200.8	NTB





Serial\_No:04242413:30

Project Name: SANDY CREEK CS

Lab Number: L2421137

Project Number: AL24-0474D-3

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421137-09

Date Collected: 04/17/24 06:45

Client ID: 069

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0037		mg/l	0.0010	—	1	04/22/24 16:20	04/23/24 21:13	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS  
Project Number: AL24-0474D-3

Lab Number: L2421137  
Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421137-10  
Client ID: 070 Room 1429 sink  
Sample Location: ELEM. A

Date Collected: 04/17/24 06:46  
Date Received: 04/17/24  
Field Prep: Not Specified

Sample Depth:  
Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0355		mg/l	0.0010	—	1	04/22/24 16:20	04/23/24 21:17	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-3

**Lab Number:** L2421137  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421137-11  
**Client ID:** 071  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:47  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0028		mg/l	0.0010	—	1	04/22/24 16:20	04/23/24 21:20	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS**Lab Number:** L2421137**Project Number:** AL24-0474D-3**Report Date:** 04/24/24**SAMPLE RESULTS****Lab ID:** L2421137-12**Date Collected:** 04/17/24 06:47**Client ID:** 072**Date Received:** 04/17/24**Sample Location:** ELEM. A**Field Prep:** Not Specified**Sample Depth:****Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0039		mg/l	0.0010	—	1	04/22/24 16:20	04/23/24 21:24	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421137

**Project Number:** AL24-0474D-3

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421137-13

**Date Collected:** 04/17/24 06:48

**Client ID:** 073

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 16:20	04/23/24 21:35	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421137

**Project Number:** AL24-0474D-3

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421137-14

**Date Collected:** 04/17/24 06:49

**Client ID:** 074

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0024		mg/l	0.0010	—	1	04/22/24 16:20	04/23/24 21:39	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421137

**Project Number:** AL24-0474D-3

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421137-15

**Date Collected:** 04/17/24 06:50

**Client ID:** 075

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0012		mg/l	0.0010	--	1	04/22/24 16:20	04/23/24 21:43	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474D-3

**Lab Number:** L2421137  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421137-16  
**Client ID:** 076  
**Sample Location:** ELEM. A

**Date Collected:** 04/17/24 06:50  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 16:20	04/23/24 21:47	EPA 3005A	3,200.8	NTB





Serial\_No:04242413:30

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421137

**Project Number:** AL24-0474D-3

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421137-17

**Date Collected:** 04/17/24 06:51

**Client ID:** 077

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.001		mg/l	0.0010	--	1	04/22/24 16:20	04/23/24 21:50	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421137

**Project Number:** AL24-0474D-3

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421137-18

**Date Collected:** 04/17/24 06:51

**Client ID:** 078

**Date Received:** 04/17/24

**Sample Location:** ELEM. A

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 16:20	04/23/24 21:54	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421137

Project Number: AL24-0474D-3

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421137-19

Date Collected: 04/17/24 06:52

Client ID: 079

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:20	04/23/24 21:58	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

Project Name: SANDY CREEK CS

Lab Number: L2421137

Project Number: AL24-0474D-3

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421137-20

Date Collected: 04/17/24 06:53

Client ID: 080

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0029		mg/l	0.0010	--	1	04/22/24 16:20	04/23/24 22:01	EPA 3005A	3,200.8	NTB



Serial\_No:04242413:30

Project Name: SANDY CREEK CS

Lab Number: L2421137

Project Number: AL24-0474D-3

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421137-21

Date Collected: 04/17/24 06:53

Client ID: 081

Date Received: 04/17/24

Sample Location: ELEM. A

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/23/24 11:28	04/24/24 08:38	EPA 3005A	3,200.8	EJF





800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Project 1031 Samples

Page \_\_\_\_ of \_\_\_\_

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: __Municipal__ <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV								
Client Address: <b>124 Salisbury Street</b>						DW= Drinking Water											
Sandy Creek, NY 13145						GW=Ground Water WW=Wastewater											
Phone #: <b>315-412-5326</b> Cell #:			G = Grab C = Composite Matrix - see codes above Chlorine Residual			Preservative Codes			PLEASE NOTE: Reports for businesses will be forwarded to your DOH.								
E-Mail address: <u>aridgew@sccs.cnyric.org</u>						1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9= _____			<b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.								
Contact/Report to: <b>Andy Ridgeway</b>						<b>List Preservative Code Below</b> 1 2 3 4 5 6 7 8											
Sampler: client																	
Date Collected	Time Collected	Sample Identification	G	C	Matrix	Chlorine Residual	1	2	3	4	5	6	7	8	Subcontracted Y/N	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)
4/17/24	4:30	HS/MS B1st	G		DW					1					Y	Lead	3637
	4:31		G		DW					1					Y	Lead	
	4:32		G		DW					1					Y	Lead	
	4:15		G		DW					1					Y	Lead	
	4:16		G		DW					1					Y	Lead	
	4:17		G		DW					1					Y	Lead	
	4:18		G		DW					1					Y	Lead	
	4:18		G		DW					1					Y	Lead	
	4:19		G		DW					1					Y	Lead	
	4:20		G		DW					1					Y	Lead	
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.							
Andrew Ridgeway		4/17/24	9:12	Laurie Shultz		4/17/24	09:12	10.4	(Yes/No)	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet YES NO							
Laurie Shultz		4/17/24	1100	K. B. H. M. Y.		4/17/24	11:00										

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: KLM 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_

## Chain of Custody

Page \_\_\_\_ of \_\_\_\_

Client Name: <b>Sandy Creek CS</b>		Client Project ID / PO#:		Matrix Codes		Sample Information:					
Client Address: <b>124 Salisbury Street</b>				DW= Drinking Water		<input type="checkbox"/> Drilled <input type="checkbox"/> Dug					
Sandy Creek, NY 13145				GW=Ground Water WW=Wastewater		<input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u>					
Phone #: <b>315-412-5326</b>		Cell #:		G = Grab C = Composite Matrix - see codes above Chlorine Residual		Preservative Codes		PLEASE NOTE: Reports for businesses will be forwarded to your DOH.			
E-Mail address: <b>aridgew@sccs.cnyric.org</b>		1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl 3= H <sub>2</sub> SO <sub>4</sub>				Subcontracted Y/N					
Contact/Report to: <b>Andy Ridgeway</b>		4= HNO <sub>3</sub> 5= NaOH									
Sampler: client						6= Asorbic Acid 7= NH <sub>4</sub> CL		NOTES TO LABORATORY			
						8= Unpres. 9=		Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.			
Date Collected		Time Collected		Sample Identification		List Preservative Code Below		ANALYSIS / TEST REQUESTED		SAMPLE ID # (lab use only)	
1		2		3		4		5		6	
7		8		9		10		11		12	
13		14		15		16		17		18	
19		20		21		22		23		24	
25		26		27		28		29		30	
31		32		33		34		35		36	
37		38		39		40		41		42	
43		44		45		46		47		48	
49		50		51		52		53		54	
55		56		57		58		59		60	
61		62		63		64		65		66	
67		68		69		70		71		72	
73		74		75		76		77		78	
79		80		81		82		83		84	
85		86		87		88		89		90	
91		92		93		94		95		96	
97		98		99		100		101		102	
103		104		105		106		107		108	
109		110		111		112		113		114	
115		116		117		118		119		120	
121		122		123		124		125		126	
127		128		129		130		131		132	
133		134		135		136		137		138	
139		140		141		142		143		144	
145		146		147		148		149		150	
151		152		153		154		155		156	
157		158		159		160		161		162	
163		164		165		166		167		168	
169		170		171		172		173		174	
175		176		177		178		179		180	
181		182		183		184		185		186	
187		188		189		190		191		192	
193		194		195		196		197		198	
199		200		201		202		203		204	
205		206		207		208		209		210	
211		212		213		214		215		216	
217		218		219		220		221		222	
223		224		225		226		227		228	
229		230		231		232		233		234	
235		236		237		238		239		240	
241		242		243		244		245		246	
247		248		249		250		251		252	
253		254		255		256		257		258	
259		260		261		262		263		264	
265		266		267		268		269		270	
271		272		273		274		275		276	
277		278		279		280		281		282	
283		284		285		286		287		288	
289		290		291		292		293		294	
295		296		297		298		299		300	

Doc. # 357

1/2/2024

Rev. # 118

**Amt. Due:**

**Amt. Paid:**

Initial Review: 12MB 4/17/24

Transcriptual Rev.: \_\_\_\_\_

**Final Review:** \_\_\_\_\_

Cash	Check#	CC
------	--------	----



800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Page \_\_\_\_ of \_\_\_\_

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV							
Client Address: <b>124 Salisbury Street</b>						DW= Drinking Water										
Sandy Creek, NY 13145						GW=Ground Water WW=Wastewater										
Phone #: <b>315-412-5326</b> Cell #:			G = Grab C = Composite Matrix - see codes above Chlorine Residual			SL=Sludge SW=Surface Water SO=Soil			PLEASE NOTE: Reports for businesses will be forwarded to your DOH.							
E-Mail address: <u>aridgew@scs.nyric.org</u>						Preservative Codes			<b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.							
Contact/Report to: <b>Andy Ridgeway</b>						1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9= _____										
Sampler: client						List Preservative Code Below										
Date Collected	Time Collected	Sample Identification	G	C	Chlorine Residual	1	2	3	4	5	6	7	8	Subcontracted Y/N	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)
4/17/24	4:29	HS/MS B 1st 120	G	DW					1					Y	Lead	3637
	4:34	121	G	DW					1					Y	Lead	
	4:34	122	G	DW					1					Y	Lead	
	4:35	123	G	DW					1					Y	Lead	
	4:36	124	G	DW					1					Y	Lead	
	4:36	125	G	DW					1					Y	Lead	
	4:37	126	G	DW					1					Y	Lead	
	4:38	127	G	DW					1					Y	Lead	
	4:39	128	G	DW					1					Y	Lead	
	4:40	129	G	DW					1					Y	Lead	
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.						
Andrew Ridgeway		4/17/2024	9:12	Laurie Shellen		4/17/24	0912	16.4	<input checked="" type="radio"/> Yes <input type="radio"/> No	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet YES <input checked="" type="radio"/> NO <input type="radio"/>						
Laurie Shellen		4/17/24	1100	K Brommy		4/17/24	1100									

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: KWB 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_





800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Page \_\_\_\_ of \_\_\_\_

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV								
Client Address: <b>124 Salisbury Street</b>						DW= Drinking Water											
Sandy Creek, NY 13145						GW=Ground Water WW=Wastewater											
Phone #: <b>315-412-5326</b>		Cell #:	G = Grab C = Composite Matrix - see codes above Chlorine Residual			Preservative Codes			PLEASE NOTE:								
E-Mail address: <u>aridge@scsccs.cnyric.org</u>						1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9= _____			Reports for businesses will be forwarded to your DOH. <b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.								
Contact/Report to: <b>Andy Ridgeway</b>						List Preservative Code Below 1 2 3 4 5 6 7 8			Subcontracted Y/N ANALYSIS / TEST REQUESTED SAMPLE ID # (lab use only)								
Sampler: client																	
Date Collected	Time Collected	Sample Identification	G	C	Matrix	Chlorine Residual	1	2	3	4	5	6	7	8	Subcontracted Y/N	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)
4/17/24	4:41	HS/MSB/st 130	G		DW					1					Y	Lead	3637
	4:42	131	G		DW					1					Y	Lead	
	4:42	132	G		DW					1					Y	Lead	
	4:43	133	G		DW					1					Y	Lead	
	4:45	134	G		DW					1					Y	Lead	
	4:46	135	G		DW					1					Y	Lead	
	4:47	136	G		DW					1					Y	Lead	
	4:47	137	G		DW					1					Y	Lead	
	4:52	138	G		DW					1					Y	Lead	
	4:53	139	G		DW					1					Y	Lead	
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.							
Andrew Ridgeway		4/17/2024	9:12	Laurie Shultz		4/17/24	0913	16.4	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO							
Laurie Shultz		4/17/24	1100	K. B. H. M. G.		4/17/24	1100										

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: KLMS 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_



800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Page \_\_\_\_ of \_\_\_\_

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			<b>Matrix Codes</b> DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: __Municipal__ <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV										
Client Address: <b>124 Salisbury Street</b>			Phone #: <b>315-412-5326</b> Cell #: _____ E-Mail address: <b>aridgew@scs.cnyric.org</b> Contact/Report to: <b>Andy Ridgeway</b> Sampler: client			<b>Preservative Codes</b> 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9= _____			PLEASE NOTE: Reports for businesses will be forwarded to your DOH.										
Sandy Creek, NY 13145						<b>List Preservative Code Below</b> <table border="1" style="width:100%; text-align: center;"> <tr><td>1</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td></tr> </table>			1	2	3	4	5	6	7	8	<b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.		
1	2	3				4	5	6	7	8									
			G = Grab C = Composite Matrix - see codes above Chlorine Residual			Subcontracted Y/N													
<b>Date Collected</b>	<b>Time Collected</b>	<b>Sample Identification</b>	<b>G</b>	<b>C</b>	<b>Chlorine Residual</b>	<b>ANALYSIS / TEST REQUESTED</b>			<b>SAMPLE ID # (lab use only)</b>										
4/17/24	4:54	HS/MS B 1st 140	G	DW					1			Y	Lead	3637					
	4:54	141	G	DW					1			Y	Lead						
	4:55	142	G	DW					1			Y	Lead						
	4:55	143	G	DW					1			Y	Lead						
	4:57	144	G	DW					1			Y	Lead						
	4:58	145	G	DW					1			Y	Lead						
	4:59	146	G	DW					1			Y	Lead						
	5:00	147	G	DW					1			Y	Lead						
	5:06	148	G	DW					1			Y	Lead						
	5:08	149	G	DW					1			Y	Lead						
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.									
Andrew Ridgeway		4/17/2024	9:12	Lauri Stultz		4/17/24	0912	16.4	Yes / No	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet YES NO									
Lauri Stultz		4/17/24	1100	K. Brunny		4/17/24	1150												

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

 Initial Review: KMB 4/17/24  
 Transcriptural Rev.: \_\_\_\_\_  
 Final Review: \_\_\_\_\_



## Chain of Custody

Client Name: <b>Sandy Creek CS</b>		Client Project ID / PO# :		<b>Matrix Codes</b> DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil		<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV											
Client Address: <b>124 Salisbury Street</b>																	
<b>Sandy Creek, NY 13145</b>																	
Phone #: <b>315-412-5326</b>		Cell #:		<b>Preservative Codes</b> 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9=		PLEASE NOTE: Reports for businesses will be forwarded to your DOH. <b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.											
E-Mail address: <u>aridgew@scs.cnyric.org</u>		Contact/Report to: <b>Andy Ridgeway</b>															
Sampler: client																	
Date Collected		Time Collected		Sample Identification		G = Grab C = Composite		Matrix - see codes above		Chlorine Residual		Subcontracted Y/N		ANALYSIS / TEST REQUESTED		SAMPLE ID # (lab use only)	
4/17/24		—		HS/MSB 1st -150		G		DW				Y		Lead		3637	
		5:02		151		G		DW				Y		Lead			
		5:02		152		G		DW				Y		Lead			
		5:03		153		G		DW				Y		Lead			
		4:49		154		G		DW				Y		Lead			
		4:49		155		G		DW				Y		Lead			
		4:50		156		G		DW				Y		Lead			
		5:09		157		G		DW				Y		Lead			
		5:05		158		G		DW				Y		Lead			
		5:05		159		G		DW				Y		Lead			
Relinquished by:		Date		Time		Received by:		Date		Time		Rec'd Temp°		ICED?		AUTHORIZED RECIPIENTS & CONTACT INFO.	
Andrew Ridgeway		4/17/2024		9:12		Lauri Shella		4/17/24		0912		16.4		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Lauri Shella		4/17/24		1100		KBrownley		4/17/24		1100							
SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet																YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

 Initial Review: KMB 4/17/24  
 Transcriptual Rev.: \_\_\_\_\_  
 Final Review: \_\_\_\_\_



Page \_\_\_\_ of \_\_\_\_

Doc. # 357  
1/2/2024  
Rev. # 118

**Amt. Due:**

**Amt. Paid:**

Cash	Check#	CC
------	--------	----

Initial Review: 12/11/13 4/17/14  
 Transcriptual Rev.: \_\_\_\_\_  
 Final Review: \_\_\_\_\_

Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-01  
**Client ID:** 100  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:30  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/24/24 23:46	04/26/24 15:25	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421105

**Project Number:** AL24-0474B-1

**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-02

**Date Collected:** 04/17/24 04:31

**Client ID:** 101

**Date Received:** 04/17/24

**Sample Location:** HS/MS B1ST

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0011		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 15:39	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

Project Name: SANDY CREEK CS

Lab Number: L2421105

Project Number: AL24-0474B-1

Report Date: 04/28/24

**SAMPLE RESULTS**

Lab ID: L2421105-03

Date Collected: 04/17/24 04:32

Client ID: 102

Date Received: 04/17/24

Sample Location: HS/MS B1ST

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0029		mg/l	0.0010	—	1	04/24/24 23:46	04/26/24 15:53	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-04  
**Client ID:** 103  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:15  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0017		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 15:57	EPA 3005A	3,200.8	NTB





Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-05  
**Client ID:** 104  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:16  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0033		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 16:19	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-06  
**Client ID:** 105  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:17  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0011		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 16:24	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-07  
**Client ID:** 106  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:18  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 16:28	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421105

**Project Number:** AL24-0474B-1

**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-08

**Date Collected:** 04/17/24 04:18

**Client ID:** 107

**Date Received:** 04/17/24

**Sample Location:** HS/MS B1ST

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/24/24 23:46	04/26/24 16:33	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Project Number: AL24-0474B-1

Lab Number: L2421105

Report Date: 04/28/24

## SAMPLE RESULTS

Lab ID: L2421105-09

Client ID: 108

Sample Location: HS/MS B1ST

Date Collected: 04/17/24 04:19

Date Received: 04/17/24

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0017		mg/l	0.0010	—	1	04/24/24 23:46	04/26/24 16:38	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421105

**Project Number:** AL24-0474B-1

**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-10

**Date Collected:** 04/17/24 04:20

**Client ID:** 109

**Date Received:** 04/17/24

**Sample Location:** HS/MS B1ST

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0035		mg/l	0.0010	—	1	04/24/24 23:46	04/26/24 16:42	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421105

**Project Number:** AL24-0474B-1

**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-11

**Date Collected:** 04/17/24 04:21

**Client ID:** 110

**Date Received:** 04/17/24

**Sample Location:** HS/MS B1ST

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 16:47	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-12  
**Client ID:** 111  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:22  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
<b>Total Metals - Mansfield Lab</b>											
Lead, Total	0.0012		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 16:52	EPA 3005A	3,200.8	NTB





Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421105

**Project Number:** AL24-0474B-1

**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-13

**Date Collected:** 04/17/24 04:22

**Client ID:** 112

**Date Received:** 04/17/24

**Sample Location:** HS/MS B1ST

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0047		mg/l	0.0010	—	1	04/24/24 23:46	04/26/24 16:56	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Project Number: AL24-0474B-1

Lab Number: L2421105

Report Date: 04/28/24

## SAMPLE RESULTS

Lab ID: L2421105-14

Client ID: 113

Sample Location: HS/MS B1ST

Date Collected: 04/17/24 04:23

Date Received: 04/17/24

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 17:01	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421105

**Project Number:** AL24-0474B-1

**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-15

**Date Collected:** 04/17/24 04:24

**Client ID:** 114

**Date Received:** 04/17/24

**Sample Location:** HS/MS B1ST

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0054		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 17:25	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421105

**Project Number:** AL24-0474B-1

**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-17

**Date Collected:** 04/17/24 04:26

**Client ID:** 116

**Date Received:** 04/17/24

**Sample Location:** HS/MS B1ST

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0047		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 17:29	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

Project Name: SANDY CREEK CS

Lab Number: L2421105

Project Number: AL24-0474B-1

Report Date: 04/28/24

**SAMPLE RESULTS**

Lab ID: L2421105-18

Date Collected: 04/17/24 04:27

Client ID: 117

Date Received: 04/17/24

Sample Location: HS/MS B1ST

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0041		mg/l	0.0010	—	1	04/24/24 23:46	04/26/24 17:34	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-19  
**Client ID:** 118  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:28  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0045		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 17:39	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-20  
**Client ID:** 120  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:29  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0011		mg/l	0.0010	—	1	04/24/24 23:46	04/26/24 17:43	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421105

Project Number: AL24-0474B-1

Report Date: 04/28/24

**SAMPLE RESULTS**

Lab ID: L2421105-21

Date Collected: 04/17/24 04:34

Client ID: 121

Date Received: 04/17/24

Sample Location: HS/MS B1ST

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
<b>Total Metals - Mansfield Lab</b>											
Lead, Total	0.0011		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 17:48	EPA 3005A	3,200.8	NTB





Serial\_No:04282417:09

Project Name: SANDY CREEK CS

Lab Number: L2421105

Project Number: AL24-0474B-1

Report Date: 04/28/24

**SAMPLE RESULTS**

Lab ID: L2421105-22

Date Collected: 04/17/24 04:34

Client ID: 122

Date Received: 04/17/24

Sample Location: HS/MS B1ST

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0016		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 18:12	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-23  
**Client ID:** 123  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:35  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 18:26	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421105

Project Number: AL24-0474B-1

Report Date: 04/28/24

## SAMPLE RESULTS

Lab ID: L2421105-24

Date Collected: 04/17/24 04:36

Client ID: 124

Date Received: 04/17/24

Sample Location: HS/MS B1ST

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 17:53	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Project Number: AL24-0474B-1

Lab Number: L2421105

Report Date: 04/28/24

## SAMPLE RESULTS

Lab ID: L2421105-25

Client ID: 125

Sample Location: HS/MS B1ST

Date Collected: 04/17/24 04:36

Date Received: 04/17/24

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 17:57	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Project Number: AL24-0474B-1

Lab Number: L2421105

Report Date: 04/28/24

## SAMPLE RESULTS

Lab ID: L2421105-26

Client ID: 126

Sample Location: HS/MS B1ST

Date Collected: 04/17/24 04:37

Date Received: 04/17/24

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 18:40	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-27  
**Client ID:** 127  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:38  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0016		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 18:44	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-28  
**Client ID:** 128  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:39  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0016		mg/l	0.0010	—	1	04/24/24 23:46	04/26/24 18:49	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS  
Project Number: AL24-0474B-1

Lab Number: L2421105  
Report Date: 04/28/24

SAMPLE RESULTS

Lab ID: L2421105-29  
Client ID: 129  
Sample Location: HS/MS B1ST

Date Collected: 04/17/24 04:40  
Date Received: 04/17/24  
Field Prep: Not Specified

Sample Depth:  
Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 18:54	EPA 3005A	3,200.8	NTB





**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-30  
**Client ID:** 130  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:41  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 19:08	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-31  
**Client ID:** 131  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:42  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 19:13	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-32  
**Client ID:** 132  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:42  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0090		mg/l	0.0010	—	1	04/24/24 23:46	04/26/24 19:17	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421105

Project Number: AL24-0474B-1

Report Date: 04/28/24

## SAMPLE RESULTS

Lab ID: L2421105-33

Date Collected: 04/17/24 04:43

Client ID: 133

Date Received: 04/17/24

Sample Location: HS/MS B1ST

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0025		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 19:22	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-34  
**Client ID:** 134  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:45  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.00290		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 19:27	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

Project Name: SANDY CREEK CS

Lab Number: L2421105

Project Number: AL24-0474B-1

Report Date: 04/28/24

**SAMPLE RESULTS**

Lab ID: L2421105-35

Date Collected: 04/17/24 04:46

Client ID: 135

Date Received: 04/17/24

Sample Location: HS/MS B1ST

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0018		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 19:32	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-36  
**Client ID:** 136  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:47  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0025		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 19:36	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-37  
**Client ID:** 137  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:47  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0052		mg/l	0.0010	—	1	04/24/24 23:46	04/26/24 19:41	EPA 3005A	3,200.8	NTB





Project Name: SANDY CREEK CS  
Project Number: AL24-0474B-1

Lab Number: L2421105  
Report Date: 04/28/24

SAMPLE RESULTS

Lab ID: L2421105-38  
Client ID: 138  
Sample Location: HS/MS B1ST

Date Collected: 04/17/24 04:52  
Date Received: 04/17/24  
Field Prep: Not Specified

Sample Depth:  
Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/24/24 23:46	04/26/24 19:46	EPA 3005A	3,200.8	NTB



Serial\_No:04282417:09

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-1

**Lab Number:** L2421105  
**Report Date:** 04/28/24

**SAMPLE RESULTS**

**Lab ID:** L2421105-39  
**Client ID:** 139  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:53  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/24/24 23:46	04/26/24 19:50	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Project Number: AL24-0474B-2

Lab Number: L2421111

Report Date: 04/25/24

**SAMPLE RESULTS**

Lab ID: L2421111-01

Client ID: 140

Sample Location: HS/MS B1ST

Date Collected: 04/17/24 04:54

Date Received: 04/17/24

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
-----------	--------	-----------	-------	----	-----	-----------------	---------------	---------------	-------------	-------------------	---------

**Total Metals - Mansfield Lab**

Lead, Total	ND		mg/l	0.0010	—	1	04/23/24 21:29	04/25/24 06:06	EPA 3005A	3,200.8	EJF
-------------	----	--	------	--------	---	---	----------------	----------------	-----------	---------	-----



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-2

**Lab Number:** L2421111  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421111-02  
**Client ID:** 141  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:54  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/23/24 21:29	04/25/24 06:17	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-2

**Lab Number:** L2421111  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421111-03  
**Client ID:** 142  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:55  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0030		mg/l	0.0010	—	1	04/23/24 21:29	04/25/24 05:59	EPA 3005A	3,200.8	EJF



Project Name: SANDY CREEK CS

Lab Number: L2421111

Project Number: AL24-0474B-2

Report Date: 04/25/24

## SAMPLE RESULTS

Lab ID: L2421111-04

Date Collected: 04/17/24 04:55

Client ID: 143

Date Received: 04/17/24

Sample Location: HS/MS B1ST

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0010		mg/l	0.0010	--	1	04/23/24 21:29	04/25/24 06:02	EPA 3005A	3,200.8	EJF



Project Name: SANDY CREEK CS

Project Number: AL24-0474B-2

Lab Number: L2421111

Report Date: 04/25/24

## SAMPLE RESULTS

Lab ID: L2421111-05

Client ID: 144

Sample Location: HS/MS B1ST

Date Collected: 04/17/24 04:57

Date Received: 04/17/24

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0025		mg/l	0.0010	--	1	04/23/24 21:29	04/25/24 06:39	EPA 3005A	3,200.8	EJF



Project Name: SANDY CREEK CS

Lab Number: L2421111

Project Number: AL24-0474B-2

Report Date: 04/25/24

**SAMPLE RESULTS**

Lab ID: L2421111-06

Date Collected: 04/17/24 04:58

Client ID: 145

Date Received: 04/17/24

Sample Location: HS/MS B1ST

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
<b>Total Metals - Mansfield Lab</b>											
Lead, Total	0.0012		mg/l	0.0010	--	1	04/23/24 21:29	04/25/24 06:43	EPA 3005A	3,200.8	EJF





**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-2

**Lab Number:** L2421111  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421111-07  
**Client ID:** 146  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:59  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0026		mg/l	0.0010	--	1	04/23/24 21:29	04/25/24 06:47	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-2

**Lab Number:** L2421111  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421111-08  
**Client ID:** 147  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 05:00  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0020		mg/l	0.0010	--	1	04/23/24 21:29	04/25/24 06:50	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-2

**Lab Number:** L2421111  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421111-09  
**Client ID:** 148  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 05:00  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0017		mg/l	0.0010	--	1	04/23/24 21:29	04/25/24 06:54	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-2

**Lab Number:** L2421111  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421111-10  
**Client ID:** 149  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 05:08  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 21:29	04/25/24 06:58	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-2

**Lab Number:** L2421111  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421111-11  
**Client ID:** 151  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 05:02  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0023		mg/l	0.0010	--	1	04/23/24 21:29	04/25/24 07:01	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-2

**Lab Number:** L2421111  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421111-12  
**Client ID:** 152  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 05:02  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0023		mg/l	0.0010	--	1	04/23/24 21:29	04/25/24 07:05	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-2

**Lab Number:** L2421111  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421111-13  
**Client ID:** 153  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 05:03  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
<b>Total Metals - Mansfield Lab</b>											
Lead, Total	0.0043		mg/l	0.0010	--	1	04/23/24 21:29	04/25/24 07:09	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-2

**Lab Number:** L2421111  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421111-14  
**Client ID:** 154  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:49  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
<b>Total Metals - Mansfield Lab</b>											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 21:29	04/25/24 07:12	EPA 3005A	3,200.8	EJF





Project Name: SANDY CREEK CS

Lab Number: L2421111

Project Number: AL24-0474B-2

Report Date: 04/25/24

## SAMPLE RESULTS

Lab ID: L2421111-15

Date Collected: 04/17/24 04:49

Client ID: 155

Date Received: 04/17/24

Sample Location: HS/MS B1ST

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 21:29	04/25/24 07:33	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-2

**Lab Number:** L2421111  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421111-16  
**Client ID:** 156  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 04:50  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/23/24 21:29	04/25/24 07:37	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-2

**Lab Number:** L2421111  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421111-17  
**Client ID:** 157  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 05:09  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0028		mg/l	0.0010	—	1	04/23/24 21:29	04/25/24 07:41	EPA 3005A	3,200.8	EJF



Project Name: SANDY CREEK CS

Lab Number: L2421111

Project Number: AL24-0474B-2

Report Date: 04/25/24

## SAMPLE RESULTS

Lab ID: L2421111-18

Date Collected: 04/17/24 05:05

Client ID: 158

Date Received: 04/17/24

Sample Location: HS/MS B1ST

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/23/24 21:29	04/25/24 07:44	EPA 3005A	3,200.8	EJF



Project Name: SANDY CREEK CS

Lab Number: L2421111

Project Number: AL24-0474B-2

Report Date: 04/25/24

## SAMPLE RESULTS

Lab ID: L2421111-19

Date Collected: 04/17/24 05:05

Client ID: 159

Date Received: 04/17/24

Sample Location: HS/MS B1ST

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/23/24 21:29	04/25/24 07:48	EPA 3005A	3,200.8	EJF



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474B-2

**Lab Number:** L2421111  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421111-20  
**Client ID:** 160  
**Sample Location:** HS/MS B1ST

**Date Collected:** 04/17/24 05:06  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 21:29	04/25/24 07:52	EPA 3005A	3,200.8	EJF



Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes			Sample Information:		
Client Address: <b>124 Salisbury Street</b>						DW= Drinking Water			<input type="checkbox"/> Drilled <input type="checkbox"/> Dug		
Sandy Creek, NY 13145						GW=Ground Water WW=Wastewater			<input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u>		
Phone #: <b>315-412-5326</b>		Cell #:	G = Grab C = Composite Matrix - see codes above Chlorine Residual			Preservative Codes			PLEASE NOTE:		
E-Mail address: <u>aridgew@scs.nyric.org</u>						1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl   3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid   7= NH <sub>4</sub> CL 8= Unpres.       9=			Reports for businesses will be forwarded to your DOH.		
Contact/Report to: <b>Andy Ridgeway</b>						List Preservative Code Below 1 2 3 4 5 6 7 8			NOTES TO LABORATORY Normal TAT <input checked="" type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.		
Sampler: client									ANALYSIS / TEST REQUESTED		
Date Collected	Time Collected	Sample Identification	G	DW							
4/18/2024	6:07	HS/ms B 2nd 200	G	DW				1			Y
?	6:08	201	G	DW				1			Y
	6:09	202	G	DW				1			Y
	6:10	203	G	DW				1			Y
	6:11	206	G	DW				1			Y
	6:12	207	G	DW				1			Y
	6:12	208	G	DW				1			Y
	6:13	209	G	DW				1			Y
	6:13	210	G	DW				1			Y
	6:14	211	G	DW				1			Y
Relinquished by:			Date	Time	Received by:			Date	Time	Rec'd Temp°	ICED?
Andrew Ridgeway			4/18/2024	1:10	Lauri Shultz			4/18/24	1310	8.4	<input checked="" type="radio"/> Yes <input type="radio"/> No
Lauri Shultz			4/18/24	1352	A. Hirsch			4/18/24	1352		
SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet YES NO											

# Chain of Custody

(315) 788-8388 www.converselabs.com

Page 2 of 4

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV			
Client Address: <b>124 Salisbury Street</b>						DW= Drinking Water						
Sandy Creek, NY 13145						GW=Ground Water WW=Wastewater						
Phone #: <b>315-412-5326</b> Cell #:			G = Grab C = Composite Matrix - see codes above Chlorine Residual			Preservative Codes			PLEASE NOTE: Reports for businesses will be forwarded to your DOH.  <b>NOTES TO LABORATORY</b> Normal TAT <input checked="" type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.			
E-Mail address: <u>aridgew@sccs.cnyric.org</u>						1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub>						
Contact/Report to: <b>Andy Ridgeway</b>						4= HNO <sub>3</sub> 5= NaOH						
Sampler: client						6= Asorbic Acid    7= NH <sub>4</sub> CL						
						8= Unpres.    9=						
						List Preservative Code Below						
						1 2 3 4 5 6 7 8						
Date Collected	Time Collected	Sample Identification	G	C								
4/18/2024	—	HS/MS B 2nd <del>212</del>	G	DW				1				Y
	6:15	213	G	DW				1				Y
	6:16	214	G	DW				1				Y
	6:16	215	G	DW				1				Y
	6:17	216	G	DW				1				Y
	6:17	217	G	DW				1				Y
	6:18	218	G	DW				1				Y
	6:18	219	G	DW				1				Y
	6:19	220	G	DW				1				Y
	6:20	221	G	DW				1				Y
Relinquished by:			Date	Time	Received by:			Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.
Andrew Ridgeway			4/18/2024	1:10	Laurie Stultz			4/18/24				SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet YES NO
Laurie Stultz			4/18/24	1352	A. Hirsch			4/18/24	1352	8.4		

Doc. # 357  
1/2/2024  
Rev. # 118

Amt. Due: \_\_\_\_\_ Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: Amf 4/18/24  
Transcriptural Rev.: \_\_\_\_\_  
Final Review: \_\_\_\_\_



Page 3 of 4

Doc. # 357  
1/2/2024  
Rev. # 118

**Amt. Due:**

**Amt. Paid:** \_\_\_\_\_

Initial Review: Conf 4/18/24  
 Transcriptual Rev.: \_\_\_\_\_  
 Final Review: \_\_\_\_\_

**Cash** \_\_\_\_\_ **Check#** \_\_\_\_\_ **CC** \_\_\_\_\_

# Chain of Custody

Page 4 of 4

Client Name: <b>Sandy Creek CS</b>		Client Project ID / PO# :		Matrix Codes		<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV									
Client Address: <b>124 Salisbury Street</b>				DW= Drinking Water											
Sandy Creek, NY 13145				GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil											
Phone #: <b>315-412-5326</b>	Cell #:	G = Grab C = Composite Matrix - see codes above Chlorine Residual	Preservative Codes		PLEASE NOTE: Reports for businesses will be forwarded to your DOH.  <b>NOTES TO LABORATORY</b> Normal TAT <input checked="" type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.										
E-Mail address: <u>aridgew@sccs.cnyric.org</u>			1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9= _____												
Contact/Report to: <b>Andy Ridgeway</b>			List Preservative Code Below		Subcontracted <input checked="" type="checkbox"/>		<b>ANALYSIS / TEST REQUESTED</b>		<b>SAMPLE ID # (lab use only)</b>						
Sampler: client			1   2   3   4   5   6   7   8												
Date Collected	Time Collected	Sample Identification	G	DW									Y	Lead	3783
			G	DW									Y	Lead	
			G	DW									Y	Lead	
4/18/2024	7:45	HS/MCB/st 115	G	DW									Y	Lead	3783
			G	DW									Y	Lead	
			G	DW									Y	Lead	
			G	DW									Y	Lead	
			G	DW									Y	Lead	
			G	DW									Y	Lead	
			G	DW									Y	Lead	
			G	DW									Y	Lead	
			G	DW									Y	Lead	
			G	DW									Y	Lead	
Relinquished by:			Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.				
Andrew Ridgeway			4/18/2024	1:10	Lamir Shultz		4/18/24	1310		<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>				
Lamir Shultz			4/18/24	1352	[Signature]		4/18/24	1352	8.4						

Doc. # 357  
 1/2/2024  
 Rev. # 118

Amt. Due: \_\_\_\_\_ Amt. Paid: \_\_\_\_\_  
 Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: Conf 4/18/24  
 Transcriptural Rev.: \_\_\_\_\_  
 Final Review: \_\_\_\_\_

Serial\_No:05032408:46

Project Name: SANDY CREEK CS

Lab Number: L2421736

Project Number: AL24-0490

Report Date: 05/03/24

### SAMPLE RESULTS

Lab ID: L2421736-01

Date Collected: 04/18/24 06:07

Client ID: 200

Date Received: 04/18/24

Sample Location: HS/MS B 2ND

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	05/01/24 00:16	05/02/24 10:54	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-02  
**Client ID:** 201  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:08  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	05/01/24 00:16	05/02/24 11:08	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421736

**Project Number:** AL24-0490

**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-03

**Date Collected:** 04/18/24 06:09

**Client ID:** 202

**Date Received:** 04/18/24

**Sample Location:** HS/MS B 2ND

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	05/01/24 00:16	05/02/24 12:43	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-04  
**Client ID:** 203  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:10  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	05/01/24 00:16	05/02/24 15:14	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-05  
**Client ID:** 206  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:11  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0094		mg/l	0.0010	--	1	05/01/24 00:16	05/02/24 15:18	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-06  
**Client ID:** 207  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:12  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0042		mg/l	0.0010	--	1	05/01/24 00:16	05/02/24 15:23	EPA 3005A	3,200.8	NTB





Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

# **SAMPLE RESULTS**

**Lab ID:** L2421736-07  
**Client ID:** 208  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:12  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0043		mg/l	0.0010	—	1	05/01/24 00:16	05/02/24 15:28	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-08  
**Client ID:** 209  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:13  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0028		mg/l	0.0010	--	1	05/01/24 00:16	05/02/24 15:32	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-09  
**Client ID:** 210  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:13  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0048		mg/l	0.0010	—	1	05/01/24 00:16	05/02/24 16:14	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

### SAMPLE RESULTS

**Lab ID:** L2421736-10  
**Client ID:** 211  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:14  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0043		mg/l	0.0010	--	1	05/01/24 00:16	05/02/24 16:19	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-11  
**Client ID:** 213  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:15  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0015		mg/l	0.0010	—	1	05/01/24 00:16	05/02/24 16:23	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421736

**Project Number:** AL24-0490

**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-12

**Date Collected:** 04/18/24 06:16

**Client ID:** 214

**Date Received:** 04/18/24

**Sample Location:** HS/MS B 2ND

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0029		mg/l	0.0010	--	1	05/01/24 00:16	05/02/24 16:28	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

### SAMPLE RESULTS

**Lab ID:** L2421736-13  
**Client ID:** 215  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:16  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0051		mg/l	0.0010	—	1	05/01/24 00:16	05/02/24 16:33	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-14  
**Client ID:** 216  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:17  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0051		mg/l	0.0010	--	1	05/01/24 00:16	05/02/24 16:37	EPA 3005A	3,200.8	NTB





**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-15  
**Client ID:** 217  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:17  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0049		mg/l	0.0010	--	1	05/01/24 00:16	05/02/24 16:42	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421736

**Project Number:** AL24-0490

**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-16

**Date Collected:** 04/18/24 06:18

**Client ID:** 218

**Date Received:** 04/18/24

**Sample Location:** HS/MS B 2ND

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0021		mg/l	0.0010	—	1	05/01/24 00:16	05/02/24 16:47	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-17  
**Client ID:** 219  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:18  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0044		mg/l	0.0010	--	1	05/01/24 00:16	05/02/24 16:51	EPA 3005A	3,200.8	NTB



Serial No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-18  
**Client ID:** 220  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:19  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0015		mg/l	0.0010	---	1	05/01/24 00:16	05/02/24 16:56	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-19  
**Client ID:** 221  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:20  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0289		mg/l	0.0010	-	1	05/01/24 00:16	05/02/24 17:12	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

Project Name: SANDY CREEK CS

Lab Number: L2421736

Project Number: AL24-0490

Report Date: 05/03/24

**SAMPLE RESULTS**

Lab ID: L2421736-20

Date Collected: 04/18/24 06:21

Client ID: 222

Date Received: 04/18/24

Sample Location: HS/MS B 2ND

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0026		mg/l	0.0010	--	1	05/01/24 00:16	05/02/24 17:17	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421736

Project Number: AL24-0490

Report Date: 05/03/24

## SAMPLE RESULTS

Lab ID: L2421736-21

Date Collected: 04/18/24 06:21

Client ID: 223

Date Received: 04/18/24

Sample Location: HS/MS B 2ND

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/30/24 23:58	05/01/24 22:00	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-22  
**Client ID:** 224  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:25  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/30/24 23:58	05/01/24 22:14	EPA 3005A	3.200.8	NTB





Serial\_No:05032408:46

Project Name: SANDY CREEK CS

Lab Number: L2421736

Project Number: AL24-0490

Report Date: 05/03/24

**SAMPLE RESULTS**

Lab ID: L2421736-23

Date Collected: 04/18/24 06:24

Client ID: 225

Date Received: 04/18/24

Sample Location: HS/MS B 2ND

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0020		mg/l	0.0010	--	1	04/30/24 23:58	05/01/24 22:28	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-24  
**Client ID:** 238  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 06:27  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0074		mg/l	0.0010	--	1	04/30/24 23:58	05/01/24 22:33	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-25  
**Client ID:** 115 HS/MS B1ST  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 07:45  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/30/24 23:58	05/02/24 17:21	EPA 3005A	3,200.8	NTB



Serial\_No:05032408:46

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0490

**Lab Number:** L2421736  
**Report Date:** 05/03/24

**SAMPLE RESULTS**

**Lab ID:** L2421736-26  
**Client ID:** GYMC 330  
**Sample Location:** HS/MS B 2ND

**Date Collected:** 04/18/24 07:45  
**Date Received:** 04/18/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/30/24 23:58	05/02/24 17:26	EPA 3005A	3,200.8	NTB





800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Project 17 To Samples

Page \_\_\_\_ of \_\_\_\_

Client Name: <b>Sandy Creek CS</b>		Client Project ID / PO# :		Matrix Codes DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil		Sample Information: <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV	
Client Address: <b>124 Salisbury Street</b>							
Sandy Creek, NY 13145							
Phone #: <b>315-412-5326</b>	Cell #:			Preservative Codes 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl 3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid 7= NH <sub>4</sub> CL 8= Unpres. 9=		PLEASE NOTE: Reports for businesses will be forwarded to your DOH.	
E-Mail address: <u>aridgew@scs.cnyric.org</u>						NOTES TO LABORATORY	
Contact/Report to: <b>Andy Ridgeway</b>						Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.	
Sampler: client							

Date Collected	Time Collected	Sample Identification	G = Grab C = Composite	Matrix - see codes above	Chlorine Residual	List Preservative Code Below	Subcontracted Y/N	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)		
1	2	3	4	5	6	7	8				
4/17/24	5:16	Gym C	300	G	DW			1	Y	Lead	3637
	5:16		301	G	DW			1	Y	Lead	
	5:17		302	G	DW			1	Y	Lead	
	5:18		303	G	DW			1	Y	Lead	
	5:19		304	G	DW			1	Y	Lead	
	5:20		305	G	DW			1	Y	Lead	
	5:21		306	G	DW			1	Y	Lead	
	5:21		307	G	DW			1	Y	Lead	
	5:22		308	G	DW			1	Y	Lead	
	5:23		309	G	DW			1	Y	Lead	

Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.
Andrew Ridgeway		4/17/2024	9:12	Laurie Sheltie		4/17/24	0912	16.4	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	
Laurie Sheltie		4/17/24	1100	KWBunny		4/17/24	1100			
SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet <div style="text-align: right;"><input checked="" type="checkbox"/> YES <input type="checkbox"/> NO</div>										

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Initial Review: KWBunny 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_



800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Page \_\_\_\_ of \_\_\_\_

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			<b>Matrix Codes</b> DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: __Municipal__ <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV			
Client Address: <b>124 Salisbury Street</b>			Phone #: <b>315-412-5326</b> Cell #: _____ E-Mail address: <b>aridge@scs.cnyric.org</b> Contact/Report to: <b>Andy Ridgeway</b> Sampler: client			<b>Preservative Codes</b> 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9= _____			PLEASE NOTE: Reports for businesses will be forwarded to your DOH.			
Sandy Creek, NY 13145						<b>List Preservative Code Below</b> 1 2 3 4 5 6 7 8			<b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.			
<b>Date Collected</b>	<b>Time Collected</b>	<b>Sample Identification</b>	<b>G = Grab C = Composite</b>	<b>Matrix - see codes above</b>	<b>Chlorine Residual</b>				<b>Subcontracted Y / N</b>	<b>ANALYSIS / TEST REQUESTED</b>	<b>SAMPLE ID # (lab use only)</b>	
4/17/24	5:24	Gym C 310	G	DW						Y	Lead	3637
	5:25	312	G	DW						Y	Lead	
	5:26	313	G	DW						Y	Lead	
	5:27	314	G	DW						Y	Lead	
	5:28	315	G	DW						Y	Lead	
	5:29	316	G	DW						Y	Lead	
	5:29	317	G	DW						Y	Lead	
	5:30	318	G	DW						Y	Lead	
	5:31	319	G	DW						Y	Lead	
	5:32	320	G	DW						Y	Lead	
<b>Relinquished by:</b>		<b>Date</b>	<b>Time</b>	<b>Received by:</b>		<b>Date</b>	<b>Time</b>	<b>Rec'd Temp°</b>	<b>ICED?</b>	<b>AUTHORIZED RECIPIENTS &amp; CONTACT INFO.</b>		
Andrew Ridgeway		4/17/2024	9:12	Lauri Shelton		4/17/24	0912	16.4	(Yes/No)	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet YES NO		
Lauri Shelton		4/17/24	1100	K Bohmy		4/17/24	1100					

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: KMB 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_



800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Page \_\_\_\_ of \_\_\_\_

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil			Sample Information: <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: __Municipal__ <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV						
Client Address: <b>124 Salisbury Street</b>									PLEASE NOTE: Reports for businesses will be forwarded to your DOH.						
Sandy Creek, NY 13145									NOTES TO LABORATORY Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.						
Phone #: <b>315-412-5326</b>		Cell #:		G = Grab C = Composite Matrix - see codes above Chlorine Residual		Preservative Codes 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl 3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid 7= NH <sub>4</sub> CL 8= Unpres. 9= _____			Subcontracted Y/N						
E-Mail address: <b>aridgew@scs.cnyric.org</b>						List Preservative Code Below									
Contact/Report to: <b>Andy Ridgeway</b>															
Sampler: client															
Date Collected	Time Collected	Sample Identification				1	2	3	4	5	6	7	8	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)
4/17/24	5:32	Gym C 321	G	DW					1					Lead	3637
	5:33	322	G	DW					1					Lead	
	5:34	323	G	DW					1					Lead	
	5:35	324	G	DW					1					Lead	
	5:36	325	G	DW					1					Lead	
	5:36	327	G	DW					1					Lead	
	5:38	328	G	DW					1					Lead	
	5:38	329	G	DW					1					Lead	
	5:40	330	G	DW					1					Lead	
	5:40	331	G	DW					1					Lead	
Relinquished by:			Date	Time	Received by:			Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.			
Andrew Ridgeway			4/17/2024	9:12	Laurie Shultz			4/17/24	09:12	16.4	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO			
Laurie Shultz			4/17/24	11:00	K Brownly			4/17/24	11:06						

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Initial Review: KMS 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_



800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Page \_\_\_\_ of \_\_\_\_

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV																																																																																																																																																																																																													
Client Address: <b>124 Salisbury Street</b>						DW= Drinking Water																																																																																																																																																																																																																
Sandy Creek, NY 13145						GW=Ground Water WW=Wastewater																																																																																																																																																																																																																
Phone #: <b>315-412-5326</b>		Cell #:	G = Grab C = Composite Matrix - see codes above Chlorine Residual			Preservative Codes			<b>PLEASE NOTE:</b> Reports for businesses will be forwarded to your DOH.  <b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.																																																																																																																																																																																																													
E-Mail address: <u>aridgew@scs.cnyric.org</u>						1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub>																																																																																																																																																																																																																
Contact/Report to: <b>Andy Ridgeway</b>						4= HNO <sub>3</sub> 5= NaOH																																																																																																																																																																																																																
Sampler: client						6= Asorbic Acid    7= NH <sub>4</sub> CL																																																																																																																																																																																																																
						8= Unpres.    9= _____																																																																																																																																																																																																																
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Date Collected</th> <th>Time Collected</th> <th>Sample Identification</th> <th>G</th> <th>C</th> <th>Matrix</th> <th>Chlorine Residual</th> <th>1</th> <th>2</th> <th>3</th> <th>4</th> <th>5</th> <th>6</th> <th>7</th> <th>8</th> <th>Subcontracted</th> <th>Y/N</th> <th>ANALYSIS / TEST REQUESTED</th> <th>SAMPLE ID # (lab use only)</th> </tr> </thead> <tbody> <tr> <td>4/17/24</td> <td>5:40</td> <td>Gym C 332</td> <td>G</td> <td></td> <td>DW</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Y</td> <td>Lead</td> <td rowspan="10" style="text-align: center; vertical-align: middle; font-size: 2em;">}</td> </tr> <tr> <td></td> <td>5:42</td> <td>333</td> <td>G</td> <td></td> <td>DW</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Y</td> <td>Lead</td> </tr> <tr> <td></td> <td>5:43</td> <td>334</td> <td>G</td> <td></td> <td>DW</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Y</td> <td>Lead</td> </tr> <tr> <td></td> <td>5:43</td> <td>335</td> <td>G</td> <td></td> <td>DW</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Y</td> <td>Lead</td> </tr> <tr> <td></td> <td>5:44</td> <td>336</td> <td>G</td> <td></td> <td>DW</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Y</td> <td>Lead</td> </tr> <tr> <td></td> <td>5:45</td> <td>337</td> <td>G</td> <td></td> <td>DW</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Y</td> <td>Lead</td> </tr> <tr> <td></td> <td>5:45</td> <td>338</td> <td>G</td> <td></td> <td>DW</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Y</td> <td>Lead</td> </tr> <tr> <td></td> <td>5:47</td> <td>339</td> <td>G</td> <td></td> <td>DW</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Y</td> <td>Lead</td> </tr> <tr> <td></td> <td>5:47</td> <td>340</td> <td>G</td> <td></td> <td>DW</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Y</td> <td>Lead</td> </tr> <tr> <td></td> <td>5:48</td> <td>341</td> <td>G</td> <td></td> <td>DW</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td>Y</td> <td>Lead</td> </tr> </tbody> </table>			Date Collected	Time Collected	Sample Identification	G	C	Matrix	Chlorine Residual	1	2	3	4	5	6	7	8	Subcontracted	Y/N	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)	4/17/24	5:40	Gym C 332	G		DW					1						Y	Lead	}		5:42	333	G		DW					1						Y	Lead		5:43	334	G		DW					1						Y	Lead		5:43	335	G		DW					1						Y	Lead		5:44	336	G		DW					1						Y	Lead		5:45	337	G		DW					1						Y	Lead		5:45	338	G		DW					1						Y	Lead		5:47	339	G		DW					1						Y	Lead		5:47	340	G		DW					1						Y	Lead		5:48	341	G		DW					1						Y	Lead												
Date Collected	Time Collected	Sample Identification	G	C	Matrix	Chlorine Residual	1	2	3	4	5	6	7	8	Subcontracted	Y/N	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)																																																																																																																																																																																																				
4/17/24	5:40	Gym C 332	G		DW					1						Y	Lead	}																																																																																																																																																																																																				
	5:42	333	G		DW					1						Y	Lead																																																																																																																																																																																																					
	5:43	334	G		DW					1						Y	Lead																																																																																																																																																																																																					
	5:43	335	G		DW					1						Y	Lead																																																																																																																																																																																																					
	5:44	336	G		DW					1						Y	Lead																																																																																																																																																																																																					
	5:45	337	G		DW					1						Y	Lead																																																																																																																																																																																																					
	5:45	338	G		DW					1						Y	Lead																																																																																																																																																																																																					
	5:47	339	G		DW					1						Y	Lead																																																																																																																																																																																																					
	5:47	340	G		DW					1						Y	Lead																																																																																																																																																																																																					
	5:48	341	G		DW					1						Y	Lead																																																																																																																																																																																																					
Relinquished by:			Date	Time	Received by:			Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.																																																																																																																																																																																																										
Andrew Ridgeway			4/17/2024	9:12	Laurin Shelton			4/17/24	0912	164	(Yes) / No																																																																																																																																																																																																											
Laurin Shelton			4/17/24	1100	K. Borman			4/17/24	1100																																																																																																																																																																																																													
											SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet <div style="display: flex; justify-content: space-between;"> <span>(YES)</span> <span>NO</span> </div>																																																																																																																																																																																																											

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Initial Review: KMRB 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_





800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Page \_\_\_\_ of \_\_\_\_

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: __Municipal__ <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV								
Client Address: <b>124 Salisbury Street</b>																	
Sandy Creek, NY 13145																	
Phone #: <b>315-412-5326</b>		Cell #:				Preservative Codes 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9=			PLEASE NOTE: Reports for businesses will be forwarded to your DOH.								
E-Mail address: <u>aridge@scs.cnyric.org</u>			G = Grab C = Composite Matrix - see codes above Chlorine Residual		List Preservative Code Below 1 2 3 4 5 6 7 8			<b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.									
Contact/Report to: <b>Andy Ridgeway</b>								Subcontracted Y/N			<b>ANALYSIS / TEST REQUESTED</b> <b>SAMPLE ID # (lab use only)</b>						
Sampler: client																	
Date Collected	Time Collected	Sample Identification	G	C		1	2	3	4	5	6	7	8				
4/17/24	5:56	Gym C 342	G	DW					1						Y	Lead	3637
	5:56	343	G	DW	AL-24-0474A-2								Y	Lead			
	5:57	344	G	DW				1						Y	Lead		
	5:54	345	G	DW				1						Y	Lead		
	5:55	346	G	DW				1						Y	Lead		
	5:53	347	G	DW				1						Y	Lead		
	5:52	348	G	DW				1						Y	Lead		
	5:50	349	G	DW				1						Y	Lead		
		<del>350</del>	G	DW				1						Y	Lead		
	5:51	351	G	DW				1						Y	Lead		
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.							
Andrew Ridgeway		4/17/2024	9:12	Laurie Shultz		4/17/24	0912	164	YES/ No	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet							
Laurie Shultz		4/17/24	1100	L. Bonny		4/17/24	1100										
										YES NO							

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: KMB 4/17/24

Transcriptual Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_

Serial\_No:04242409:53

Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-01

Date Collected: 04/17/24 05:16

Client ID: 300

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0015		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 16:28	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421097

**Project Number:** AL24-0474A-1

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-02

**Date Collected:** 04/17/24 05:16

**Client ID:** 301

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0014		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 16:39	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421097

**Project Number:** AL24-0474A-1

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-03

**Date Collected:** 04/17/24 05:17

**Client ID:** 302

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0016		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 16:21	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-04  
**Client ID:** 303  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:18  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0013		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 16:24	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-05  
**Client ID:** 304  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:19  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 16:58	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-06

Date Collected: 04/17/24 05:20

Client ID: 305

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0012		mg/l	0.0010	—	1	04/22/24 18:34	04/23/24 17:02	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-07  
**Client ID:** 306  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:21  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 18:34	04/23/24 17:05	EPA 3005A	3,200.8	NTB





Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-08  
**Client ID:** 307  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:21  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0014		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 17:09	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-09  
**Client ID:** 308  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:22  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 17:13	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-10  
**Client ID:** 309  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:23  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0011		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 17:16	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-11  
**Client ID:** 310  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:24  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 17:20	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421097

**Project Number:** AL24-0474A-1

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-12

**Date Collected:** 04/17/24 05:25

**Client ID:** 312

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 17:24	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-13  
**Client ID:** 313  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:26  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 18:34	04/23/24 17:27	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-14  
**Client ID:** 314  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:27  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 18:34	04/23/24 17:31	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421097

**Project Number:** AL24-0474A-1

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-15

**Date Collected:** 04/17/24 05:28

**Client ID:** 315

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 17:54	EPA 3005A	3,200.8	NTB





Serial\_No:04242409:53

Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-16

Date Collected: 04/17/24 05:29

Client ID: 316

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 17:58	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421097

**Project Number:** AL24-0474A-1

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-17

**Date Collected:** 04/17/24 05:29

**Client ID:** 317

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 18:01	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-18  
**Client ID:** 318  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:30  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 18:05	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421097

**Project Number:** AL24-0474A-1

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-19

**Date Collected:** 04/17/24 05:31

**Client ID:** 319

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0030		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 18:09	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

# **SAMPLE RESULTS**

**Lab ID:** L2421097-20  
**Client ID:** 320  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:32  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0050		mg/l	0.0010	—	1	04/22/24 18:34	04/23/24 18:13	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-21

Date Collected: 04/17/24 05:32

Client ID: 321

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0017		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 18:52	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421097

**Project Number:** AL24-0474A-1

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-22

**Date Collected:** 04/17/24 05:33

**Client ID:** 322

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0025		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:03	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-23

Date Collected: 04/17/24 05:34

Client ID: 323

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 18:16	EPA 3005A	3,200.8	NTB





Serial\_No:04242409:53

Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-24

Date Collected: 04/17/24 05:35

Client ID: 324

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 18:20	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-25

Date Collected: 04/17/24 05:36

Client ID: 325

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 18:37	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-26

Date Collected: 04/17/24 05:36

Client ID: 327

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 18:40	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-27  
**Client ID:** 328  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:38  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0072		mg/l	0.0010	—	1	04/22/24 16:39	04/23/24 18:44	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-28

Date Collected: 04/17/24 05:38

Client ID: 329

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0028		mg/l	0.0010	—	1	04/22/24 16:39	04/23/24 18:48	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-29

Date Collected: 04/17/24 05:40

Client ID: 331

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0046		mg/l	0.0010	—	1	04/22/24 16:39	04/23/24 19:21	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-30  
**Client ID:** 332  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:40  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.001		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:25	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421097

**Project Number:** AL24-0474A-1

**Report Date:** 04/24/24

### SAMPLE RESULTS

**Lab ID:** L2421097-31

**Date Collected:** 04/17/24 05:42

**Client ID:** 333

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0028		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:29	EPA 3005A	3,200.8	NTB





Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

# **SAMPLE RESULTS**

**Lab ID:** L2421097-32  
**Client ID:** 334  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:43  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0018		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:32	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421097

**Project Number:** AL24-0474A-1

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-33

**Date Collected:** 04/17/24 05:43

**Client ID:** 335

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0027		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:36	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421097

**Project Number:** AL24-0474A-1

**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-34

**Date Collected:** 04/17/24 05:44

**Client ID:** 336

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:40	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-35

Date Collected: 04/17/24 05:45

Client ID: 337

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 16:39	04/23/24 19:44	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

### SAMPLE RESULTS

**Lab ID:** L2421097-36  
**Client ID:** 338  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:45  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0023		mg/l	0.0010	—	1	04/22/24 16:39	04/23/24 19:47	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-37

Date Collected: 04/17/24 05:47

Client ID: 339

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:51	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421097

**Project Number:** AL24-0474A-1

**Report Date:** 04/24/24

# **SAMPLE RESULTS**

**Lab ID:** L2421097-38

**Date Collected:** 04/17/24 05:47

**Client ID:** 340

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:55	EPA 3005A	3,200.8	NTB



Serial\_No:04242409:53

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-1

**Lab Number:** L2421097  
**Report Date:** 04/24/24

**SAMPLE RESULTS**

**Lab ID:** L2421097-39  
**Client ID:** 341  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:48  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 20:13	EPA 3005A	3,200.8	NTB





Serial\_No:04242409:53

Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-40

Date Collected: 04/17/24 05:56

Client ID: 342

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 20:17	EPA 3005A	3,200.8	NTB



Serial\_No:04252414:25

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-2

**Lab Number:** L2421103  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421103-01  
**Client ID:** 343  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:56  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/23/24 11:28	04/25/24 07:55	EPA 3005A	3,200.8	EJF



Serial\_No:04252414:25

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421103

**Project Number:** AL24-0474A-2

**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421103-02

**Date Collected:** 04/17/24 05:57

**Client ID:** 344

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
<b>Total Metals - Mansfield Lab</b>											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 11:28	04/25/24 07:59	EPA 3005A	3,200.8	EJF



Serial\_No:04252414:25

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-2

**Lab Number:** L2421103  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421103-03  
**Client ID:** 345  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:54  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 11:28	04/25/24 08:16	EPA 3005A	3,200.8	EJF



Serial\_No:04252414:25

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421103

**Project Number:** AL24-0474A-2

**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421103-04

**Date Collected:** 04/17/24 05:55

**Client ID:** 346

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/23/24 11:28	04/25/24 08:20	EPA 3005A	3,200.8	EJF



Serial\_No:04252414:25

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-2

**Lab Number:** L2421103  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421103-05  
**Client ID:** 347  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:53  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0015		mg/l	0.0010	--	1	04/23/24 11:28	04/25/24 08:23	EPA 3005A	3,200.8	EJF



Serial\_No:04252414:25

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-2

**Lab Number:** L2421103  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421103-06  
**Client ID:** 348  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:52  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/23/24 11:28	04/25/24 08:27	EPA 3005A	3,200.8	EJF



Serial\_No:04252414:25

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421103

**Project Number:** AL24-0474A-2

**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421103-07

**Date Collected:** 04/17/24 05:50

**Client ID:** 349

**Date Received:** 04/17/24

**Sample Location:** GYM-C

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 11:28	04/25/24 08:31	EPA 3005A	3,200.8	EJF





Serial\_No:04252414:25

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-2

**Lab Number:** L2421103  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421103-08  
**Client ID:** 351  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:51  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 11:28	04/25/24 08:34	EPA 3005A	3,200.8	EJF





800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Project 40 SamplesPage 1 of 4

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV								
Client Address: <b>124 Salisbury Street</b>						DW= Drinking Water											
Sandy Creek, NY 13145						GW=Ground Water WW=Wastewater											
Phone #: <b>315-412-5326</b>		Cell #:	G = Grab C = Composite Matrix - see codes above Chlorine Residual			Preservative Codes			PLEASE NOTE:								
E-Mail address: <u>aridgew@scs.cnyric.org</u>						1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9=			Reports for businesses will be forwarded to your DOH. <b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.								
Contact/Report to: <b>Andy Ridgeway</b>						List Preservative Code Below 1 2 3 4 5 6 7 8			ANALYSIS / TEST REQUESTED SAMPLE ID # (lab use only)								
Sampler: client																	
Date Collected	Time Collected	Sample Identification	G	C	Matrix	Chlorine Residual	1	2	3	4	5	6	7	8	Subcontracted Y/N	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)
4/17/24	7:26	HS/MSBZnd 204	G		DW					1					Y	Lead	3627 (S)
	7:26	205	G		DW					1					Y	Lead	3637
	7:35	226	G		DW					1					Y	Lead	
	7:35	227	G		DW					1					Y	Lead	
	7:27	228	G		DW					1					Y	Lead	
	7:28	229	G		DW					1					Y	Lead	
	7:29	230	G		DW					1					Y	Lead	
	7:29	231	G		DW					1					Y	Lead	
	7:30	232	G		DW					1					Y	Lead	
	7:30	233	G		DW					1					Y	Lead	
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.							
Andrew Ridgeway		4/17/2024	9:12	Laurie Sultz		4/17/24	0912	16.4	<input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS "If no, see attached sheet" YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>							
Laurie Sultz		4/17/24	1100	K Brumby		4/17/24	1100										

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: KMS 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_



## Chain of Custody

Page 2 of 4

Client Name: <b>Sandy Creek CS</b>		Client Project ID / PO# :		Matrix Codes DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil		Sample Information: <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV	
Client Address: <b>124 Salisbury Street</b>							
Sandy Creek, NY 13145							
Phone #: <b>315-412-5326</b>	Cell #:			Preservative Codes 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl 3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid 7= NH <sub>4</sub> CL 8= Unpres. 9=		PLEASE NOTE: Reports for businesses will be forwarded to your DOH.	
E-Mail address: <u>aridgew@scs.cnyric.org</u>						NOTES TO LABORATORY	
Contact/Report to: <b>Andy Ridgeway</b>						Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.	
Sampler: client							

Date Collected	Time Collected	Sample Identification	G = Grab C = Composite	Matrix - see codes above	Chlorine Residual	1	2	3	4	5	6	7	8	Subcontracted Y/N	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)
4/17/24	7:31	HS/MSB 2nd 234	G	DW					1					Y	Lead	3627 (45)
	7:31	235	G	DW					1					Y	Lead	3637
	7:32	236	G	DW					1					Y	Lead	
	7:33	237	G	DW					1					Y	Lead	
	7:21	239	G	DW					1					Y	Lead	
	7:21	240	G	DW					1					Y	Lead	
	7:22	241	G	DW					1					Y	Lead	
	7:23	242	G	DW					1					Y	Lead	
	7:24	243	G	DW					1					Y	Lead	
	7:16	244	G	DW					1					Y	Lead	

Relinquished by:	Date	Time	Received by:	Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.
Andrew Ridgeway	4/17/2024	9:12	Lauri Shultz	4/17/24	0912	16.4	<input checked="" type="radio"/> Yes <input type="radio"/> No	
Lauri Shultz	4/17/24	1100	K. Brunley	4/17/24	1100			
							SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet	
							YES NO	

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: KMB 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_



800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Page 3 of 4

Client Name: <b>Sandy Creek CS</b>		Client Project ID / PO# :		Matrix Codes DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil		Sample Information: <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV	
Client Address: <b>124 Salisbury Street</b>							
Sandy Creek, NY 13145							
Phone #: <b>315-412-5326</b>	Cell #:			Preservative Codes 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl 3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid 7= NH <sub>4</sub> CL 8= Unpres. 9=		PLEASE NOTE: Reports for businesses will be forwarded to your DOH.	
E-Mail address: <u>aridge@scs.nyric.org</u>						NOTES TO LABORATORY	
Contact/Report to: <b>Andy Ridgeway</b>						Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.	
Sampler: client							

Date Collected	Time Collected	Sample Identification	G = Grab C = Composite	Matrix - see codes above	Chlorine Residual	List Preservative Code Below	1	2	3	4	5	6	7	8	Subcontracted Y/N	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)
4/17/24	7:16	HS/MSB 2nd 245	G	DW						1					Y	Lead	3627 <sup>CS</sup>
	7:17	246	G	DW						1					Y	Lead	3637
	7:17	247	G	DW						1					Y	Lead	
	7:18	248	G	DW						1					Y	Lead	
	7:19	249	G	DW						1					Y	Lead	
	7:20	250	G	DW						1					Y	Lead	
	7:10	251	G	DW						1					Y	Lead	
	7:05	252	G	DW						1					Y	Lead	
	7:06	253	G	DW						1					Y	Lead	
	7:06	254	G	DW						1					Y	Lead	

Relinquished by:	Date	Time	Received by:	Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.
Andy Ridgeway	4/17/2024	9:12	Lauri Shultz	4/17/24	0912	16.4	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Lauri Shultz	4/17/24	1100	K. Barnes	4/17/24	1100			
							SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet	
							<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: KMB 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_



800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

## Chain of Custody

Page 4 of 4

Client Name: <b>Sandy Creek CS</b>		Client Project ID / PO# :		Matrix Codes DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil		Sample Information: <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV	
Client Address: <b>124 Salisbury Street</b>							
Sandy Creek, NY 13145							
Phone #: <b>315-412-5326</b>	Cell #:			Preservative Codes 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl 3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid 7= NH <sub>4</sub> CL 8= Unpres. 9=		PLEASE NOTE: Reports for businesses will be forwarded to your DOH.	
E-Mail address: <u>aridgew@scs.cnyric.org</u>						NOTES TO LABORATORY Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.	
Contact/Report to: <b>Andy Ridgeway</b>							
Sampler: client							

Date Collected	Time Collected	Sample Identification	G = Grab C = Composite	Matrix - see codes above	Chlorine Residual	1	2	3	4	5	6	7	8	Subcontracted Y/N	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)
4/17/24	7:07	HS/MSB 2nd 255	G	DW					1					Y	Lead	}
	7:07	256	G	DW					1					Y	Lead	
	7:08	257	G	DW					1					Y	Lead	
	7:12	258	G	DW					1					Y	Lead	
	7:12	259	G	DW					1					Y	Lead	
	7:13	260	G	DW					1					Y	Lead	
	7:14	261	G	DW					1					Y	Lead	
	7:14	262	G	DW					1					Y	Lead	
	7:15	263	G	DW					1					Y	Lead	
	7:11	264	G	DW					1					Y	Lead	

Relinquished by:	Date	Time	Received by:	Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.
Andy Ridgeway	4/17/2024	9:12	Lauri Stulta	4/17/24	0912	16.4	<input checked="" type="radio"/> Yes <input type="radio"/> No	
Lauri Stulta	4/17/24	1100	K. Bunney	4/17/24	1100			
							SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet	
							YES NO	

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

 Initial Review: KMB 4/17/24  
 Transcriptural Rev.: \_\_\_\_\_  
 Final Review: \_\_\_\_\_

Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

### SAMPLE RESULTS

**Lab ID:** L2421117-01  
**Client ID:** 204  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:26  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 18:11	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

Project Name: SANDY CREEK CS

Lab Number: L2421117

Project Number: AL24-0474C

Report Date: 04/29/24

**SAMPLE RESULTS**

Lab ID: L2421117-02

Date Collected: 04/17/24 07:26

Client ID: 205

Date Received: 04/17/24

Sample Location: HS/MS B2ND

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 18:50	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-03  
**Client ID:** 226  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:35  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0023		mg/l	0.0010	—	1	04/25/24 21:03	04/28/24 18:25	EPA 3005A	3,200.8	WKP





Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421117

**Project Number:** AL24-0474C

**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-04

**Date Collected:** 04/17/24 07:35

**Client ID:** 227

**Date Received:** 04/17/24

**Sample Location:** HS/MS B2ND

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0024		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 19:03	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-05  
**Client ID:** 228  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:27  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 19:08	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-06  
**Client ID:** 229  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:28  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0012		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 19:12	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

### SAMPLE RESULTS

**Lab ID:** L2421117-07  
**Client ID:** 230  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:29  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 19:17	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-08  
**Client ID:** 231  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:29  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/25/24 21:03	04/28/24 19:22	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS

**Lab Number:** L2421117

**Project Number:** AL24-0474C

**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-09

**Date Collected:** 04/17/24 07:30

**Client ID:** 232

**Date Received:** 04/17/24

**Sample Location:** HS/MS B2ND

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 19:28	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS

**Project Number:** AL24-0474C

**Lab Number:** L2421117

**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-10

**Client ID:** 233

**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:30

**Date Received:** 04/17/24

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 19:40	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

Project Name: SANDY CREEK CS

Project Number: AL24-0474C

Lab Number: L2421117

Report Date: 04/29/24

### SAMPLE RESULTS

Lab ID: L2421117-11

Client ID: 234 Rm 2907 sink A

Sample Location: HS/MS B2ND

Date Collected: 04/17/24 07:31

Date Received: 04/17/24

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0316		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 19:44	EPA 3005A	3,200.8	WKP





**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-12  
**Client ID:** 235  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:31  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0095		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 19:49	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

# **SAMPLE RESULTS**

**Lab ID:** L2421117-13  
**Client ID:** 236  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:32  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0030		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 19:54	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-14  
**Client ID:** 237  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:33  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0075		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 19:58	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

Project Name: SANDY CREEK CS  
Project Number: AL24-0474C

Lab Number: L2421117  
Report Date: 04/29/24

**SAMPLE RESULTS**

Lab ID: L2421117-15  
Client ID: 239 Room 2514 sink-  
Sample Location: HS/MS B2ND

Date Collected: 04/17/24 07:21  
Date Received: 04/17/24  
Field Prep: Not Specified

Sample Depth:  
Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0388		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 20:03	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

Project Name: SANDY CREEK CS

Lab Number: L2421117

Project Number: AL24-0474C

Report Date: 04/29/24

**SAMPLE RESULTS**

Lab ID: L2421117-16

Date Collected: 04/17/24 07:21

Client ID: 240

Date Received: 04/17/24

Sample Location: HS/MS B2ND

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0078		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 20:07	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-17  
**Client ID:** 241 Room 2514 Sink C  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:22  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0107		mg/l	0.0010	—	1	04/25/24 21:03	04/28/24 20:12	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-18  
**Client ID:** 242  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:23  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0087		mg/l	0.0010	—	1	04/25/24 21:03	04/28/24 20:16	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-19  
**Client ID:** 243  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:24  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0027		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 20:21	EPA 3005A	3,200.8	WKP





**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-20  
**Client ID:** 244  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:16  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0090		mg/l	0.0010	--	1	04/25/24 21:03	04/28/24 21:11	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-21  
**Client ID:** 245  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:16  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 20:44	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-22  
**Client ID:** 246  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:17  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0108		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 20:58	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-23  
**Client ID:** 247  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:17  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0082		mg/l	0.0010	—	1	04/25/24 17:22	04/28/24 21:16	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-24  
**Client ID:** 248  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:18  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0103		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 21:29	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-25  
**Client ID:** 249  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:19  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0040		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 21:34	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-26  
**Client ID:** 250  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:20  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0036		mg/l	0.0010	—	1	04/25/24 17:22	04/28/24 21:39	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-27

**Client ID:** 251 *Room 2510 sink A*

**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:10

**Date Received:** 04/17/24

**Field Prep:** Not Specified

**Sample Depth:**

**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.2220		mg/l	0.0100	--	10	04/25/24 17:22	04/29/24 09:18	EPA 3005A	3,200.8	NTB





**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-28  
**Client ID:** 252  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:05  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0037		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 21:48	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-29  
**Client ID:** 253  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:06  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0039		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 21:52	EPA 3005A	3,200.8	WKP



Project Name: SANDY CREEK CS

Lab Number: L2421117

Project Number: AL24-0474C

Report Date: 04/29/24

## SAMPLE RESULTS

Lab ID: L2421117-30

Date Collected: 04/17/24 07:06

Client ID: 254

Date Received: 04/17/24

Sample Location: HS/MS B2ND

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 21:57	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-31  
**Client ID:** 255  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:07  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0036		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 22:01	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-32  
**Client ID:** 256  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:07  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0083		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 22:06	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-33  
**Client ID:** 257  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:08  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0018		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 22:10	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-34  
**Client ID:** 258  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:12  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0082		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 22:24	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-35  
**Client ID:** 259  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:12  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0084		mg/l	0.0010	—	1	04/25/24 17:22	04/28/24 22:29	EPA 3005A	3,200.8	WKP





**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-36  
**Client ID:** 260  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:13  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0014		mg/l	0.0010	—	1	04/25/24 17:22	04/28/24 22:33	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-37  
**Client ID:** 261  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:14  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0042		mg/l	0.0010	—	1	04/25/24 17:22	04/28/24 22:38	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-38  
**Client ID:** 262  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:14  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
<b>Total Metals - Mansfield Lab</b>											
Lead, Total	0.0043		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 22:42	EPA 3005A	3,200.8	WKP



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-39  
**Client ID:** 263  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:15  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 22:47	EPA 3005A	3,200.8	WKP



Serial\_No:04292414:47

**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474C

**Lab Number:** L2421117  
**Report Date:** 04/29/24

**SAMPLE RESULTS**

**Lab ID:** L2421117-40  
**Client ID:** 264  
**Sample Location:** HS/MS B2ND

**Date Collected:** 04/17/24 07:11  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/25/24 17:22	04/28/24 22:52	EPA 3005A	3,200.8	WKP





CONVERSE LABORATORIES, INC.  
800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

# Chain of Custody

Project (A) - 48 Samples

Page \_\_\_\_ of \_\_\_\_

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			<b>Matrix Codes</b> DW= Drinking Water GW=Ground Water WW=Wastewater SL=Sludge SW=Surface Water SO=Soil			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: __Municipal__ <input type="checkbox"/> Chlorinated <input type="checkbox"/> UV							
Client Address: <b>124 Salisbury Street</b>																
Sandy Creek, NY 13145																
Phone #: <b>315-412-5326</b>		Cell #:				<b>Preservative Codes</b> 1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid    7= NH <sub>4</sub> CL 8= Unpres.    9=			PLEASE NOTE: Reports for businesses will be forwarded to your DOH.							
E-Mail address: <b>aridgew@sccs.cnyric.org</b>			G = Grab C = Composite Matrix - see codes above Chlorine Residual		Subcontracted Y/N		<b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.									
Contact/Report to: <b>Andy Ridgeway</b>																
Sampler: client																
Date Collected	Time Collected	Sample Identification	G	C	DW	1	2	3	4	5	6	7	8	ANALYSIS / TEST REQUESTED	SAMPLE ID # (lab use only)	
4/17/24	5:16	Gym C 300	G		DW				1					Y	Lead	3637
	5:16		G		DW				1					Y	Lead	
	5:17		G		DW				1					Y	Lead	
	5:18		G		DW				1					Y	Lead	
	5:19		G		DW				1					Y	Lead	
	5:20		G		DW				1					Y	Lead	
	5:21		G		DW				1					Y	Lead	
	5:21		G		DW				1					Y	Lead	
	5:22		G		DW				1					Y	Lead	
	5:23		G		DW				1					Y	Lead	
Relinquished by:		Date	Time	Received by:		Date	Time	Rec'd Temp°	ICED?	AUTHORIZED RECIPIENTS & CONTACT INFO.						
Andrew Ridgeway		4/17/2024	9:12	Laurie Shelton		4/17/24	0912	16.4	Yes/No	SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO						
Laurie Shelton		4/17/24	1100	KWBunny		4/17/24	1100									

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: KWBunny 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_



## Page \_\_\_\_ of \_\_\_\_

**Cash** \_\_\_\_\_ **Check#** \_\_\_\_\_ **CC** \_\_\_\_\_

## Chain of Custody

Page \_\_\_\_ of \_\_\_\_

[illegible]

Doc. # 357

1/2/2024

Rev. # 118

**Amt. Due:**

**Amt. Paid:** \_\_\_\_\_

Initial Review: KMB 4/17/20

Transcriptual Rev.: \_\_\_\_\_

**Final Review:**

Cash	Check#	CC
------	--------	----





CONVERSE LABORATORIES, INC.

800 Starbuck Ave., Suite B101, Watertown, NY 13601

(315) 788-8388 www.converselabs.com

# Chain of Custody

Page \_\_\_\_ of \_\_\_\_

Client Name: <b>Sandy Creek CS</b>			Client Project ID / PO# :			Matrix Codes			<b>Sample Information:</b> <input type="checkbox"/> Drilled <input type="checkbox"/> Dug <input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: <u>Municipal</u> <input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV																	
Client Address: <b>124 Salisbury Street</b>						DW= Drinking Water																				
Sandy Creek, NY 13145						GW=Ground Water WW=Wastewater																				
Phone #: <b>315-412-5326</b> Cell #:			G = Grab C = Composite Matrix - see codes above Chlorine Residual			Preservative Codes			PLEASE NOTE:																	
E-Mail address: <u>aridge@scs.cnyric.org</u>						1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl    3= H <sub>2</sub> SO <sub>4</sub>			<b>NOTES TO LABORATORY</b> Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.																	
Contact/Report to: <b>Andy Ridgeway</b>						4= HNO <sub>3</sub> 5= NaOH																				
Sampler: client						6= Asorbic Acid    7= NH <sub>4</sub> CL																				
			8= Unpres.    9= _____			Subcontracted Y/N			ANALYSIS / TEST REQUESTED																	
Date Collected			Time Collected			Sample Identification			List Preservative Code Below			SAMPLE ID # (lab use only)														
1			5:40			GYM C 332			1			Y														
1			5:42			333			1			Y														
1			5:43			334			1			Y														
1			5:43			335			1			Y														
1			5:44			336			1			Y														
1			5:45			337			1			Y														
1			5:45			338			1			Y														
1			5:47			339			1			Y														
1			5:47			340			1			Y														
1			5:48			341			1			Y														
Relinquished by:			Date			Time			Received by:			Date			Time			Rec'd Temp°			ICED?			AUTHORIZED RECIPIENTS & CONTACT INFO.		
Andrew Ridgeway			4/17/2024			9:12			Laurie Shelton			4/17/24			0912			164			Yes/No			SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		
Laurie Shelton			4/17/24			1100			K. Burners			4/17/24			1100											

Doc. # 357

1/2/2024

Rev. # 118

Amt. Due: \_\_\_\_\_

Amt. Paid: \_\_\_\_\_

Cash \_\_\_\_\_ Check# \_\_\_\_\_ CC \_\_\_\_\_

Initial Review: KMRB 4/17/24

Transcriptural Rev.: \_\_\_\_\_

Final Review: \_\_\_\_\_

## Chain of Custody

Page \_\_\_\_ of \_\_\_\_

Client Name: <b>Sandy Creek CS</b>		Client Project ID / PO#:		Matrix Codes		Sample Information:											
Client Address: <b>124 Salisbury Street</b>				DW= Drinking Water		<input type="checkbox"/> Drilled <input type="checkbox"/> Dug											
<b>Sandy Creek, NY 13145</b>				GW=Ground Water WW=Wastewater		<input checked="" type="checkbox"/> Finished <input type="checkbox"/> Raw <input type="checkbox"/> Other: __Municipal__											
Phone #: <b>315-412-5326</b>		Cell #:		SL=Sludge SW=Surface Water SO=Soil		<input checked="" type="checkbox"/> Chlorinated <input type="checkbox"/> UV											
E-Mail address: <b>aridgew@sccs.cnyric.org</b>		G = Grab C = Composite Matrix - see codes above Chlorine Residual		Preservative Codes		PLEASE NOTE: Reports for businesses will be forwarded to your DOH.											
Contact/Report to: <b>Andy Ridgeway</b>				1= Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> 2= HCl 3= H <sub>2</sub> SO <sub>4</sub> 4= HNO <sub>3</sub> 5= NaOH 6= Asorbic Acid 7= NH <sub>4</sub> CL 8= Unpres. 9=		NOTES TO LABORATORY											
Sampler: client				List Preservative Code Below		Normal TAT <input type="checkbox"/> Rush TAT <input type="checkbox"/> Date Needed: _____ a.m. / p.m.											
Date Collected		Time Collected		Sample Identification		ANALYSIS / TEST REQUESTED		SAMPLE ID # (lab use only)									
4/17/24		5:56		Gym C 342		G DW		Y Lead 3637									
		5:56		343		G DW		Y Lead									
		5:57		344		G DW		Y Lead									
		5:54		345		G DW		Y Lead									
		5:55		346		G DW		Y Lead									
		5:53		347		G DW		Y Lead									
		5:52		348		G DW		Y Lead									
		5:50		349		G DW		Y Lead									
		<del>5:50</del>		<del>350</del>		G DW		Y Lead									
		5:51		351		G DW		Y Lead									
Relinquished by:		Date		Time		Received by:		Date		Time		Rec'd Temp°		ICED?		AUTHORIZED RECIPIENTS & CONTACT INFO.	
Andrew Ridgeway		4/17/2024		9:12		Laurie Sheltor		4/17/24		0912		16.4		(Yes/ No)		SAMPLE(S) AS RECEIVED CONFORM TO NELAC STANDARDS *If no, see attached sheet <div>(YES) NO</div>	
Laurie Sheltor		4/17/24		1100		K. Brumby		4/17/24		1100							

Doc. # 357

1/2/2024

Rev. # 118

**Amt. Due:**

**Amt. Paid:**

Initial Review: KHR 4/17/24

Transcriptual Rev.: \_\_\_\_\_

**Final Review:** \_\_\_\_\_

Cash	Check#	CC
------	--------	----

Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-01

Date Collected: 04/17/24 05:16

Client ID: 300

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0015		mg/l	0.0010	—	1	04/22/24 18:34	04/23/24 16:28	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-02

Date Collected: 04/17/24 05:16

Client ID: 301

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0014		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 16:39	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-03

Date Collected: 04/17/24 05:17

Client ID: 302

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0016		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 16:21	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-04

Date Collected: 04/17/24 05:18

Client ID: 303

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0013		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 16:24	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-05

Date Collected: 04/17/24 05:19

Client ID: 304

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 16:58	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-06

Date Collected: 04/17/24 05:20

Client ID: 305

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0012		mg/l	0.0010	—	1	04/22/24 18:34	04/23/24 17:02	EPA 3005A	3,200.8	NTB





Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-07

Date Collected: 04/17/24 05:21

Client ID: 306

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 17:05	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-08

Date Collected: 04/17/24 05:21

Client ID: 307

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0014		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 17:09	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-09

Date Collected: 04/17/24 05:22

Client ID: 308

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
<b>Total Metals - Mansfield Lab</b>											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 17:13	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-10

Date Collected: 04/17/24 05:23

Client ID: 309

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0011		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 17:16	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-11

Date Collected: 04/17/24 05:24

Client ID: 310

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 18:34	04/23/24 17:20	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-12

Date Collected: 04/17/24 05:25

Client ID: 312

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 18:34	04/23/24 17:24	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-13

Date Collected: 04/17/24 05:26

Client ID: 313

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 18:34	04/23/24 17:27	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Project Number: AL24-0474A-1

Lab Number: L2421097

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-14

Client ID: 314

Sample Location: GYM-C

Date Collected: 04/17/24 05:27

Date Received: 04/17/24

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 17:31	EPA 3005A	3,200.8	NTB





Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-15

Date Collected: 04/17/24 05:28

Client ID: 315

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 17:54	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-16

Date Collected: 04/17/24 05:29

Client ID: 316

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 18:34	04/23/24 17:58	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-17

Date Collected: 04/17/24 05:29

Client ID: 317

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 18:01	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Project Number: AL24-0474A-1

Lab Number: L2421097

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-18

Client ID: 318

Sample Location: GYM-C

Date Collected: 04/17/24 05:30

Date Received: 04/17/24

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 18:05	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Project Number: AL24-0474A-1

Lab Number: L2421097

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-19

Client ID: 319

Sample Location: GYM-C

Date Collected: 04/17/24 05:31

Date Received: 04/17/24

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0030		mg/l	0.0010	--	1	04/22/24 18:34	04/23/24 18:09	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-20

Date Collected: 04/17/24 05:32

Client ID: 320

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0050		mg/l	0.0010	-	1	04/22/24 18:34	04/23/24 18:13	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-21

Date Collected: 04/17/24 05:32

Client ID: 321

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
<b>Total Metals - Mansfield Lab</b>											
Lead, Total	0.0017		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 18:52	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-22

Date Collected: 04/17/24 05:33

Client ID: 322

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
<b>Total Metals - Mansfield Lab</b>											
Lead, Total	0.0025		mg/l	0.0010	—	1	04/22/24 16:39	04/23/24 19:03	EPA 3005A	3,200.8	NTB





Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-23

Date Collected: 04/17/24 05:34

Client ID: 323

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 16:39	04/23/24 18:16	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-24

Date Collected: 04/17/24 05:35

Client ID: 324

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 18:20	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-25

Date Collected: 04/17/24 05:36

Client ID: 325

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 18:37	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-26

Date Collected: 04/17/24 05:36

Client ID: 327

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 16:39	04/23/24 18:40	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-27

Date Collected: 04/17/24 05:38

Client ID: 328

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0072		mg/l	0.0010	-	1	04/22/24 16:39	04/23/24 18:44	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-28

Date Collected: 04/17/24 05:38

Client ID: 329

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0028		mg/l	0.0010	---	1	04/22/24 16:39	04/23/24 18:48	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

**SAMPLE RESULTS**

Lab ID: L2421097-29

Date Collected: 04/17/24 05:40

Client ID: 331

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
<b>Total Metals - Mansfield Lab</b>											
Lead, Total	0.0046		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:21	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-30

Date Collected: 04/17/24 05:40

Client ID: 332

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.001		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:25	EPA 3005A	3,200.8	NTB





Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-31

Date Collected: 04/17/24 05:42

Client ID: 333

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0028		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:29	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-32

Date Collected: 04/17/24 05:43

Client ID: 334

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0018		mg/l	0.0010	—	1	04/22/24 16:39	04/23/24 19:32	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-33

Date Collected: 04/17/24 05:43

Client ID: 335

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0027		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:36	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-34

Date Collected: 04/17/24 05:44

Client ID: 336

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 16:39	04/23/24 19:40	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-35

Date Collected: 04/17/24 05:45

Client ID: 337

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:44	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-36

Date Collected: 04/17/24 05:45

Client ID: 338

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0023		mg/l	0.0010		1	04/22/24 16:39	04/23/24 19:47	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-37

Date Collected: 04/17/24 05:47

Client ID: 339

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 16:39	04/23/24 19:51	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-38

Date Collected: 04/17/24 05:47

Client ID: 340

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 19:55	EPA 3005A	3,200.8	NTB





Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-39

Date Collected: 04/17/24 05:48

Client ID: 341

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/22/24 16:39	04/23/24 20:13	EPA 3005A	3,200.8	NTB



Project Name: SANDY CREEK CS

Lab Number: L2421097

Project Number: AL24-0474A-1

Report Date: 04/24/24

## SAMPLE RESULTS

Lab ID: L2421097-40

Date Collected: 04/17/24 05:56

Client ID: 342

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/22/24 16:39	04/23/24 20:17	EPA 3005A	3,200.8	NTB



**Project Name:** SANDY CREEK CS  
**Project Number:** AL24-0474A-2

**Lab Number:** L2421103  
**Report Date:** 04/25/24

**SAMPLE RESULTS**

**Lab ID:** L2421103-01  
**Client ID:** 343  
**Sample Location:** GYM-C

**Date Collected:** 04/17/24 05:56  
**Date Received:** 04/17/24  
**Field Prep:** Not Specified

**Sample Depth:**  
**Matrix:** Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 11:28	04/25/24 07:55	EPA 3005A	3,200.8	EJF



Project Name: SANDY CREEK CS

Lab Number: L2421103

Project Number: AL24-0474A-2

Report Date: 04/25/24

## SAMPLE RESULTS

Lab ID: L2421103-02

Date Collected: 04/17/24 05:57

Client ID: 344

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 11:28	04/25/24 07:59	EPA 3005A	3,200.8	EJF



Project Name: SANDY CREEK CS

Lab Number: L2421103

Project Number: AL24-0474A-2

Report Date: 04/25/24

## SAMPLE RESULTS

Lab ID: L2421103-03

Date Collected: 04/17/24 05:54

Client ID: 345

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 11:28	04/25/24 08:16	EPA 3005A	3,200.8	EJF



Project Name: SANDY CREEK CS

Lab Number: L2421103

Project Number: AL24-0474A-2

Report Date: 04/25/24

## SAMPLE RESULTS

Lab ID: L2421103-04

Date Collected: 04/17/24 05:55

Client ID: 346

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 11:28	04/25/24 08:20	EPA 3005A	3,200.8	EJF



Project Name: SANDY CREEK CS

Lab Number: L2421103

Project Number: AL24-0474A-2

Report Date: 04/25/24

## SAMPLE RESULTS

Lab ID: L2421103-05

Date Collected: 04/17/24 05:53

Client ID: 347

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	0.0015		mg/l	0.0010	--	1	04/23/24 11:28	04/25/24 08:23	EPA 3005A	3,200.8	EJF



Project Name: SANDY CREEK CS

Lab Number: L2421103

Project Number: AL24-0474A-2

Report Date: 04/25/24

## SAMPLE RESULTS

Lab ID: L2421103-06

Date Collected: 04/17/24 05:52

Client ID: 348

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 11:28	04/25/24 08:27	EPA 3005A	3,200.8	EJF





Project Name: SANDY CREEK CS

Lab Number: L2421103

Project Number: AL24-0474A-2

Report Date: 04/25/24

## SAMPLE RESULTS

Lab ID: L2421103-07

Date Collected: 04/17/24 05:50

Client ID: 349

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	—	1	04/23/24 11:28	04/25/24 08:31	EPA 3005A	3,200.8	EJF



Project Name: SANDY CREEK CS

Lab Number: L2421103

Project Number: AL24-0474A-2

Report Date: 04/25/24

## SAMPLE RESULTS

Lab ID: L2421103-08

Date Collected: 04/17/24 05:51

Client ID: 351

Date Received: 04/17/24

Sample Location: GYM-C

Field Prep: Not Specified

Sample Depth:

Matrix: Dw

Parameter	Result	Qualifier	Units	RL	MDL	Dilution Factor	Date Prepared	Date Analyzed	Prep Method	Analytical Method	Analyst
Total Metals - Mansfield Lab											
Lead, Total	ND		mg/l	0.0010	--	1	04/23/24 11:28	04/25/24 08:34	EPA 3005A	3,200.8	EJF

