

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:23:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-001

Client Sample ID: ROOM 1502 SINK

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:20:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-002

Client Sample ID: ROOM 1440 SINK

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:26:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-003

Client Sample ID: ROOM 1429 SINK

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:28:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-004

Client Sample ID: ROOM 1428 SINK

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:30:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-005

Client Sample ID: ROOM 1425 SINK

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:30:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-006

Client Sample ID: DRINKING FOUNTAIN #1

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:31:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-007

Client Sample ID: DRINKING FOUNTAIN #2

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:34:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-008

Client Sample ID: ROOM 1116 SINK

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:35:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-009

Client Sample ID: ROOM 1108 SINK

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :					<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>	<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:36:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-010

Client Sample ID: ROOM 11105 SINK

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:38:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-011

Client Sample ID: ROOM 1204 SINK

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:45:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-012

**Client Sample ID: ROOM 1202 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:46:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-013

**Client Sample ID: ROOM 1203 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:47:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-014

**Client Sample ID: ROOM 1205 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :					<u>Analyst:</u> Sub
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:49:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-015

**Client Sample ID: ROOM 1206 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:50:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-016

**Client Sample ID: ROOM 1207 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:51:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-017

**Client Sample ID: ROOM 1208 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :					<u>Analyst:</u> Sub
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:53:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-018

**Client Sample ID: ROOM 1302 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:54:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-019

**Client Sample ID: ROOM 1303 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:55:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-020

**Client Sample ID: ROOM 1304 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:56:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-021

**Client Sample ID: ROOM 1305 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:57:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-022

**Client Sample ID: ROOM 1014 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :					<u>Analyst:</u> Sub
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016 Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 5:59:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-023

**Client Sample ID: ROOM 1013 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 6:01:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-024

Client Sample ID: PLAYGROUND 1

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 6:02:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-025

Client Sample ID: PLAYGROUND 2

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 6:04:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-026

**Client Sample ID: ROOM 1012 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 6:05:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-027

**Client Sample ID: ROOM 1011 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 6:06:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-028

**Client Sample ID: ROOM 1009 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 6:08:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-029

**Client Sample ID: ROOM 1310 DRINKING
FOUNTAIN**

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :					<u>Analyst:</u> Sub
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Container:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016 Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC
unless otherwise noted.

This report shall not be reproduced except in full,
without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 6:09:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-030

Client Sample ID: DRINKING FOUNTAIN #3

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-	+	1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

LABORATORY RESULTS

Results are only for the samples and analytes requested.

The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

Sandy Creek Central School District

124 Salisbury

Sandy Creek, NY 13145

Attn To : Andy Ridgeway

Collected : 5/19/2016 6:10:00 AM

Received : 5/20/2016 9:35:00 AM ELEMENTARY

Collected By JM99

Lab No. : 1605J63-031

Client Sample ID: DRINKING FOUNTAIN #4

Sample Information:

Type : Potable Water

Origin:

<u>Analytical Method:</u> SUB :				<u>Analyst:</u> Sub	
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Analyzed:</u>
Subcontract (See Attached)	-		+ 1		06/08/2016
					<u>Container:</u>
					Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound


P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Date Reported : 6/9/2016



Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040 FAX: (631) 420-8436
Website: www.pacelabs.com

Sample Receipt Checklist

Client Name **SCCSD**

Date and Time Received: **5/20/2016 9:35:00 AM**

Work Order Number: **1605J63**

RcptNo: **1**

Received by **Erick Johnson**

Completed by:

Maressa Fudin

Reviewed by:

Elizabeth Harrison

Completed Date: 5/20/2016 6:10:15 PM

Reviewed Date: 5/23/2016 10:46:25 PM

Carrier name: FedEx

Chain of custody present?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Chain of custody signed when relinquished and received?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Chain of custody agrees with sample labels?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Are matrices correctly identified on Chain of custody?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Is it clear what analyses were requested?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Custody seals intact on sample bottles?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	Not Present <input checked="" type="checkbox"/>	
Samples in proper container/bottle?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Were correct preservatives used and noted?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>	
Preservative added to bottles:				
Sample Condition?	Intact <input checked="" type="checkbox"/>	Broken <input type="checkbox"/>	Leaking <input type="checkbox"/>	
Sufficient sample volume for indicated test?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Were container labels complete (ID, Pres, Date)?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
All samples received within holding time?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Was an attempt made to cool the samples?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>	
All samples received at a temp. of > 0° C to 6.0° C?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	NA <input type="checkbox"/>	
Response when temperature is outside of range:				
Sample Temp. taken and recorded upon receipt?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	To 1.2 ° <input type="checkbox"/>	
Water - Were bubbles absent in VOC vials?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	No Vials <input checked="" type="checkbox"/>	
Water - Was there Chlorine Present?	Yes <input type="checkbox"/>	No <input type="checkbox"/>	NA <input checked="" type="checkbox"/>	
Water - pH acceptable upon receipt?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>	No Water <input type="checkbox"/>	
Are Samples considered acceptable?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Custody Seals present?	Yes <input checked="" type="checkbox"/>	No <input type="checkbox"/>		
Airbill or Sticker?	Air Bil <input checked="" type="checkbox"/>	Sticker <input type="checkbox"/>	Not Present <input type="checkbox"/>	
Airbill No:	7831 4911 7409			

Case Number:

SDG:

SAS:

Any No response should be detailed in the comments section below, if applicable.

Client Contacted? ☐ Yes ☐ No ☒ NA Person Contacted:
Contact Mode: ☐ Phone: ☐ Fax: ☐ Email: ☐ In Person:
Client Instructions:
Date Contacted: Contacted By:
Regarding:
Comments:
CorrectiveAction:

WorkOrder :
1605J63

Certifications

STATE	CERTIFICATION #
NEW YORK	10478
NEW JERSEY	NY158
CONNECTICUT	PH-0435
MARYLAND	208
MASSACHUSETTS	MA-NY026
NEW HAMPSHIRE	2987
RHODE ISLAND	LAO00340
PENNSYLVANIA	68-00350

CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Pace Analytical
www.paceanalytical.com

Page: <u>1</u> of <u>3</u>																																																																																																																																																																																																																																													
REGULATORY AGENCY																																																																																																																																																																																																																																													
<input type="checkbox"/> NPDES <input type="checkbox"/> GROUND WATER <input type="checkbox"/> DRINKING WATER <input type="checkbox"/> UST <input type="checkbox"/> RCRA <input type="checkbox"/> OTHER _____																																																																																																																																																																																																																																													
SITE LOCATION <input type="checkbox"/> GA <input type="checkbox"/> IL <input type="checkbox"/> IN <input type="checkbox"/> MI <input type="checkbox"/> NC <input type="checkbox"/> OH <input type="checkbox"/> SC <input type="checkbox"/> WI <input type="checkbox"/> OTHER <u>NY</u>																																																																																																																																																																																																																																													
Filtered (Y/N) _____ Requested _____ Analyte _____ Preservatives: <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> HNO ₃ <input type="checkbox"/> HCl <input type="checkbox"/> NaOH <input type="checkbox"/> Na ₂ SO ₃ <input type="checkbox"/> Methanol <input type="checkbox"/> Na ₂ S ₂ O ₄ Unpreserved _____ Pace Project No. Lab I.D. <u>16053603</u>																																																																																																																																																																																																																																													
Section A Required Client Information: Company: <u>Sandy Creek CSD</u> Address: _____ Email To: <u>atidgew@scsccs.nytic.org</u> Phone: _____ Project Name: <u>ELEMENTARY</u> Project Number: _____ Requested Due Date/TAT: <u>10 DAYS</u>																																																																																																																																																																																																																																													
Section B Required Project Information: Report To: _____ Copy To: _____ Address: _____ Pace Quote Reference: _____ Pace Project Manager: _____ Pace Profile #: _____																																																																																																																																																																																																																																													
Section C Invoice Information: Attention: _____ Company Name: _____ Address: _____ Pace Quote Reference: _____ Pace Project Manager: _____ Pace Profile #: _____																																																																																																																																																																																																																																													
Section D Required Client Information <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">ITEM #</th> <th rowspan="2">Valid Matrix Codes</th> <th rowspan="2">MATRIX</th> <th rowspan="2">CODE</th> <th colspan="2">COLLECTED</th> <th rowspan="2">SAMPLE TEMP AT COLLECTION</th> <th rowspan="2"># OF CONTAINERS</th> <th rowspan="2">PRESERVATIVES</th> <th rowspan="2">Unpreserved</th> <th rowspan="2">H₂SO₄</th> <th rowspan="2">HNO₃</th> <th rowspan="2">HCl</th> <th rowspan="2">NaOH</th> <th rowspan="2">Na₂SO₃</th> <th rowspan="2">Methanol</th> <th rowspan="2">Na₂S₂O₄</th> <th rowspan="2">Pace Project No. Lab I.D.</th> </tr> <tr> <th>COMPOSITE START</th> <th>COMPOSITE END/GRAB</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>ROOM 1502 SINK</td> <td>DW</td> <td>G</td> <td>5/19</td> <td>5:23</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>2</td> <td>ROOM 1440 SINK</td> <td>DW</td> <td>G</td> <td></td> <td>5:20</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>3</td> <td>ROOM 1429 SINK</td> <td>DW</td> <td>G</td> <td></td> <td>5:26</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>4</td> <td>ROOM 1428 SINK</td> <td>DW</td> <td>G</td> <td></td> <td>5:28</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>5</td> <td>ROOM 1425 SINK</td> <td>DW</td> <td>G</td> <td></td> <td>5:30</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>6</td> <td>DRINKING FOUNTAIN #1</td> <td>DW</td> <td>G</td> <td></td> <td>5:30</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>7</td> <td>DRINKING FOUNTAIN #2</td> <td>DW</td> <td>G</td> <td></td> <td>5:31</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>8</td> <td>ROOM 1116 SINK</td> <td>DW</td> <td>G</td> <td></td> <td>5:34</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>9</td> <td>ROOM 1108 SINK</td> <td>DW</td> <td>G</td> <td></td> <td>5:35</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>10</td> <td>ROOM 1110 SINK</td> <td>DW</td> <td>G</td> <td></td> <td>5:36</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>11</td> <td>ROOM 1204 SINK</td> <td>DW</td> <td>G</td> <td></td> <td>5:38</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>12</td> <td>ROOM 1202 DRINKING FOUNTAIN</td> <td>DW</td> <td>G</td> <td></td> <td>5:45</td> <td>1</td> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>		ITEM #	Valid Matrix Codes	MATRIX	CODE	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	PRESERVATIVES	Unpreserved	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ SO ₃	Methanol	Na ₂ S ₂ O ₄	Pace Project No. Lab I.D.	COMPOSITE START	COMPOSITE END/GRAB	1	ROOM 1502 SINK	DW	G	5/19	5:23	1	1											2	ROOM 1440 SINK	DW	G		5:20	1	1											3	ROOM 1429 SINK	DW	G		5:26	1	1											4	ROOM 1428 SINK	DW	G		5:28	1	1											5	ROOM 1425 SINK	DW	G		5:30	1	1											6	DRINKING FOUNTAIN #1	DW	G		5:30	1	1											7	DRINKING FOUNTAIN #2	DW	G		5:31	1	1											8	ROOM 1116 SINK	DW	G		5:34	1	1											9	ROOM 1108 SINK	DW	G		5:35	1	1											10	ROOM 1110 SINK	DW	G		5:36	1	1											11	ROOM 1204 SINK	DW	G		5:38	1	1											12	ROOM 1202 DRINKING FOUNTAIN	DW	G		5:45	1	1										
ITEM #	Valid Matrix Codes					MATRIX	CODE													COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	PRESERVATIVES	Unpreserved	H ₂ SO ₄	HNO ₃	HCl	NaOH	Na ₂ SO ₃	Methanol	Na ₂ S ₂ O ₄	Pace Project No. Lab I.D.																																																																																																																																																																																																												
		COMPOSITE START	COMPOSITE END/GRAB																																																																																																																																																																																																																																										
1	ROOM 1502 SINK	DW	G	5/19	5:23	1	1																																																																																																																																																																																																																																						
2	ROOM 1440 SINK	DW	G		5:20	1	1																																																																																																																																																																																																																																						
3	ROOM 1429 SINK	DW	G		5:26	1	1																																																																																																																																																																																																																																						
4	ROOM 1428 SINK	DW	G		5:28	1	1																																																																																																																																																																																																																																						
5	ROOM 1425 SINK	DW	G		5:30	1	1																																																																																																																																																																																																																																						
6	DRINKING FOUNTAIN #1	DW	G		5:30	1	1																																																																																																																																																																																																																																						
7	DRINKING FOUNTAIN #2	DW	G		5:31	1	1																																																																																																																																																																																																																																						
8	ROOM 1116 SINK	DW	G		5:34	1	1																																																																																																																																																																																																																																						
9	ROOM 1108 SINK	DW	G		5:35	1	1																																																																																																																																																																																																																																						
10	ROOM 1110 SINK	DW	G		5:36	1	1																																																																																																																																																																																																																																						
11	ROOM 1204 SINK	DW	G		5:38	1	1																																																																																																																																																																																																																																						
12	ROOM 1202 DRINKING FOUNTAIN	DW	G		5:45	1	1																																																																																																																																																																																																																																						
Section E ADDITIONAL COMMENTS <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>RELINQUISHED BY / AFFILIATION</th> <th>DATE</th> <th>TIME</th> <th>ACCEPTED BY / AFFILIATION</th> <th>DATE</th> <th>TIME</th> <th>SAMPLE CONDITIONS</th> </tr> </thead> <tbody> <tr> <td><u>James Murphy PACE</u></td> <td><u>5/19/16</u></td> <td><u>17:00</u></td> <td><u>Edy</u></td> <td><u>5/20</u></td> <td><u>9:35</u></td> <td>Received on Ice Y/N <input checked="" type="checkbox"/> Custody Sealed Y/N <input checked="" type="checkbox"/> Cooler Y/N <input checked="" type="checkbox"/> Samples Intact Y/N <input checked="" type="checkbox"/></td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>		RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS	<u>James Murphy PACE</u>	<u>5/19/16</u>	<u>17:00</u>	<u>Edy</u>	<u>5/20</u>	<u>9:35</u>	Received on Ice Y/N <input checked="" type="checkbox"/> Custody Sealed Y/N <input checked="" type="checkbox"/> Cooler Y/N <input checked="" type="checkbox"/> Samples Intact Y/N <input checked="" type="checkbox"/>																																																																																																																																																																																																																														
RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS																																																																																																																																																																																																																																							
<u>James Murphy PACE</u>	<u>5/19/16</u>	<u>17:00</u>	<u>Edy</u>	<u>5/20</u>	<u>9:35</u>	Received on Ice Y/N <input checked="" type="checkbox"/> Custody Sealed Y/N <input checked="" type="checkbox"/> Cooler Y/N <input checked="" type="checkbox"/> Samples Intact Y/N <input checked="" type="checkbox"/>																																																																																																																																																																																																																																							
Section F SAMPLER NAME AND SIGNATURE PRINT Name of SAMPLER: <u>James Murphy PACE</u> SIGNATURE of SAMPLER: <u>James Murphy</u> DATE Signed (MM/DD/YY): <u>5/19/16</u>																																																																																																																																																																																																																																													

2031 4211-7409

Face Analytical™
www.facelabs.com

www.pacelabs.com

[illegible]

7831 138C
7409 116h
60hC

[illegible]

7831 4911 7409

File(A110020 rev. 4 '29 Mar '65) 22 Jun 70 05

June 09, 2016

Betty Harrison
Pace Analytical Melville
575 Broad Hollow Road
Melville, NY 11747

RE: Project: 1605J63
Pace Project No.: 35247875

Dear Betty Harrison:

Enclosed are the analytical results for sample(s) received by the laboratory on June 07, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current TNI standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Bo Garcia
bo.garcia@pacelabs.com
Project Manager

Enclosures

cc: Jennifer Aracri, Pace Analytical Melville
Caitlin Hutchinson, Pace Analytical Services, Inc.
Stu Murrell, Pace Analytical Services, Inc.
Susan Richter, Pace Analytical Services, Inc.
Joann Slavin, Pace Analytical Melville
Sophia Sparks, Pace Analytical Services, Inc.



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

CERTIFICATIONS

Project: 1605J63

Pace Project No.: 35247875

Ormond Beach Certification IDs

8 East Tower Circle, Ormond Beach, FL 32174
Alabama Certification #: 41320
Connecticut Certification #: PH-0216
Delaware Certification: FL NELAC Reciprocity
Florida Certification #: E83079
Georgia Certification #: 955
Guam Certification: FL NELAC Reciprocity
Hawaii Certification: FL NELAC Reciprocity
Illinois Certification #: 200068
Indiana Certification: FL NELAC Reciprocity
Kansas Certification #: E-10383
Louisiana Certification #: FL NELAC Reciprocity
Louisiana Environmental Certificate #: 05007
Maryland Certification: #346
Michigan Certification #: 9911
Mississippi Certification: FL NELAC Reciprocity
Missouri Certification #: 236
Montana Certification #: Cert 0074

Nebraska Certification: NE-OS-28-14
Nevada Certification: FL NELAC Reciprocity
New York Certification #: 11608
North Carolina Environmental Certificate #: 667
North Carolina Certification #: 12710
North Dakota Certification #: R-216
Oklahoma Certification #: D9947
Pennsylvania Certification #: 68-00547
Puerto Rico Certification #: FL01264
South Carolina Certification: #96042001
Tennessee Certification #: TN02974
Texas Certification: FL NELAC Reciprocity
US Virgin Islands Certification: FL NELAC Reciprocity
Virginia Environmental Certification #: 460165
Wyoming Certification: FL NELAC Reciprocity
West Virginia Certification #: 9962C
Wisconsin Certification #: 399079670
Wyoming (EPA Region 8): FL NELAC Reciprocity

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

SAMPLE SUMMARY

Project: 1605J63
Pace Project No.: 35247875

Lab ID	Sample ID	Matrix	Date Collected	Date Received
35247875001	ROOM 1502 SINK	Drinking Water	05/19/16 05:23	06/07/16 05:11
35247875002	ROOM 1440 SINK	Drinking Water	05/19/16 05:20	06/07/16 05:11
35247875003	ROOM 1429 SINK	Drinking Water	05/19/16 05:26	06/07/16 05:11
35247875004	ROOM 1428 SINK	Drinking Water	05/19/16 05:28	06/07/16 05:11
35247875005	ROOM 1425 SINK	Drinking Water	05/19/16 05:30	06/07/16 05:11
35247875006	DRINKING FOUNTAIN #1	Drinking Water	05/19/16 05:30	06/07/16 05:11
35247875007	DRINKING FOUNTAIN #2	Drinking Water	05/19/16 05:31	06/07/16 05:11
35247875008	ROOM 1116 SINK	Drinking Water	05/19/16 05:34	06/07/16 05:11
35247875009	ROOM 1108 SINK	Drinking Water	05/19/16 05:35	06/07/16 05:11
35247875010	ROOM 11105 SINK	Drinking Water	05/19/16 05:36	06/07/16 05:11
35247875011	ROOM 1204 SINK	Drinking Water	05/19/16 05:38	06/07/16 05:11
35247875012	ROOM 1202 DRINKING FOUNTAIN	Drinking Water	05/19/16 05:45	06/07/16 05:11
35247875013	ROOM 1203 DRINKING FOUNTAIN	Drinking Water	05/19/16 05:46	06/07/16 05:11
35247875014	ROOM 1205 DRINKING FOUNTAIN	Drinking Water	05/19/16 05:47	06/07/16 05:11
35247875015	ROOM 1206 DRINKING FOUNTAIN	Drinking Water	05/19/16 05:49	06/07/16 05:11
35247875016	ROOM 1207 DRINKING FOUNTAIN	Drinking Water	05/19/16 05:50	06/07/16 05:11
35247875017	ROOM 1208 DRINKING FOUNTAIN	Drinking Water	05/19/16 05:51	06/07/16 05:11
35247875018	ROOM 1302 DRINKING FOUNTAIN	Drinking Water	05/19/16 05:53	06/07/16 05:11
35247875019	ROOM 1303 DRINKING FOUNTAIN	Drinking Water	05/19/16 05:54	06/07/16 05:11
35247875020	ROOM 1304 DRINKING FOUNTAIN	Drinking Water	05/19/16 05:55	06/07/16 05:11
35247875021	ROOM 1305 DRINKING FOUNTAIN	Drinking Water	05/19/16 05:56	06/07/16 05:11
35247875022	ROOM 1014 DRINKING FOUNTAIN	Drinking Water	05/19/16 05:57	06/07/16 05:11
35247875023	ROOM 1013 DRINKING FOUNTAIN	Drinking Water	05/19/16 05:59	06/07/16 05:11
35247875024	PLAYGROUND 1	Drinking Water	05/19/16 06:01	06/07/16 05:11
35247875025	PLAYGROUND 2	Drinking Water	05/19/16 06:02	06/07/16 05:11
35247875026	ROOM 1012 DRINKING FOUNTAIN	Drinking Water	05/19/16 06:04	06/07/16 05:11
35247875027	ROOM 1011 DRINKING FOUNTAIN	Drinking Water	05/19/16 06:05	06/07/16 05:11
35247875028	ROOM 1009 DRINKING FOUNTAIN	Drinking Water	05/19/16 06:06	06/07/16 05:11
35247875029	ROOM 1310 DRINKING FOUNTAIN	Drinking Water	05/19/16 06:08	06/07/16 05:11
35247875030	DRINKING FOUNTAIN #3	Drinking Water	05/19/16 06:09	06/07/16 05:11
35247875031	DRINKING FOUNTAIN #4	Drinking Water	05/19/16 06:10	06/07/16 05:11

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

SAMPLE ANALYTE COUNT

Project: 1605J63
Pace Project No.: 35247875

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
35247875001	ROOM 1502 SINK	EPA 200.8	CKJ	1	PASI-O
35247875002	ROOM 1440 SINK	EPA 200.8	CKJ	1	PASI-O
35247875003	ROOM 1429 SINK	EPA 200.8	CKJ	1	PASI-O
35247875004	ROOM 1428 SINK	EPA 200.8	CKJ	1	PASI-O
35247875005	ROOM 1425 SINK	EPA 200.8	CKJ	1	PASI-O
35247875006	DRINKING FOUNTAIN #1	EPA 200.8	CKJ	1	PASI-O
35247875007	DRINKING FOUNTAIN #2	EPA 200.8	CKJ	1	PASI-O
35247875008	ROOM 1116 SINK	EPA 200.8	CKJ	1	PASI-O
35247875009	ROOM 1108 SINK	EPA 200.8	CKJ	1	PASI-O
35247875010	ROOM 11105 SINK	EPA 200.8	DRS	1	PASI-O
35247875011	ROOM 1204 SINK	EPA 200.8	DRS	1	PASI-O
35247875012	ROOM 1202 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875013	ROOM 1203 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875014	ROOM 1205 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875015	ROOM 1206 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875016	ROOM 1207 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875017	ROOM 1208 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875018	ROOM 1302 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875019	ROOM 1303 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875020	ROOM 1304 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875021	ROOM 1305 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875022	ROOM 1014 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875023	ROOM 1013 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875024	PLAYGROUND 1	EPA 200.8	DRS	1	PASI-O
35247875025	PLAYGROUND 2	EPA 200.8	DRS	1	PASI-O
35247875026	ROOM 1012 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875027	ROOM 1011 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875028	ROOM 1009 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875029	ROOM 1310 DRINKING FOUNTAIN	EPA 200.8	DRS	1	PASI-O
35247875030	DRINKING FOUNTAIN #3	EPA 200.8	DRS	1	PASI-O
35247875031	DRINKING FOUNTAIN #4	EPA 200.8	DRS	1	PASI-O

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1502 SINK		Lab ID: 35247875001	Collected: 05/19/16 05:23	Received: 06/07/16 05:11	Matrix: Drinking Water				
Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	1.0	ug/L	1.0	0.50	1		06/08/16 11:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1440 SINK **Lab ID: 35247875002** Collected: 05/19/16 05:20 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	1.8	ug/L	1.0	0.50	1		06/08/16 12:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1429 SINK **Lab ID: 35247875003** Collected: 05/19/16 05:26 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
Lead	11.0	ug/L	1.0	0.50	1		06/08/16 12:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1428 SINK **Lab ID: 35247875004** Collected: 05/19/16 05:28 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	5.6	ug/L	1.0	0.50	1		06/08/16 12:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1425 SINK **Lab ID: 35247875005** Collected: 05/19/16 05:30 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	2.6	ug/L	1.0	0.50	1		06/08/16 12:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63

Pace Project No.: 35247875

Sample: DRINKING FOUNTAIN #1 **Lab ID: 35247875006** Collected: 05/19/16 05:30 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/08/16 12:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63

Pace Project No.: 35247875

Sample: DRINKING FOUNTAIN #2 **Lab ID: 35247875007** Collected: 05/19/16 05:31 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/08/16 12:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1116 SINK **Lab ID: 35247875008** Collected: 05/19/16 05:34 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	2.2	ug/L	1.0	0.50	1		06/08/16 12:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1108 SINK		Lab ID: 35247875009	Collected: 05/19/16 05:35	Received: 06/07/16 05:11	Matrix: Drinking Water				
Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	2.5	ug/L	1.0	0.50	1		06/08/16 12:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 11105 SINK **Lab ID: 35247875010** Collected: 05/19/16 05:36 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	2.5	ug/L	1.0	0.50	1		06/07/16 21:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1204 SINK		Lab ID: 35247875011	Collected: 05/19/16 05:38	Received: 06/07/16 05:11	Matrix: Drinking Water				
Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	1.1	ug/L	1.0	0.50	1		06/07/16 21:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1202 DRINKING FOUNTAIN **Lab ID:** 35247875012 Collected: 05/19/16 05:45 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 21:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1203 DRINKING FOUNTAIN **Lab ID:** 35247875013 Collected: 05/19/16 05:46 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 21:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1205 DRINKING FOUNTAIN **Lab ID:** 35247875014 Collected: 05/19/16 05:47 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 21:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1206 DRINKING FOUNTAIN **Lab ID: 35247875015** Collected: 05/19/16 05:49 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 21:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1207 DRINKING FOUNTAIN **Lab ID:** 35247875016 Collected: 05/19/16 05:50 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 21:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1208 DRINKING FOUNTAIN **Lab ID:** 35247875017 Collected: 05/19/16 05:51 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 21:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1302 DRINKING FOUNTAIN **Lab ID:** 35247875018 Collected: 05/19/16 05:53 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 21:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1303 DRINKING FOUNTAIN **Lab ID:** 35247875019 Collected: 05/19/16 05:54 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 21:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1304 DRINKING FOUNTAIN **Lab ID: 35247875020** Collected: 05/19/16 05:55 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 21:45	7439-92-1	M1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1305 DRINKING FOUNTAIN **Lab ID:** 35247875021 Collected: 05/19/16 05:56 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 21:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1014 DRINKING FOUNTAIN **Lab ID: 35247875022** Collected: 05/19/16 05:57 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 21:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1013 DRINKING FOUNTAIN **Lab ID:** 35247875023 Collected: 05/19/16 05:59 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 21:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: PLAYGROUND 1		Lab ID: 35247875024	Collected: 05/19/16 06:01	Received: 06/07/16 05:11	Matrix: Drinking Water				
Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 22:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: PLAYGROUND 2		Lab ID: 35247875025	Collected: 05/19/16 06:02	Received: 06/07/16 05:11	Matrix: Drinking Water				
Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8								
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 22:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1012 DRINKING FOUNTAIN **Lab ID:** 35247875026 Collected: 05/19/16 06:04 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 22:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1011 DRINKING FOUNTAIN **Lab ID: 35247875027** Collected: 05/19/16 06:05 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	1.3	ug/L	1.0	0.50	1		06/07/16 22:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1009 DRINKING FOUNTAIN **Lab ID: 35247875028** Collected: 05/19/16 06:06 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	1.1	ug/L	1.0	0.50	1		06/07/16 22:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63
Pace Project No.: 35247875

Sample: ROOM 1310 DRINKING FOUNTAIN **Lab ID:** 35247875029 Collected: 05/19/16 06:08 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/07/16 22:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63

Pace Project No.: 35247875

Sample: DRINKING FOUNTAIN #3 **Lab ID: 35247875030** Collected: 05/19/16 06:09 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/08/16 20:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

ANALYTICAL RESULTS

Project: 1605J63

Pace Project No.: 35247875

Sample: DRINKING FOUNTAIN #4 **Lab ID: 35247875031** Collected: 05/19/16 06:10 Received: 06/07/16 05:11 Matrix: Drinking Water

Parameters	Results	Units	PQL	MDL	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water									
Analytical Method: EPA 200.8									
Lead	<1.0	ug/L	1.0	0.50	1		06/08/16 20:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

QUALITY CONTROL DATA

Project: 1605J63
Pace Project No.: 35247875

QC Batch:	ICPM/12484	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
Associated Lab Samples:	35247875010, 35247875011, 35247875012, 35247875013, 35247875014, 35247875015, 35247875016, 35247875017, 35247875018, 35247875019, 35247875020, 35247875021, 35247875022, 35247875023, 35247875024, 35247875025, 35247875026, 35247875027, 35247875028, 35247875029		

METHOD BLANK:	1597257	Matrix:	Water
Associated Lab Samples:	35247875010, 35247875011, 35247875012, 35247875013, 35247875014, 35247875015, 35247875016, 35247875017, 35247875018, 35247875019, 35247875020, 35247875021, 35247875022, 35247875023, 35247875024, 35247875025, 35247875026, 35247875027, 35247875028, 35247875029		

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	0.50	06/07/16 21:13	

LABORATORY CONTROL SAMPLE: 1597258						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.8	104	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:													1597259	1597260			
			35247875010	MS	MSD												
	Parameter	Units	Result	Spike Conc.	Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual				
Lead		ug/L	2.5	50	50	49.1	54.2	93	103	70-130	10	20					

MATRIX SPIKE & MATRIX SPIKE DUPLICATE:												
1597261					1597262							
		35247875020	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Parameter	Units	Result										
Lead	ug/L	<1.0	50	50	68.8	69.3	137	139	70-130	1	20	M1

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

QUALITY CONTROL DATA

Project: 1605J63
Pace Project No.: 35247875

QC Batch:	ICPM/12491	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
Associated Lab Samples:	35247875001, 35247875002, 35247875003, 35247875004, 35247875005, 35247875006, 35247875007, 35247875008, 35247875009		

METHOD BLANK:	1597922	Matrix:	Water
Associated Lab Samples:	35247875001, 35247875002, 35247875003, 35247875004, 35247875005, 35247875006, 35247875007, 35247875008, 35247875009		

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	0.50	06/08/16 11:18	

LABORATORY CONTROL SAMPLE: 1597923

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.2	104	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 1597924 1597925

Parameter	Units	35247870018 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	1.4	50	50	55.7	55.2	109	107	70-130	1	20	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 1597926 1597927

Parameter	Units	35247875001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	1.0	50	50	55.4	56.5	109	111	70-130	2	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

QUALITY CONTROL DATA

Project: 1605J63

Pace Project No.: 35247875

QC Batch: ICPM/12499

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET No Prep Drinking Water

Associated Lab Samples: 35247875030, 35247875031

METHOD BLANK: 1598791

Matrix: Water

Associated Lab Samples: 35247875030, 35247875031

Parameter	Units	Blank Result	Reporting Limit	MDL	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	0.50	06/08/16 20:43	

LABORATORY CONTROL SAMPLE: 1598792

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.3	101	85-115	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 1598793 1598794

Parameter	Units	35247875030 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	<1.0	50	50	52.4	54.1	105	108	70-130	3	20	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 1598795 1598796

Parameter	Units	35247891021 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
Lead	ug/L	<1.0	50	50	55.1	54.8	109	108	70-130	1	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

QUALIFIERS

Project: 1605J63
Pace Project No.: 35247875

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

LABORATORIES

PASI-O Pace Analytical Services - Ormond Beach

ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: 1605J63

Pace Project No.: 35247875

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
35247875001	ROOM 1502 SINK	EPA 200.8	ICPM/12491		
35247875002	ROOM 1440 SINK	EPA 200.8	ICPM/12491		
35247875003	ROOM 1429 SINK	EPA 200.8	ICPM/12491		
35247875004	ROOM 1428 SINK	EPA 200.8	ICPM/12491		
35247875005	ROOM 1425 SINK	EPA 200.8	ICPM/12491		
35247875006	DRINKING FOUNTAIN #1	EPA 200.8	ICPM/12491		
35247875007	DRINKING FOUNTAIN #2	EPA 200.8	ICPM/12491		
35247875008	ROOM 1116 SINK	EPA 200.8	ICPM/12491		
35247875009	ROOM 1108 SINK	EPA 200.8	ICPM/12491		
35247875010	ROOM 11105 SINK	EPA 200.8	ICPM/12484		
35247875011	ROOM 1204 SINK	EPA 200.8	ICPM/12484		
35247875012	ROOM 1202 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875013	ROOM 1203 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875014	ROOM 1205 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875015	ROOM 1206 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875016	ROOM 1207 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875017	ROOM 1208 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875018	ROOM 1302 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875019	ROOM 1303 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875020	ROOM 1304 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875021	ROOM 1305 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875022	ROOM 1014 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875023	ROOM 1013 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875024	PLAYGROUND 1	EPA 200.8	ICPM/12484		
35247875025	PLAYGROUND 2	EPA 200.8	ICPM/12484		
35247875026	ROOM 1012 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875027	ROOM 1011 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875028	ROOM 1009 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875029	ROOM 1310 DRINKING FOUNTAIN	EPA 200.8	ICPM/12484		
35247875030	DRINKING FOUNTAIN #3	EPA 200.8	ICPM/12499		
35247875031	DRINKING FOUNTAIN #4	EPA 200.8	ICPM/12499		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, Inc..



CHAIN OF CUSTODY RECORD

ADDRESS
PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040
FAX: (631) 420-8436
site: www.pacelabs.com

COC ID: 5241

PAGE: 1

OF: 6

WO#: 35247875



35247875

Please Include Email Address of Report Recipient

SUB CONTRACTOR		Pace-Ormond Beach		COMPANY		Pace-Ormond Beach	
ADDRESS		8 East Tower Circle					
CITY, STATE, ZIP		Ormond Beach, FL 32174					
PHONE		(386) 672-5668		FAX		(386) 673-4001	
ACCOUNT #		70-100281		EMAIL			
ITEM	SAMPLE ID	CLIENT SAMPLE ID	BOTTLE TYPE	MATRIX	DATE COLLECTED	NUMBER OF CONTAINERS	COMMENTS: Methanol Preserved Weights HOT Sample Notation, Additional Sample Description.
1	1605J63-001A	ROOM 1502 SINK	250mlHDPEHN O3	Potable Water	5/19/2016 5:23:00 AM	1	
	200.8_DW_RT (E200.8)						
2	1605J63-002A	ROOM 1440 SINK	250mlHDPEHN O3	Potable Water	5/19/2016 5:20:00 AM	1	
	200.8_DW_RT (E200.8)						
3	1605J63-003A	ROOM 1429 SINK	250mlHDPEHN O3	Potable Water	5/19/2016 5:26:00 AM	1	
	200.8_DW_RT (E200.8)						
4	1605J63-004A	ROOM 1428 SINK	250mlHDPEHN O3	Potable Water	5/19/2016 5:28:00 AM	1	
	200.8_DW_RT (E200.8)						
5	1605J63-005A	ROOM 1425 SINK	250mlHDPEHN O3	Potable Water	5/19/2016 5:30:00 AM	1	
	200.8_DW_RT (E200.8)						
6	1605J63-006A	DRINKING FOUNTAIN #1	250mlHDPEHN O3	Potable Water	5/19/2016 5:30:00 AM	1	
	200.8_DW_RT (E200.8)						

SPECIAL INSTRUCTIONS / COMMENTS

Please analyze for Pb in drinking water by method 200.8. Results are requested by 6/9/16. Use the Client Sample ID (not sample ID as listed on paperwork) as main identifier on report. Please contact Betty Harrison @ 516-370-6013 with questions. Thank you!

Relinquished By		Date		Time		Received By		Date		Time	
Mona Gubiny		6/6/16		10:00		Mona Gubiny		6/7/16		10:00	
Relinquished By		Date		Time		Received By		Date		Time	
Relinquished By		Date		Time		Received By		Date		Time	
TAT:		Standard <input type="checkbox"/>				RUSH		Next BD <input type="checkbox"/>		2nd BD <input type="checkbox"/>	
										3rd BD <input type="checkbox"/>	
Note: RUSH requests will incur surcharges!											

REPORT TRANSMITTAL DESIRED:			
<input type="checkbox"/> HARD COPY (extra cost)	<input type="checkbox"/> FAX	<input type="checkbox"/> EMAIL	<input type="checkbox"/> ONLINE
FOR LAB USE ONLY			
Temp of samples		21.7 °C	
Comments		Attempt to Cool ?	

CHAIN OF CUSTODY RECORD

COC ID: 5241

PAGE: 2

OF: 6

ADDRESS
PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040
FAX: (631) 420-8436
Website: www.pacelabs.com

Please Include Email Address of Report Recipient Whenever Possible!!!

SUB CONTRACTOR		Pace-Ormond Beach		COMPANY:		Pace-Ormond Beach		SPECIAL INSTRUCTIONS / COMMENTS	
ADDRESS:		8 East Tower Circle						Please analyze for Pb in drinking water by method 200.8. Results are requested by 6/9/16. Use the Client Sample ID (not sample ID as listed on paperwork) as main identifier on report. Please contact Betty Harrison @ 516-370-6013 with questions. Thank you!	
CITY, STATE, ZIP		Ormond Beach, FL 32174							
PHONE		(386) 672-5668		FAX		(386) 673-4001			
ACCOUNT #		70-100281		EMAIL					
ITEM	SAMPLE ID	CLIENT SAMPLE ID	BOTTLE TYPE	MATRIX	DATE COLLECTED	NUMBER OF CONTAINERS	COMMENTS: Methanol Preserved Weights HOT Sample Notation, Additional Sample Description.		
7	1605J63-007A	DRINKING FOUNTAIN #2	250mlHDPEHN	Potable Water	5/19/2016 5:31:00 AM	1			
	200.8_DW_RT (E200.8)								
8	1605J63-008A	ROOM 1116 SINK	250mlHDPEHN	Potable Water	5/19/2016 5:34:00 AM	1			
	200.8_DW_RT (E200.8)								
9	1605J63-009A	ROOM 1108 SINK	250mlHDPEHN	Potable Water	5/19/2016 5:35:00 AM	1			
	200.8_DW_RT (E200.8)								
10	1605J63-010A	ROOM 11105 SINK	250mlHDPEHN	Potable Water	5/19/2016 5:36:00 AM	1			
	200.8_DW_RT (E200.8)								
11	1605J63-011A	ROOM 1204 SINK	250mlHDPEHN	Potable Water	5/19/2016 5:38:00 AM	1			
	200.8_DW_RT (E200.8)								
12	1605J63-012A	ROOM 1202 DRINKING FOUNTAIN	250mlHDPEHN	Potable Water	5/19/2016 5:45:00 AM	1			
	200.8_DW_RT (E200.8)								

Relinquished By: <i>Marlene Grebing</i>	Date: <i>6/17/16</i>	Time: <i>10:50</i>	Received By: <i>Marlene Grebing</i>	Date: <i>6/17/16</i>	Time: <i>10:50</i>
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:

TAT:

Standard ☐

RUSH

Next BD ☐ 2nd BD ☐ 3rd BD ☐

Note: RUSH requests will incur surcharges!

REPORT TRANSMITTAL DESIRED:

☐ HARDCOPY (extra cost)
 ☐ FAX
 ☐ EMAIL
 ☐ ONLINE

FOR LAB USE ONLY

Temp of samples

71.7 °C

Attempt to Cool ?

12.2

Comments:

7-221



CHAIN OF CUSTODY RECORD

COC ID: 5241

PAGE: 3

OF: 6

ADDRESS

PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040
FAX: (631) 420-8436
Website: www.pacelabs.com

Please Include Email Address of Report Recipient Whenever Possible!!!

SUB CONTRACTOR		COMPANY		SPECIAL INSTRUCTIONS / COMMENTS			
Pace-Ormond Beach		Pace-Ormond Beach		Please analyze for Pb in drinking water by method 200.8. Results are requested by 6/9/16. Use the Client Sample ID (not sample ID as listed on paperwork) as main identifier on report. Please contact Betty Harrison @ 516-370-6013 with questions. Thank you!			
ADDRESS		8 East Tower Circle					
CITY, STATE, ZIP		Ormond Beach, FL 32174					
PHONE		(386) 672-5668					
FAX		(386) 673-4001					
ACCOUNT #		70-100281					
EMAIL							
ITEM	SAMPLE ID	CLIENT SAMPLE ID	BOTTLE TYPE	MATRIX	DATE COLLECTED	NUMBER OF CONTAINERS	COMMENTS: Methanol Preserved Weights HOT Sample Notation, Additional Sample Description.
13	1605J63-013A	ROOM 1203 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 5:46:00 AM	1	
200.8_DW_RT (E200.8)							
14	1605J63-014A	ROOM 1205 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 5:47:00 AM	1	
200.8_DW_RT (E200.8)							
15	1605J63-015A	ROOM 1206 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 5:49:00 AM	1	
200.8_DW_RT (E200.8)							
16	1605J63-016A	ROOM 1207 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 5:50:00 AM	1	
200.8_DW_RT (E200.8)							
17	1605J63-017A	ROOM 1208 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 5:51:00 AM	1	
200.8_DW_RT (E200.8)							
18	1605J63-018A	ROOM 1302 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 5:53:00 AM	1	
200.8_DW_RT (E200.8)							

Relinquished By:		Date:	Time:	Received By:		Date:	Time:	REPORT TRANSMITTAL DESIRED:	
[Signature]		6/7/16	10:50	[Signature]		6/7/16	10:50	<input type="checkbox"/> HARD COPY (extra cost) <input type="checkbox"/> FAX <input type="checkbox"/> EMAIL <input type="checkbox"/> ONLINE	
Relinquished By:		Date:	Time:	Received By:		Date:	Time:		
Relinquished By:		Date:	Time:	Received By:		Date:	Time:		
TAT:		Standard <input type="checkbox"/>		RUSH <input type="checkbox"/>				FOR LAB USE ONLY	
		Next BD <input type="checkbox"/>		2nd BD <input type="checkbox"/>				Temp of samples 21.7 °C Attempt to Cool ?	
		3rd BD <input type="checkbox"/>						Comments: 4-221	

Note: RUSH requests will incur surcharges!



CHAIN OF CUSTODY RECORD

COC ID: 5241

PAGE: 4

OF: 6

ADDRESS
PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040
FAX: (631) 420-8436
Website: www.pacelabs.com

Please Include Email Address of Report Recipient Whenever Possible!!!

SUB CONTRACTOR		COMPANY		SPECIAL INSTRUCTIONS / COMMENTS			
Pace-Ormond Beach		Pace-Ormond Beach		Please analyze for Pb in drinking water by method 200.8. Results are requested by 6/9/16. Use the Client Sample ID (not sample ID as listed on paperwork) as main identifier on report. Please contact Betty Harrison @ 516-370-6013 with questions. Thank you!			
ADDRESS		8 East Tower Circle					
CITY, STATE, ZIP		Ormond Beach, FL 32174					
PHONE		(386) 672-5668					
FAX		(386) 673-4001					
ACCOUNT #		70-100281					
E-MAIL							
ITEM	SAMPLE ID	CLIENT SAMPLE ID	BOTTLE TYPE	MATRIX	DATE COLLECTED	NUMBER OF CONTAINERS	COMMENTS: Methanol Preserved Weights HOT Sample Notation, Additional Sample Description.
19	1605J63-019A	ROOM 1303 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 5:54:00 AM	1	
200.8_DW_RT (E200.8)							
20	1605J63-020A	ROOM 1304 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 5:55:00 AM	1	
200.8_DW_RT (E200.8)							
21	1605J63-021A	ROOM 1305 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 5:56:00 AM	1	
200.8_DW_RT (E200.8)							
22	1605J63-022A	ROOM 1014 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 5:57:00 AM	1	
200.8_DW_RT (E200.8)							
23	1605J63-023A	ROOM 1013 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 5:59:00 AM	1	
200.8_DW_RT (E200.8)							
24	1605J63-024A	PLAYGROUND 1	250mlHDPEHN O3	Potable Water	5/19/2016 6:01:00 AM	1	
200.8_DW_RT (E200.8)							

Relinquished By		Received By		REPORT TRANSMITTAL DESIRED:	
Date	Time	Date	Time	<input type="checkbox"/> HARD COPY (extra cost)	<input type="checkbox"/> FAX <input type="checkbox"/> EMAIL <input type="checkbox"/> ONLINE
<i>Michelle G. Kelly</i>	6/16/16	<i>McCurdy</i>	6/16/16 10:50		
Relinquished By		Received By			
Relinquished By		Received By			
TAT:	Standard <input type="checkbox"/>	RUSH <input type="checkbox"/>	Next BD <input type="checkbox"/>	2nd BD <input type="checkbox"/>	3rd BD <input type="checkbox"/>
Note: RUSH requests will incur surcharges!					
FOR LAB USE ONLY					
Temp of samples <u>21.7</u> °C Attempt to Cool? <u>+</u>					
Comments <u>5-22-1</u>					



CHAIN OF CUSTODY RECORD

COC ID: 5241

PAGE: 5

OF: 6

ADDRESS

PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040
FAX: (631) 420-8436
Website: www.pacelabs.com

Please Include Email Address of Report Recipient Whenever Possible!!!

SUB CONTRACTOR		Pace-Ormond Beach		COMPANY		Pace-Ormond Beach	
ADDRESS		8 East Tower Circle					
CITY, STATE, ZIP		Ormond Beach, FL 32174					
PHONE		(386) 672-5668		FAX		(386) 673-4001	
ACCOUNT #		70-100281		EMAIL			
ITEM	SAMPLE ID	CLIENT SAMPLE ID	BOTTLE TYPE	MATRIX	DATE COLLECTED	NUMBER OF CONTAINERS	COMMENTS: Methanol Preserved Weights HOT Sample Notation, Additional Sample Description.
25	1605J63-025A	PLAYGROUND 2	250mlHDPEHN O3	Potable Water	5/19/2016 6:02:00 AM	1	
200.8_DW_RT (E200.8)							
26	1605J63-026A	ROOM 1012 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 6:04:00 AM	1	
200.8_DW_RT (E200.8)							
27	1605J63-027A	ROOM 1011 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 6:05:00 AM	1	
200.8_DW_RT (E200.8)							
28	1605J63-028A	ROOM 1009 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 6:06:00 AM	1	
200.8_DW_RT (E200.8)							
29	1605J63-029A	ROOM 1310 DRINKING FOUNTAIN	250mlHDPEHN O3	Potable Water	5/19/2016 6:08:00 AM	1	
200.8_DW_RT (E200.8)							
30	1605J63-030A	DRINKING FOUNTAIN #3	250mlHDPEHN O3	Potable Water	5/19/2016 6:09:00 AM	1	
200.8_DW_RT (E200.8)							

Relinquished By: <i>[Signature]</i>	Date: 6/16/16	Time: 10:00	Received By: <i>[Signature]</i>	Date: 6/17/16	Time: 10:30
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
TAT:	Standard <input type="checkbox"/>	RUSH <input type="checkbox"/>	Next BD <input type="checkbox"/>	2nd BD <input type="checkbox"/>	3rd BD <input type="checkbox"/>
Note: RUSH requests will incur surcharges!					
REPORT TRANSMITTAL DESIRED: <input type="checkbox"/> HARDCOPY (extra cost) <input type="checkbox"/> FAX <input type="checkbox"/> EMAIL <input type="checkbox"/> ONLINE					
FOR LAB USE ONLY Temp of samples 21.7 °C Attempt to Cool ? Comments: 7-221					



CHAIN OF CUSTODY RECORD

COC ID: 5241

PAGE: 6

OF: 6


ADDRESS
PACE ANALYTICAL
575 Broad Hollow Road
Melville, NY 11747
TEL: (631) 694-3040
FAX: (631) 420-8436
Website: www.pacelabs.com

Please Include Email Address of Report Recipient Whenever Possible!!!

SUB CONTRACTOR		Pace-Ormond Beach		COMPANY		Pace-Ormond Beach	
ADDRESS		8 East Tower Circle					
CITY, STATE, ZIP		Ormond Beach, FL 32174					
PHONE:		(386) 672-5668		FAX:		(386) 673-4001	
ACCOUNT #		70-100281		EMAIL:			
ITEM	SAMPLE ID	CLIENT SAMPLE ID	BOTTLE TYPE	MATRIX	DATE COLLECTED	NUMBER OF CONTAINERS	COMMENTS: Methanol Preserved Weights HOT Sample Notation, Additional Sample Description.
31	1605J63-031A	DRINKING FOUNTAIN #4	250mlHDPEHN O3	Potable Water	5/19/2016 6:10:00 AM	1	

200.8_DW_RT (E200.8)

Relinquished By: <i>Melvin Greedy</i>	Date: 6/17/16	Time: 10:50	Received By: <i>mcenrumpster</i>	Date: 6/17/16	Time: 10:50
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
TAT:	Standard <input type="checkbox"/>	RUSH <input type="checkbox"/>	Next BD <input type="checkbox"/>	2nd BD <input type="checkbox"/>	3rd BD <input type="checkbox"/>
Note: RUSH requests will incur surcharges!					
REPORT TRANSMITTAL DESIRED:			FOR LAB USE ONLY		
<input type="checkbox"/> HARD COPY (extra cost)			<input type="checkbox"/> FAX <input type="checkbox"/> EMAIL <input type="checkbox"/> ONLINE		
Temp of samples			Temp of samples 21.7 °C		
Comments:			Comments: T-221 Attempt to Cool?		

	Document Name:	Document Revised:
	Sample Condition Upon Receipt Form	December 28, 2015
	Document No.: F-FL-C-007 rev. 07	Issuing Authority: Pace Florida Quality Office

Sample Condition Upon Receipt Form (SCUR)

Project # **WO# : 35247875**
Project Manager: PM: VEG **Due Date:** 06/09/16
Client: CLIENT: PACH2M

Date and Initials of person examining contents: MPD 6/7/1050
Label: MPD
Deliver: MPD
pH: MPD

Courier: ☒ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☐ Pace ☐ Other _____
Shipping Method: ☐ First Overnight ☒ Priority Overnight ☐ Standard Overnight ☐ Ground
Billing: ☐ Recipient ☐ Sender ☐ Third Party ☐ Unknown **Cooler Size if Applicable:** _____
Tracking # 7764 5522 5618

Custody Seal on Cooler/Box Present: ☐ yes ☒ no **Seals intact:** ☐ yes ☐ no
Packing Material: ☒ Bubble Wrap ☐ Bubble Bags ☐ None ☐ Other _____ **Biological Tissue is Frozen:** Yes No N/A
Thermometer Used T-221 **Type of Ice:** Wet Blue None ☐ Samples on ice, cooling process has begun
Cooler #1 Temperature°C 21.7 (Visual) 0 (Correction Factor) 21.7 (Actual)
Cooler #2 Temperature°C _____ (Visual) _____ (Correction Factor) _____ (Actual)
Cooler #3 Temperature°C _____ (Visual) _____ (Correction Factor) _____ (Actual)
Cooler #4 Temperature°C _____ (Visual) _____ (Correction Factor) _____ (Actual)
Cooler #5 Temperature°C _____ (Visual) _____ (Correction Factor) _____ (Actual)
Cooler #6 Temperature°C _____ (Visual) _____ (Correction Factor) _____ (Actual)

Temp should be above freezing to 6°C

Comments:

Chain of Custody Present	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Chain of Custody Filled Out	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Relinquished Signature & Sampler Name COC	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Samples Arrived within Hold Time	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Rush TAT requested on COC	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sufficient Volume	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Correct Containers Used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Pace Containers Used	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Containers Intact	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Sample Labels match COC (sample IDs & date/time of collection)	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
All containers needing acid/base preservation have been checked.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	HNO3 pH<2 HCl pH<2
All Containers needing preservation are found to be in compliance with EPA recommendation:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	H2SO4 pH<2 NaOH pH>12
Exceptions: VOA, Coliform, TOC, O&G		NaOH/ZnOAc pH>9
No Headpace in VOA Vials (>6mm):	<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	
Trip Blank Present:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Client Notification/ Resolution:

Person Contacted: _____ Date/Time: _____
 Comments/ Resolution (use back for additional comments): _____

Project Manager Review: _____ **Date:** _____