

Sandy Creek Central School District

P.O. Box 248, 124 Salisbury St., Sandy Creek, NY 13145

Lead in Drinking Water Remediation Plan for Outlets that Exceed 15ppb

- 1) Remove outlet from service immediately after receiving test results indicating this outlet has exceeded the action level.**
- 2) Permanently remove or replace outlet.**
- 3) All replaced outlets will be re-tested before being put back in service.**
- 4) Any outlet that cannot be taken out of service, because it is used for hand washing and / or cleaning, will be posted with signage. Signage will be placed on these non-drinking water outlets stating that the water should not be used for drinking; only hand washing and / or cleaning.**